FCC SAR Test Report

Applicant	:	**Shenzhen Feima Robotics Technology Co.,Ltd.**
Address	:	**13th Floor, Building A4, Nanshan Zhiyuan, No. 1001 Xueyuan Avenue, Nanshan District, Shenzhen, China**
Product Name	:	**Multi-fonctional Portable RTK Module**
Report Date	:	**Aug. 04, 2023**

Shenzhen Anbotek Compliance Laboratory Limited

Contents

1. Statement of Compliance 6
2. General Information 7
2.1. Client Information 7
2.2. Description of EquipmentUnder Test (EUT) 7
2.3. Device Category and SAR Limits 8
2.4. Applied Standard 8
2.5. Environment of Test Site 8
2.6. Test Configuration 8
3. Specific Absorption Rate (SAR) 9
3.1. Introduction 9
3.2. SAR Definition 9
4. SAR Measurement System 10
4.1. E-Field Probe 11
4.2. Data Acquisition Electronics (DAE) 11
4.3. Robot 12
4.4. Measurement Server 13
4.5. Data Storage and Evaluation 13
4.6. Phantom 16
4.7. Device Holder 17
5. Test Equipment List 18
6. Tissue Simulating Liquids 19
7. System Verification Procedures 22
8. EUT Testing Position 24
8.1. Body Worn Position 24
9. Measurement Procedures 24
9.1. Spatial Peak SAR Evaluation 25
9.2. Power Reference Measurement 25
9.3. Area Scan Procedures 25
9.4. Zoom Scan Procedures 27
9.5. Volume Scan Procedures 28
9.6. Power Drift Monitoring 28
10. Conducted Power 29
11. Antenna Location 41
12. SAR Test Results Summary 42
11.1 Body and Limbs SAR Results 43
13. Simultaneous Transmission Analysis 45
Simultaneous TX SAR Considerations 45
14. Measurement Uncertainty 46
Appendix A. EUT Photos and Test Setup Photos 48

Appendix B. Plots of SAR System Check 49
Appendix C. Plots of SAR Test Data 53
Appendix D. DASY System Calibration Certificate 57

TEST REPORT

Applicant	:	Shenzhen Feima Robotics Technology Co.,Ltd.
Manufacturer	:	Tianjin Feima Robotics Technology Co.,Ltd.
Product Name	:	Multi-fonctional Portable RTK Module
Model No.	:	S-RTK100A,RTK120GO
Trade Mark	:	N/A
Rating(s)	:	Input: 9~20V⎓ 2A Output: 9~20V⎓ 2A

Test Standard(s) : IEC/IEEE 62209-1528:2020; FCC 47 CFR Part 2.1093; ANSI/IEEE C95.1:2005; Reference FCC KDB 447498; KDB 941225; KDB 865664

The device described above is tested by Shenzhen Anbotek Compliance Laboratory Limited to determine the maximum emission levels emanating from the device and the severe levels of the device can endure and its performance criterion. The measurement results are contained in this test report and Shenzhen Anbotek Compliance Laboratory Limited is assumed full of responsibility for the accuracy and completeness of these measurements. Also, this report shows that the EUT (Equipment Under Test) is technically compliant with the IEC/IEEE 62209-1528:2020, FCC 47 CFR Part 2.1093, ANSI/IEEE C95.1:2005 requirements.

This report applies to above tested sample only and shall not be reproduced in part without written approval of Shenzhen Anbotek Compliance Laboratory Limited.

Date of Receipt	Jun. 14, 2023
Date of Test	Jun. 25 - 30, 2023
Prepared By	Ella Liang (Ella Liang)
Approved & Authorized Signer	Kingkong Jin (Kingkong Jin)

Version

Version No.	Date	Description
R00	Aug. 04, 2023	Original

1. Statement of Compliance

<Highest SAR Summary>

This device is in compliance with Specific Absorption Rate (SAR) for general population/uncontrolled exposure limits (1.6 W/kg) specified in FCC 47 CFR part 2 (2.1093) and ANSI/IEEE C95.1-2005, and had been tested in accordance with the measurement methods and procedures specified in IEEE 1528-2013 The maximum results of Specific Absorption Rate (SAR) found during testing are as follows.

<Highest SAR Summary>

Frequency Band	Highest 1g-SAR(W/Kg)	SAR Test Limit (W/Kg)
	Body&Limbs(0mm)	
LTE Band 2	0.472	1.6
LTE Band 4	0.490	
LTE Band 5	0.420	
LTE Band 41	0.425	
Simultaneous SAR	**0.498**	
Test Result	**PASS**	

Note: This device is in compliance with Specific Absorption Rate (SAR) for general population/uncontrolled exposure limits (1.6 W/kg) specified in FCC 47 CFR part 2 (2.1093) and ANSI/IEEE C95.1-2005, and had been tested in accordance with the measurement methods and procedures specified in IEEE 1528-2013

2. General Information

2.1. Client Information

Applicant	:	Shenzhen Feima Robotics Technology Co.,Ltd.
Address	:	13th Floor, Building A4, Nanshan Zhiyuan, No. 1001 Xueyuan Avenue, Nanshan District, Shenzhen, China
Manufacturer	:	Tianjin Feima Robotics Technology Co.,Ltd.
Address	:	Unit 1, Factory building A09, No1, Huandong Avenue 6, Tianjin Pilot Free Trade Zone (Airport Economic Zone), China
Factory	:	Tianjin Feima Robotics Technology Co.,Ltd.
Address	:	Unit 1, Factory building A09, No1, Huandong Avenue 6, Tianjin Pilot Free Trade Zone (Airport Economic Zone), China

2.2. Description of EquipmentUnder Test (EUT)

Product Name	:	Product manual of S-RTK100A
Model No.	:	S-RTK100A, RTK120GO (Note: All samples are the same except the log, so we prepare "S-RTK100A" for test only.)
Trade Mark	:	N/A
Test Power Supply	:	DC 20V
Test Sample No.	:	1-2-1(Engineering Sample)
Tx Frequency	:	BT BLE: 2402-2480MHz LTE-FDD Band 2: TX: 1850.7 ~ 1909.3 MHz LTE-FDD Band 4: TX: 1710.7 ~ 1754.3 MHz LTE-FDD Band 5: TX: 824.7 ~ 848.3 MHz LTE-TDD Band 41: TX: 2498.5 MHz – 2687.5 MHz
Type of Modulation	:	LTE:QPSK,16QAM BT: GFSK
Category of device	:	Portable device
Remark: The above DUT's information was declared by manufacturer. Please refer to the specifications or user's manual for more detailed description.		

2.3. Device Category and SAR Limits

This device belongs to portable device category because its radiating structure is allowed to be used within 20 centimeters of the body of the user. Limit for General Population/Uncontrolled exposure should be applied for this device, it is 1.6 W/kg as averaged over any 1 gram of tissue.

2.4. Applied Standard

The Specific Absorption Rate (SAR) testing specification, method, and procedure for this device is in accordance with the following standards:

- FCC 47 CFR Part 2.1093
- ANSI/IEEE C95.1:2005
- IEC/IEEE 62209-1528:2020
- KDB 865664 D01 SAR Measurement 100 MHz to 6 GHz v01r04
- KDB 865664 D02 RF Exposure Reporting v01r02
- KDB 447498 D01 General RF Exposure Guidance v06
- KDB 941225 D05 SAR for LTE Devicesv02r05

2.5. Environment of Test Site

Items	Required	Actual
Temperature (℃)	18-25	22~23
Humidity (%RH)	30-70	55~65

2.6. Test Configuration

The device was controlled by using a base station emulator. Communication between the device and the emulator was established by air link. The distance between the EUT and the antenna of the emulator is larger than 50 cm and the output power radiated from the emulator antenna is at least 30 dB smaller than the output power of EUT. The EUT was set from the emulator to radiate maximum output power during all tests. For WLAN SAR testing, WLAN engineering testing software installed on the EUT can provide continuous transmitting RF signal.

3. Specific Absorption Rate (SAR)

3.1. Introduction

SAR is related to the rate at which energy is absorbed per unit mass in an object exposed to a radio field. The SAR distribution in a biological body is complicated and is usually carried out by experimental techniques or numerical modeling. The standard recommends limits for two tiers of groups, occupational/controlled and general population/uncontrolled, based on a person's awareness and ability to exercise control over his or her exposure. In general, occupational/controlled exposure limits are higher than the limits for general population/uncontrolled.

3.2. SAR Definition

The SAR definition is the time derivative (rate) of the incremental energy (dW) absorbed by (dissipated in) an incremental mass (dm) contained in a volume element (dv) of a given density (ρ).The equation description is as below:

$$\mathbf{SAR} = \frac{\mathbf{d}}{\mathbf{dt}}\left(\frac{\mathbf{dW}}{\mathbf{dm}}\right) = \frac{\mathbf{d}}{\mathbf{dt}}\left(\frac{\mathbf{dW}}{\boldsymbol{\rho}\mathbf{dv}}\right)$$

SAR is expressed in units of Watts per kilogram (W/kg)

SAR measurement can be either related to the temperature elevation in tissue by

$$\mathbf{SAR} = \mathbf{C}\left(\frac{\boldsymbol{\delta}\mathbf{T}}{\boldsymbol{\delta}\mathbf{t}}\right)$$

Where: C is the specific head capacity, δT is the temperature rise and δtisthe exposure duration, or related to the electrical field in the tissue by

$$\mathbf{SAR} = \frac{\boldsymbol{\sigma}|\mathbf{E}|^2}{\boldsymbol{\rho}}$$

Where:σ is the conductivity of the tissue, ρ is the mass density of the tissue and E is the RMS electrical field strength.

However for evaluating SAR of low power transmitter, electrical field measurement is typically applied.

4. SAR Measurement System



DASY System Configurations

The DASYsystem for performance compliance tests is illustrated above graphically. This system consists of the following items:

- A standard high precision 6-axis robot with controller, a teach pendant and software
- A data acquisition electronic (DAE) attached to the robot arm extension
- A dosimetric probe equipped with an optical surface detector system
- The electro-optical converter (EOC) performs the conversion between optical and electrical signals
- A measurement server performs the time critical tasks such as signal filtering, control of the robot operation and fast movement interrupts.
- A probe alignment unit which improves the accuracy of the probe positioning
- A computer operating Windows XP
- DASY software
- Remove control with teach pendant and additional circuitry for robot safety such as warming lamps, etc.
- The SAM twin phantom
- A device holder
- Tissue simulating liquid
- Dipole for evaluating the proper functioning of the system

components are described in details in the following sub-sections.

4.1. E-Field Probe

The SAR measurement is conducted with the dosimetric probe (manufactured by SPEAG).The probe is specially designed and calibrated for use in liquid with high permittivity. The dosimetric probe has special calibration in liquid at different frequency. This probe has a built in optical surface detection system to prevent from collision with phantom.

➢ E-Field Probe Specification

<EX3DV4 Probe>

Construction	Symmetrical design with triangular core Built-in shielding against static charges PEEK enclosure material (resistant to organic solvents, e.g., DGBE)	 **Photo of EX3DV4**
Frequency	10 MHz to 6 GHz; Linearity: ± 0.2 dB	
Directivity	± 0.3 dB in HSL (rotation around probe axis) ± 0.5 dB in tissue material (rotation normal to probe axis)	
Dynamic Range	10 μW/g to 100 W/kg; Linearity: ± 0.2 dB (noise: typically< 1 μW/g)	
Dimensions	Overall length: 330 mm (Tip: 20 mm) Tip diameter: 2.5 mm (Body: 12 mm) Typical distance from probe tip to dipole centers: 1 mm	

➢ E-Field Probe Calibration

Each probe needs to be calibrated according to a dosimetric assessment procedure with accuracy better than ± 10%. The spherical isotropy shall be evaluated and within ± 0.25dB. The sensitivity parameters (NormX, NormY, and NormZ), the diode compression parameter (DCP) and the conversion factor (ConvF) of the probe are tested. The calibration data can be referred to appendix C of this report.

4.2. Data Acquisition Electronics (DAE)

The data acquisition electronics (DAE) consists of a highly sensitive electrometer-grade preamplifier with auto-zeroing, a channel and gain-switching multiplexer, a fast 16 bit AD-converter and a command decoder and control logic unit. Transmission to the measurement server is accomplished through an optical downlink for data and status information as well as an optical uplink for commands and the clock.

The input impedance of the DAE is 200MOhm; the inputs are symmetrical and floating. Common mode rejection is above 80dB.

Photo of DAE

4.3. Robot

The SPEAG DASY system uses the high precision robots (DASY5: TX60XL) type from Stäubli SA (France). For the 6-axis controllersystem, the robot controller version (DASY5: CS8c) from Stäubli is used. The Stäublirobot series have many features that are important for our application:

- High precision (repeatability ±0.035 mm)
- High reliability (industrial design)
- Jerk-free straight movements
- Low ELF interference (the closed metallic construction shields against motor control fields)

Photo of DASY5

4.4. Measurement Server

The measurement server is based on a PC/104 CPU board with CPU (DASY5: 400 MHz, Intel Celeron), chipdisk (DASY5: 128 MB), RAM (DASY5: 128 MB). The necessary circuits for communication with the DAE electronic box, as well as the 16 bit AD converter system for optical detection and digital I/O interface are contained on the DASY I/O board, which is directly connected to the PC/104 bus of the CPU board.

The measurement server performs all the real-time data evaluation for field measurements and surface detection, controls robot movements and handles safety operations.

Photo of Server for DASY5

4.5. Data Storage and Evaluation

- Data Storage

The DASY software stores the assessed data from the data acquisition electronics as raw data (in microvolt readings from the probe sensors), together with all the necessary software parameters for the data evaluation (probe calibration data, liquid parameters and device frequency and modulation data) in measurement files. The post-processing software evaluates the desired unit and format for output each time the data is visualized or exported. This allows verification of the complete software setup even after the measurement and allows correction of erroneous parameter settings. For example, if a measurement has been performed with an incorrect crest factor parameter in the device setup, the parameter can be corrected afterwards and the data can be reevaluated.

The measured data can be visualized or exported in different units or formats, depending on the selected probe type (e.g., [V/m], [A/m], [W/kg]). Some of these units are not available in certain situations or give meaningless results, e.g., a SAR-output in a non-lose media, will always be zero. Raw data can also be exported to perform the evaluation with other software packages.

- Data Evaluation

The DASY post-processing software (SEMCAD) automatically executes the following procedures to calculate the field units from the microvolt readings at the probe connector. The parameters used in the evaluation are stored in the configuration modules of the software：

Probe parameters： - Sensitivity $Norm_i$, a_{i0}, a_{i1}, a_{i2}

- Conversion factor $ConvF_i$

- Diode compression point dcp_i

Device parameters: - Frequency f

- Crest factor cf

Media parameters: - Conductivity σ

- Density ρ

These parameters must be set correctly in the software. They can be found in the component documents or they can be imported into the software from the configuration files issued for the DASY components. In the direct measuring mode of the multi-meter option, the parameters of the actual system setup are used. In the scan visualization and export modes, the parameters stored in the corresponding document files are used.

The first step of the evaluation is a linearization of the filtered input signal to account for the compression characteristics of the detector diode. The compensation depends on the input signal, the diode type and the DC-transmission factor from the diode to the evaluation electronics. If the exciting field is pulsed, the crest factor of the signal must be known to correctly compensate for peak power.

The formula for each channel can be given as:

$$\mathbf{V_i = U_i + U_i^2 \cdot \frac{cf}{dcp_i}}$$

with V_i= compensated signal of channel i, (i = x, y, z)

U_i = input signal of channel i, (i = x, y, z)

cf = crest factor of exciting field (DASY parameter)

dcp_i = diode compression point (DASY parameter)

From the compensated input signals, the primary field data for each channel can be evaluated:

E-field Probes: $\mathbf{E_i = \sqrt{\frac{V_i}{Norm_i \cdot ConvF}}}$

H-field Probes: $\mathbf{H_i = \sqrt{V_i} \cdot \frac{a_{i0}+a_{i1}f+a_{i2}f^2}{f}}$

with V_i = compensated signal of channel i,(i= x, y, z)

$Norm_i$= sensor sensitivity of channel i, (i= x, y, z), μV/(V/m)^2 for E-field Probes

ConvF= sensitivity enhancement in solution

a_{ij}= sensor sensitivity factors for H-field probes

f = carrier frequency [GHz]

E_i= electric field strength of channel iin V/m

H_i= magnetic field strength of channel iin A/m

The RSS value of the field components gives the total field strength (Hermitian magnitude):

$$E_{tot} = \sqrt{E_x^2 + E_y^2 + E_z^2}$$

The primary field data are used to calculate the derived field units.

$$SAR = E_{tot}^2 \cdot \frac{\sigma}{\rho \cdot 1000}$$

with SAR = local specific absorption rate in W/kg

E_{tot}= total field strength in V/m

σ = conductivity in [mho/m] or [Siemens/m]

ρ = equivalent tissue density in g/cm^3

Note that the density is set to 1, to account for actual head tissue density rather than the density of the tissue simulating liquid.

4.6. Phantom

<SAM Twin Phantom>

Shell Thickness	2 ± 0.2 mm; Center ear point: 6 ± 0.2 mm	 **Photo of SAM Phantom**
Filling Volume	Approx. 25 liters	
Dimensions	Length: 1000 mm; Width: 500 mm; Height: adjustable feet	
Measurement Areas	Left Hand, Right Hand, Flat Phantom	

The bottom plate contains three pair of bolts for locking the device holder. The device holder positions are adjusted to the standard measurement positions in the three sections. A white cover is provided to tap the phantom during off-periods to prevent water evaporation and changes in the liquid parameters. On the phantom top, three reference markers are provided to identify the phantom position with respect to the robot.

<ELI4 Phantom>

Shell Thickness	2 ± 0.2 mm (sagging: <1%)	 **Photo of ELI4 Phantom**
Filling Volume	Approx. 30 liters	
Dimensions	Major ellipse axis: 600 mm Minor axis:400 mm	

The ELI4 phantom is intended for compliance testing of handheld and body-mounted wireless devices in the frequency range of 30 MHz to 6 GHz. ELI4 is fully compatible with standard and all known tissue simulating liquids.

4.7. Device Holder

The SAR in the phantom is approximately inversely proportional to the square of the distance between the source and the liquid surface. For a source at 5 mm distance, a positioning uncertainty of ±0.5mm would produce a SAR uncertainty of ± 20%. Accurate device positioning is therefore crucial for accurate and repeatable measurements. The positions in which the devices must be measured are defined by the standards.

The DASY device holder is designed to cope with different positions given in the standard. It has two scales for the device rotation (with respect to the body axis) and the device inclination (with respect to the line between the ear reference points). The rotation center for both scales is the ear reference point (ERP).Thus the device needs no repositioning when changing the angles.

The DASY device holder is constructed of low-loss POM material having the following dielectric parameters: relative permittivity ε = 3 and loss tangent δ = 0.02. The amount of dielectric material has been reduced in the closest vicinity of the device, since measurements have suggested that the influence of the clamp on the test results could thus be lowered.

Device Holder

5. Test Equipment List

Manufacturer	Name of Equipment	Type/Model	Serial Number	Calibration	
				Last Cal.	Due Date
SPEAG	835MHz System Validation Kit	D835V2	4d154	Jun. 16,2021	Jun. 15,2024
SPEAG	1750MHz System Validation Kit	D1750V2	1021	Jul. 01,2021	Jun. 30,2024
SPEAG	1900MHz System Validation Kit	D1900V2	5d175	Jun. 15,2022	Jun. 14,2025
SPEAG	2600MHz System Validation Kit	D2600V2	910	Jun. 15,2021	Jun. 14,2024
Rohde & Schwarz	UNIVERSAL RADIO COMMUNICATION TESTER	CMW500	1201.0002K50-104209-JC	Oct.13, 2022	Oct.12, 2023
SPEAG	Data Acquisition Electronics	DAE4	387	Sept.06,2022	Sept.05,2023
SPEAG	Dosimetric E-Field Probe	EX3DV4	7396	May 06,2023	May 05,2024
Agilent	ENA Series Network Analyzer	E5071C	MY46317418	Oct.26, 2022	Oct.25, 2023
SPEAG	DAK	DAK-3.5	1226	NCR	NCR
SPEAG	SAM Twin Phantom	QD000P40CD	1802	NCR	NCR
SPEAG	ELI Phantom	QDOVA004AA	2058	NCR	NCR
AR	Amplifier	ZHL-42W	QA1118004	NCR	NCR
Agilent	Power Meter	N1914A	MY50001102	Oct.26, 2022	Oct.25, 2023
Agilent	Power Sensor	N8481H	MY51240001	Oct.26, 2022	Oct.25, 2023
R&S	Spectrum Analyzer	N9020A	MY51170037	Oct.26, 2022	Oct.25, 2023
Agilent	Signal Generation	N5182A	MY48180656	Oct.26, 2022	Oct.25, 2023
Worken	Directional Coupler	0110A05601O-10	COM5BNW1A2	Oct.26, 2022	Oct.25, 2023

Note:

1. The calibration certificate of DASY can be referred to appendix C of this report.
2. The dipole calibration interval can be extended to 3 years with justification. The dipoles are also not physically damaged, or repaired during the interval.
3. The Insertion Loss calibration of Dual Directional Coupler and Attenuator were characterized via the network analyzer and compensated during system check.
4. The dielectric probe kit was calibrated via the network analyzer, with the specified procedure (calibrated in pure water) and calibration kit (standard) short circuit, before the dielectric measurement. The specific procedure and calibration kit are provided by Agilent.
5. In system check we need to monitor the level on the power meter, and adjust the power amplifier level to have precise power level to the dipole; the measured SAR will be normalized to 1W input power according to the ratio of 1W to the input power to the dipole. For system check, the calibration of the power amplifier is deemed not critically

required for correct measurement; the power meter is critical and we do have calibration for it

6. Tissue Simulating Liquids

For the measurement of the field distribution inside the SAM phantom with DASY, the phantom must be filled with around 25 liters of homogeneous body tissue simulating liquid. For head SAR testing, the liquid height from the ear reference point (ERP) of the phantom to the liquid top surface is larger than 15 cm, which is shown in Fig. 6.1. For body SAR testing, the liquid height from the center of the flat phantom to the liquid top surface is larger than 15 cm, which is shown as followed:



Photo of Liquid Height for Head SAR



Photo of Liquid Height for Body SAR

The following table gives the recipes for tissue simulating liquid.

Frequency (MHz)	Water (%)	Sugar (%)	Cellulose (%)	Salt (%)	Preventol (%)	DGBE (%)	Conductivity (σ)	Permittivity (εr)
For Body								
835	50.8	48.2	0	0.9	0.1	0	0.97	55.2
1750	70.2	0	0	0.4	0	29.4	1.49	53.4
1800,1900,2000	70.2	0	0	0.4	0	29.4	1.52	53.3
2600	54.8	0	0	0.1	0	45.1	2.16	52.5

The following table shows the measuring results for simulating liquid.

Measured Frequency (MHz)	Target Tissue		Measured Tissue				Liquid Temp.	Test Data
	ε_r	σ	ε_r	Dev. (%)	σ	Dev. (%)		
835	55.2	0.97	54.87	-0.60	0.93	-4.12	22.3	06/26/2023
1750	53.4	1.49	53.16	-0.45	1.43	-4.03	22.5	06/27/2023
1900	53.3	1.52	52.92	-0.71	1.49	-1.97	22.2	06/28/2023
2600	52.5	2.16	52.21	-0.55	2.17	0.46	22.6	06/30/2023

7. System Verification Procedures

Each DASY system is equipped with one or more system validation kits. These units, together with the predefined measurement procedures within the DASY software, enable the user to conduct the system performance check and system validation. System validation kit includes a dipole, tripod holder to fix it underneath the flat phantom and a corresponding distance holder.

➢ Purpose of System Performance check

The system performance check verifies that the system operates within its specifications. System and operator errors can be detected and corrected. It is recommended that the system performance check be performed prior to any usage of the system in order to guarantee reproducible results. The system performance check uses normal SAR measurements in a simplified setup with a well characterized source. This setup was selected to give a high sensitivity to all parameters that might fail or vary over time. The system check does not intend to replace the calibration of the components, but indicates situations where the system uncertainty is exceeded due to drift or failure.

➢ System Setup

In the simplified setup for system evaluation, the EUT is replaced by a calibrated dipole and the power source is replaced by a continuous wave that comes from a signal generator. The calibrated dipole must be placed beneath the flat phantom section of the SAM twin phantom with the correct distance holder. The distance holder should touch the phantom surface with a light pressure at the reference marking and be oriented parallel to the long side of the phantom. The equipment setup is shown below:



System Setup for System Evaluation



Photo of Dipole Setup

➢ Validation Results

Comparing to the original SAR value provided by SPEAG, the verification data should be within its specification of 10%. The table below shows the target SAR and measured SAR after normalized to 1W input power. It indicates that the system performance check can meet the variation criterion and the plots can be referred to Appendix A of this report.

Date	Frequency (MHz)	Power fed onto reference dipole (mW)	Targeted SAR (W/kg)	Measured SAR (W/kg)	Normalized SAR (W/kg)	Deviation (%)
06/26/2023	835	250	9.57	2.33	9.44	-2.61
06/27/2023	1750	250	36.7	9.69	38.68	5.61
06/28/2023	1900	250	40.1	10.18	40.64	1.55
06/30/2023	2600	250	51.8	13.91	51.64	-0.31

Target and Measurement SAR after Normalized

8. EUT Testing Position

8.1. Body Worn Position

(a) To position the device parallel to the phantom surface with either keypad up or down.
(b) To adjust the device parallel to the flat phantom.
(c) To adjust the distance between the device surface and the flat phantom to 0.5 cm.



Body Worn Position

9. Measurement Procedures

The measurement procedures are as follows:

(a) Use base station simulator (if applicable) or engineering software to transmit RF power continuously (continuous Tx) in the middle channel.
(b) Keep EUT to radiate maximum output power or 100% duty factor (if applicable)
(c) Measure output power through RF cable and power meter.
(d) Place the EUT in the positions as setup photos demonstrates.
(e) Set scan area, grid size and other setting on the DASY software.
(f) Measure SAR transmitting at the middle channel for all applicable exposure positions.
(g) Identify the exposure position and device configuration resulting the highest SAR
(h) Measure SAR at the lowest and highest channels attheworst exposure position and device configuration if applicable.

According to the test standard, the recommended procedure for assessing the peak spatial-average SAR value consists of the following steps:

(a) Power reference measurement
(b) Area scan
(c) Zoom scan
(d) Power drift measurement

9.1. Spatial Peak SAR Evaluation

The procedure for spatial peak SAR evaluation has been implemented according to the test standard. It can be conducted for 1g and 10g, as well as for user-specific masses. The DASY software includes all numerical procedures necessary to evaluate the spatial peak SAR value.

The base for the evaluation is a "cube" measurement. The measured volume must include the 1g and 10g cubes with the highest averaged SAR values. For that purpose, the center of the measured volume is aligned to the interpolated peak SAR value of a previously performed area scan.

The entire evaluation of the spatial peak values is performed within the post-processing engine (SEMCAD). The system always gives the maximum values for the 1g and 10g cubes. The algorithm to find the cube with highest averaged SAR is divided into the following stages:

(a) Extraction of the measured data (grid and values) from the Zoom Scan
(b) Calculation of the SAR value at every measurement point based on all stored data (A/D values and measurement parameters)
(c) Generation of a high-resolution mesh within the measured volume
(d) Interpolation of all measured values form the measurement grid to the high-resolution grid
(e) Extrapolation of the entire 3-D field distribution to the phantom surface over the distance from sensor to surface
(f) Calculation of the averaged SAR within masses of 1g and 10g

9.2. Power Reference Measurement

The Power Reference Measurement and Power Drift Measurements are for monitoring the power drift of the device under test in the batch process. The minimum distance of probe sensors to surface determines the closest measurement point to phantom surface. This distance cannot be smaller than the distance of sensor calibration points to probe tip as defined in the probe properties.

9.3. Area Scan Procedures

The area scan is used as a fast scan in two dimensions to find the area of high field values, before doing a fine measurement around the hot spot. The sophisticated interpolation routines implemented in DASY software can find the maximum found in the scanned area, within a range of the global maximum. The range (in dB0 is specified in the standards for compliance testing. For example, a 2 dB range is required in IEEE standard 1528 and IEC 62209 standards, whereby 3 dB is a requirement when compliance is assessed in accordance with the ARIB standard (Japan), if only one zoom scan follows the area scan, then only the absolute maximum will be taken as reference. For cases where multiple maximums are detected, the number of zoom scans has to be increased accordingly.

Area scan parameters extracted from FCC KDB 865664 D01 SAR measurement 100 MHz to 6 GHz.

	≤ 3 GHz	> 3 GHz
Maximum distance from closest measurement point (geometric center of probe sensors) to phantom surface	5 ± 1 mm	½·δ·ln(2) ± 0.5 mm
Maximum probe angle from probe axis to phantom surface normal at the measurement location	30° ± 1°	20° ± 1°
Maximum area scan spatial resolution: Δx_{Area}, Δy_{Area}	≤ 2 GHz: ≤ 15 mm 2 – 3 GHz: ≤ 12 mm	3 – 4 GHz: ≤ 12 mm 4 – 6 GHz: ≤ 10 mm
	When the x or y dimension of the test device, in the measurement plane orientation, is smaller than the above, the measurement resolution must be ≤ the corresponding x or y dimension of the test device with at least one measurement point on the test device.	

9.4.Zoom Scan Procedures

Zoom scans are used assess the peak spatial SAR values within a cubic averaging volume containing 1 gram and 10gram of simulated tissue. The zoom scan measures points (refer to table below) within a cube shoes base faces are centered on the maxima found in a preceding area scan job within the same procedure. When the measurement is done, the zoom scan evaluates the averaged SAR for 1 gram and 10 gram and displays these values next to the job's label.

Zoom scan parameters extracted from FCC KDB 865664 D01 SAR measurement 100 MHz to 6 GHz.

			≤ 3 GHz	> 3 GHz
Maximum zoom scan spatial resolution: Δx_{Zoom}, Δy_{Zoom}			≤ 2 GHz: ≤ 8 mm 2 – 3 GHz: ≤ 5 mm*	3 – 4 GHz: ≤ 5 mm* 4 – 6 GHz: ≤ 4 mm*
Maximum zoom scan spatial resolution, normal to phantom surface	uniform grid: $\Delta z_{Zoom}(n)$		≤ 5 mm	3 – 4 GHz: ≤ 4 mm 4 – 5 GHz: ≤ 3 mm 5 – 6 GHz: ≤ 2 mm
	graded grid	$\Delta z_{Zoom}(1)$: between 1st two points closest to phantom surface	≤ 4 mm	3 – 4 GHz: ≤ 3 mm 4 – 5 GHz: ≤ 2.5 mm 5 – 6 GHz: ≤ 2 mm
		$\Delta z_{Zoom}(n>1)$: between subsequent points	$\leq 1.5 \cdot \Delta z_{Zoom}(n-1)$	
Minimum zoom scan volume	x, y, z		≥ 30 mm	3 – 4 GHz: ≥ 28 mm 4 – 5 GHz: ≥ 25 mm 5 – 6 GHz: ≥ 22 mm

Note: δ is the penetration depth of a plane-wave at normal incidence to the tissue medium; see draft standard IEEE P1528-2011 for details.

* When zoom scan is required and the *reported* SAR from the *area scan based 1-g SAR estimation* procedures of KDB 447498 is ≤ 1.4 W/kg, ≤ 8 mm, ≤ 7 mm and ≤ 5 mm zoom scan resolution may be applied, respectively, for 2 GHz to 3 GHz, 3 GHz to 4 GHz and 4 GHz to 6 GHz.

9.5. Volume Scan Procedures

The volume scan is used for assess overlapping SAR distributions for antennas transmitting in different frequency bands. It is equivalent to an oversized zoom scan used in standalone measurements. The measurement volume will be used to enclose all the simultaneous transmitting antennas. For antennas transmitting simultaneously in different frequency bands, the volume scan is measured separately in each frequency band. In order to sum correctly to compute the 1g aggregateSAR, the EUT remain in the same test position for all measurements and all volume scan use the same spatial resolution and grid spacing. When all volume scan were completed, the software, SEMCAD postprocessor can combine and subsequently superpose these measurement data to calculating the multiband SAR.

9.6. Power Drift Monitoring

All SAR testing is under the EUT install full charged battery and transmit maximum output power. In DASY measurement software, the power reference measurement and power drift measurement procedures are used for monitoring the power drift of EUT during SAR test. Both these procedures measure the field at a specified reference position before and after the SAR testing. The software will calculate the field difference in dB. If the power drift more than 5%, the SAR will be retested.

10. Conducted Power

<LTE Conducted Power>

Condition	Band	Channel Bandwidth	Channel	RB Configure	Result (dBm)		Tune-Up	
					QPSK	16QAM	QPSK	16QAM
NTNV	Band2	1.4MHz	18607	1RB#0	23.13	22.13	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	1RB#2	22.97	22.02	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	1RB#5	22.90	22.06	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	3RB#0	22.90	21.68	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	3RB#1	22.89	21.80	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	3RB#3	22.80	21.81	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18607	6RB#0	21.92	21.04	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	1RB#0	22.81	21.89	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	1RB#2	22.90	22.09	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	1RB#5	22.79	21.85	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	3RB#0	22.71	21.52	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	3RB#1	22.62	21.51	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	3RB#3	22.72	21.64	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	18900	6RB#0	21.66	20.80	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	1RB#0	22.97	22.18	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	1RB#2	23.10	22.36	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	1RB#5	22.93	22.23	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	3RB#0	23.02	22.04	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	3RB#1	23.09	22.12	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	3RB#3	23.06	22.16	22.5±1.0	22.0±1.0
NTNV	Band2	1.4MHz	19193	6RB#0	22.19	21.09	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	1RB#0	22.81	21.77	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	1RB#8	22.79	21.75	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	1RB#14	22.89	21.77	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	8RB#0	22.02	21.02	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	8RB#4	21.83	21.02	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	8RB#7	21.83	21.12	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18615	15RB#0	21.93	20.88	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	1RB#0	22.65	21.68	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	1RB#8	22.72	21.96	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	1RB#14	22.66	21.60	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	8RB#0	21.86	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	8RB#4	21.68	20.79	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	18900	8RB#7	21.73	20.85	22.5±1.0	22.0±1.0

NTNV	Band2	3MHz	18900	15RB#0	21.67	20.77	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	1RB#0	23.06	22.29	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	1RB#8	23.23	22.18	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	1RB#14	23.09	22.14	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	8RB#0	22.04	21.24	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	8RB#4	22.04	21.06	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	8RB#7	22.18	21.19	22.5±1.0	22.0±1.0
NTNV	Band2	3MHz	19185	15RB#0	22.05	21.07	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	1RB#0	23.04	21.58	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	1RB#12	22.88	21.60	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	1RB#24	22.76	21.93	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	12RB#0	21.96	20.95	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	12RB#6	21.97	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	12RB#13	21.85	20.93	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18625	25RB#0	21.91	21.00	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	1RB#0	22.78	21.77	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	1RB#12	22.87	22.21	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	1RB#24	22.81	21.75	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	12RB#0	21.73	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	12RB#6	21.73	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	12RB#13	21.72	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	18900	25RB#0	21.70	20.87	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	1RB#0	23.06	22.20	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	1RB#12	23.18	22.46	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	1RB#24	23.11	22.23	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	12RB#0	22.02	21.28	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	12RB#6	22.07	21.03	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	12RB#13	22.13	20.84	22.5±1.0	22.0±1.0
NTNV	Band2	5MHz	19175	25RB#0	21.89	21.06	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	1RB#0	22.94	21.92	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	1RB#24	23.03	22.30	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	1RB#49	22.85	21.97	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	25RB#0	22.05	21.03	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	25RB#12	21.93	20.87	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	25RB#25	21.86	20.97	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18650	50RB#0	21.88	21.06	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	1RB#0	22.75	22.07	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	1RB#24	23.07	22.36	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	1RB#49	22.79	22.05	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	25RB#0	21.85	20.96	22.5±1.0	22.0±1.0

NTNV	Band2	10MHz	18900	25RB#12	21.86	20.89	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	25RB#25	21.98	20.90	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	18900	50RB#0	21.73	20.83	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	1RB#0	23.00	22.35	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	1RB#24	23.46	22.30	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	1RB#49	23.45	22.52	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	25RB#0	21.95	21.09	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	25RB#12	21.93	21.20	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	25RB#25	22.19	21.14	22.5±1.0	22.0±1.0
NTNV	Band2	10MHz	19150	50RB#0	22.10	21.10	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	1RB#0	22.97	22.16	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	1RB#38	23.02	22.09	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	1RB#74	23.04	21.87	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	38RB#0	22.05	22.05	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	38RB#18	22.05	22.06	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	38RB#37	22.06	22.06	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18675	75RB#0	22.06	21.01	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	1RB#0	22.67	21.75	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	1RB#38	22.80	21.81	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	1RB#74	22.70	21.78	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	38RB#0	21.92	21.90	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	38RB#18	21.90	21.90	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	38RB#37	21.90	21.90	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	18900	75RB#0	21.90	21.01	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	1RB#0	22.92	22.36	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	1RB#38	23.20	22.32	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	1RB#74	23.36	22.48	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	38RB#0	21.96	21.96	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	38RB#18	21.96	21.96	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	38RB#37	21.97	21.97	22.5±1.0	22.0±1.0
NTNV	Band2	15MHz	19125	75RB#0	21.97	21.08	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	1RB#0	22.94	22.09	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	1RB#49	**23.34**	22.49	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	1RB#99	23.01	22.15	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	50RB#0	22.02	21.11	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	50RB#25	22.06	21.17	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	50RB#50	21.91	20.97	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18700	100RB#0	21.92	20.99	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	1RB#0	22.77	22.27	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	1RB#49	23.06	22.69	22.5±1.0	22.0±1.0

NTNV	Band2	20MHz	18900	1RB#99	22.92	22.12	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	50RB#0	21.82	20.92	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	50RB#25	21.84	20.92	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	50RB#50	21.89	21.00	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	18900	100RB#0	21.92	20.99	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	1RB#0	22.73	21.78	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	1RB#49	23.04	21.82	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	1RB#99	23.26	22.20	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	50RB#0	22.12	21.09	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	50RB#25	21.97	21.11	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	50RB#50	22.16	21.27	22.5±1.0	22.0±1.0
NTNV	Band2	20MHz	19100	100RB#0	22.05	21.06	22.5±1.0	22.0±1.0

Condition	Band	Channel Bandwidth	Channel	RB Configure	Result (dBm)		Tune-Up	
					QPSK	16QAM	QPSK	16QAM
NTNV	Band4	1.4MHz	19957	1RB#0	23.10	21.96	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	1RB#2	23.00	22.34	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	1RB#5	23.01	22.18	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	3RB#0	23.07	22.08	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	3RB#1	23.07	22.07	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	3RB#3	23.04	22.22	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	19957	6RB#0	22.20	21.08	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	1RB#0	23.06	22.36	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	1RB#2	23.26	22.30	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	1RB#5	23.24	22.39	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	3RB#0	23.18	22.22	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	3RB#1	23.18	22.03	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	3RB#3	23.13	22.17	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20175	6RB#0	22.19	21.31	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	1RB#0	23.03	22.27	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	1RB#2	23.02	22.44	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	1RB#5	22.96	22.20	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	3RB#0	22.93	21.74	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	3RB#1	22.84	21.74	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	3RB#3	22.89	21.79	23.0±1.0	22.5±1.0
NTNV	Band4	1.4MHz	20393	6RB#0	21.95	21.00	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	1RB#0	23.02	22.14	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	1RB#8	23.27	22.00	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	1RB#14	23.13	22.04	23.0±1.0	22.5±1.0

NTNV	Band4	3MHz	19965	8RB#0	22.29	21.21	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	8RB#4	22.10	21.21	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	8RB#7	22.12	21.34	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	19965	15RB#0	22.21	21.29	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	1RB#0	23.06	22.05	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	1RB#8	23.17	22.41	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	1RB#14	23.13	22.40	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	8RB#0	22.21	21.19	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	8RB#4	22.21	21.19	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	8RB#7	22.23	21.35	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20175	15RB#0	22.22	21.34	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	1RB#0	22.95	21.78	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	1RB#8	22.95	21.89	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	1RB#14	23.01	21.95	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	8RB#0	21.94	21.01	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	8RB#4	21.86	21.15	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	8RB#7	21.91	20.95	23.0±1.0	22.5±1.0
NTNV	Band4	3MHz	20385	15RB#0	21.83	20.86	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	1RB#0	23.12	21.62	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	1RB#12	23.22	21.90	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	1RB#24	23.00	21.78	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	12RB#0	22.29	20.99	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	12RB#6	22.31	21.17	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	12RB#13	22.16	21.04	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	19975	25RB#0	22.13	21.32	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	1RB#0	23.16	22.37	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	1RB#12	23.31	22.55	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	1RB#24	23.16	22.24	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	12RB#0	22.20	21.35	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	12RB#6	22.20	21.23	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	12RB#13	22.30	21.36	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20175	25RB#0	22.20	21.19	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	1RB#0	22.90	22.03	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	1RB#12	23.09	22.15	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	1RB#24	22.95	22.23	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	12RB#0	22.08	20.94	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	12RB#6	21.91	20.85	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	12RB#13	22.00	21.13	23.0±1.0	22.5±1.0
NTNV	Band4	5MHz	20375	25RB#0	21.96	21.09	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	1RB#0	22.99	22.21	23.0±1.0	22.5±1.0

NTNV	Band4	10MHz	20000	1RB#24	23.20	22.63	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	1RB#49	22.99	22.09	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	25RB#0	22.35	21.27	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	25RB#12	22.21	21.18	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	25RB#25	22.09	21.15	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20000	50RB#0	22.11	21.18	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	1RB#0	22.97	22.07	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	1RB#24	23.53	23.09	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	1RB#49	23.10	22.36	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	25RB#0	22.31	21.22	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	25RB#12	22.21	21.21	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	25RB#25	22.25	21.29	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20175	50RB#0	22.20	21.32	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	1RB#0	23.07	22.31	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	1RB#24	23.39	22.92	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	1RB#49	23.18	22.51	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	25RB#0	21.98	21.03	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	25RB#12	21.92	21.04	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	25RB#25	22.00	20.95	23.0±1.0	22.5±1.0
NTNV	Band4	10MHz	20350	50RB#0	21.92	21.01	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	1RB#0	23.13	22.28	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	1RB#38	23.09	22.73	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	1RB#74	23.15	22.21	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	38RB#0	22.16	22.16	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	38RB#18	22.16	22.15	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	38RB#37	22.15	22.15	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20025	75RB#0	22.14	21.11	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	1RB#0	22.81	22.10	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	1RB#38	23.12	22.21	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	1RB#74	23.05	22.25	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	38RB#0	22.22	22.21	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	38RB#18	22.20	22.20	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	38RB#37	22.20	22.29	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20175	75RB#0	22.29	21.22	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	1RB#0	23.20	22.53	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	1RB#38	23.17	22.33	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	1RB#74	23.22	22.43	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	38RB#0	22.06	22.08	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	38RB#18	22.09	22.09	23.0±1.0	22.5±1.0
NTNV	Band4	15MHz	20325	38RB#37	22.09	22.09	23.0±1.0	22.5±1.0

NTNV	Band4	15MHz	20325	75RB#0	22.09	21.10	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	1RB#0	22.97	22.28	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	1RB#49	23.35	22.61	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	1RB#99	23.10	22.53	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	50RB#0	22.17	21.16	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	50RB#25	22.09	21.16	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	50RB#50	22.27	21.25	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20050	100RB#0	22.17	21.06	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	1RB#0	23.03	22.60	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	1RB#49	**23.58**	23.22	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	1RB#99	23.30	22.55	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	50RB#0	22.19	21.29	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	50RB#25	22.17	21.29	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	50RB#50	22.37	21.38	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20175	100RB#0	22.29	21.27	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	1RB#0	23.27	22.29	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	1RB#49	23.21	22.03	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	1RB#99	23.09	21.99	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	50RB#0	22.18	21.33	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	50RB#25	22.20	21.34	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	50RB#50	22.16	21.17	23.0±1.0	22.5±1.0
NTNV	Band4	20MHz	20300	100RB#0	22.14	21.24	23.0±1.0	22.5±1.0

Condition	Band	Channel Bandwidth	Channel	RB Configure	Result (dBm)		Tune-Up	
					QPSK	16QAM	QPSK	16QAM
NTNV	Band5	1.4MHz	20407	1RB#0	23.17	22.35	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	1RB#2	23.10	22.39	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	1RB#5	23.20	22.20	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	3RB#0	23.17	22.32	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	3RB#1	23.28	22.31	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	3RB#3	23.08	22.31	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20407	6RB#0	22.31	21.23	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	1RB#0	23.43	22.74	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	1RB#2	23.63	22.85	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	1RB#5	23.37	22.63	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	3RB#0	23.46	22.27	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	3RB#1	23.36	22.37	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	3RB#3	23.36	22.27	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20525	6RB#0	22.45	21.51	23.0±1.0	22.5±1.0

NTNV	Band5	1.4MHz	20643	1RB#0	22.87	22.12	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	1RB#2	22.95	22.11	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	1RB#5	22.89	22.12	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	3RB#0	22.93	21.97	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	3RB#1	22.92	22.06	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	3RB#3	22.94	22.09	23.0±1.0	22.5±1.0
NTNV	Band5	1.4MHz	20643	6RB#0	22.18	21.11	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	1RB#0	23.05	22.07	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	1RB#8	23.16	21.72	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	1RB#14	23.28	22.44	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	8RB#0	22.37	21.26	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	8RB#4	22.31	21.26	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	8RB#7	22.24	21.32	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20415	15RB#0	22.28	21.29	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	1RB#0	23.43	22.56	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	1RB#8	23.48	22.64	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	1RB#14	23.48	22.58	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	8RB#0	22.69	21.61	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	8RB#4	22.62	21.64	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	8RB#7	22.51	21.54	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20525	15RB#0	22.49	21.39	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	1RB#0	23.18	22.23	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	1RB#8	23.10	21.98	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	1RB#14	22.98	21.96	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	8RB#0	22.06	21.00	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	8RB#4	22.00	21.01	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	8RB#7	21.92	20.94	23.0±1.0	22.5±1.0
NTNV	Band5	3MHz	20635	15RB#0	21.98	20.92	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	1RB#0	23.06	21.85	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	1RB#12	23.33	21.76	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	1RB#24	23.47	22.26	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	12RB#0	22.17	21.38	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	12RB#6	22.28	21.27	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	12RB#13	22.36	21.50	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20425	25RB#0	22.22	21.39	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	1RB#0	23.47	22.85	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	1RB#12	23.59	22.44	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	1RB#24	23.06	22.14	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	12RB#0	22.50	21.68	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	12RB#6	22.50	21.68	23.0±1.0	22.5±1.0

NTNV	Band5	5MHz	20525	12RB#13	22.23	21.41	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20525	25RB#0	22.40	21.38	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	1RB#0	22.71	21.93	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	1RB#12	23.17	22.12	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	1RB#24	22.90	22.02	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	12RB#0	21.99	20.87	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	12RB#6	21.92	20.98	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	12RB#13	21.93	21.09	23.0±1.0	22.5±1.0
NTNV	Band5	5MHz	20625	25RB#0	21.93	20.99	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	1RB#0	23.03	22.19	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	1RB#24	23.64	22.71	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	1RB#49	23.41	22.67	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	25RB#0	22.40	21.27	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	25RB#12	22.39	21.27	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	25RB#25	22.73	21.61	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20450	50RB#0	22.45	21.44	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	1RB#0	23.44	22.54	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	1RB#24	**23.67**	23.25	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	1RB#49	22.95	21.95	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	25RB#0	22.63	21.65	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	25RB#12	22.62	21.64	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	25RB#25	22.23	21.38	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20525	50RB#0	22.41	21.44	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	1RB#0	23.11	22.58	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	1RB#24	23.09	22.69	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	1RB#49	22.93	22.36	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	25RB#0	22.04	21.11	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	25RB#12	22.08	21.13	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	25RB#25	22.09	21.04	23.0±1.0	22.5±1.0
NTNV	Band5	10MHz	20600	50RB#0	22.05	21.09	23.0±1.0	22.5±1.0

Condition	Band	Channel Bandwidth	Channel	RB Configure	Result (dBm)		Tune-Up	
					QPSK	16QAM	QPSK	16QAM
NTNV	Band41	5MHz	40265	1RB#0	22.43	21.63	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	1RB#12	22.58	21.68	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	1RB#24	22.41	21.60	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	12RB#0	21.58	20.53	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	12RB#6	21.61	20.53	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	12RB#13	21.55	20.47	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40265	25RB#0	21.53	20.59	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	1RB#0	21.75	20.91	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	1RB#12	21.97	21.07	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	1RB#24	21.82	20.82	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	12RB#0	21.00	19.93	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	12RB#6	20.91	19.94	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	12RB#13	20.97	19.89	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	40690	25RB#0	20.95	20.00	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	1RB#0	22.47	21.69	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	1RB#12	22.68	21.74	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	1RB#24	22.48	21.95	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	12RB#0	21.66	20.65	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	12RB#6	21.67	20.55	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	12RB#13	21.66	20.54	22.0±1.0	21.5±1.0
NTNV	Band41	5MHz	41215	25RB#0	21.68	20.63	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	1RB#0	22.37	21.75	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	1RB#24	22.52	21.62	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	1RB#49	22.28	21.59	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	25RB#0	21.65	20.56	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	25RB#12	21.66	20.67	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	25RB#25	21.64	20.64	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40290	50RB#0	21.60	20.53	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	1RB#0	21.69	21.11	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	1RB#24	21.94	21.37	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	1RB#49	21.77	21.04	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	25RB#0	21.00	20.13	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	25RB#12	21.01	20.13	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	25RB#25	21.00	20.16	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	40690	50RB#0	20.96	19.99	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	1RB#0	22.51	22.11	22.0±1.0	21.5±1.0

NTNV	Band41	10MHz	41190	1RB#24	22.83	22.42	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	1RB#49	22.76	22.26	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	25RB#0	21.64	20.81	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	25RB#12	21.65	20.71	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	25RB#25	21.66	20.72	22.0±1.0	21.5±1.0
NTNV	Band41	10MHz	41190	50RB#0	21.71	20.73	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	1RB#0	22.33	21.72	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	1RB#38	22.29	21.59	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	1RB#74	22.11	21.31	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	38RB#0	21.51	21.50	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	38RB#18	21.49	21.49	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	38RB#37	21.49	21.48	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40315	75RB#0	21.48	20.64	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	1RB#0	21.89	20.93	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	1RB#38	21.90	20.96	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	1RB#74	21.85	20.82	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	38RB#0	21.01	21.01	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	38RB#18	21.01	21.01	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	38RB#37	21.01	21.01	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	40690	75RB#0	21.00	20.07	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	1RB#0	22.58	22.16	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	1RB#38	22.78	22.17	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	1RB#74	22.85	22.40	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	38RB#0	21.77	21.77	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	38RB#18	21.77	21.76	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	38RB#37	21.76	21.76	22.0±1.0	21.5±1.0
NTNV	Band41	15MHz	41165	75RB#0	21.76	20.81	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	1RB#0	22.25	22.06	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	1RB#49	22.49	22.15	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	1RB#99	22.15	21.98	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	50RB#0	21.62	20.71	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	50RB#25	21.63	20.69	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	50RB#50	21.56	20.52	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40340	100RB#0	21.49	20.52	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	1RB#0	22.20	21.19	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	1RB#49	22.32	21.25	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	1RB#99	22.02	21.00	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	50RB#0	21.06	19.94	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	50RB#25	21.07	19.95	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	40690	50RB#50	21.00	20.08	22.0±1.0	21.5±1.0

NTNV	Band41	20MHz	40690	100RB#0	20.99	20.13	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	1RB#0	22.30	21.26	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	1RB#49	**22.96**	21.72	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	1RB#99	22.77	21.54	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	50RB#0	21.65	20.67	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	50RB#25	21.66	20.67	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	50RB#50	21.75	20.76	22.0±1.0	21.5±1.0
NTNV	Band41	20MHz	41140	100RB#0	21.72	20.77	22.0±1.0	21.5±1.0

<Bluetooth Conducted Power>

Mode	Channel	Frequency (MHz)	Conducted Average Power (dBm)	Tune-up power(dBm)
BT BLE_1M (GFSK)	00	2402	4.93	5.00
	19	2440	4.77	5.00
	39	2480	4.93	5.00
BT BLE_2M (GFSK)	00	2402	4.84	5.50
	19	2440	5.00	5.50
	39	2480	4.93	5.50

Note:

Per KDB 447498 D01v05r02, the 1-g and 10-g SAR test exclusion thresholds for 100 MHz to 6 GHz at test separation distances ≤ 50 mm are determined by:

[(max. power of channel, including tune-up tolerance, mW)/(min. test separation distance, mm)] ·[√f(GHz)] ≤ 3.0 for 1-g SAR and ≤ 7.5 for 10-g extremity SAR

f(GHz) is the RF channel transmit frequency in GHz

Power and distance are rounded to the nearest mW and mm before calculation

The result is rounded to one decimal place for comparison

Bluetooth Max Power (dBm)	Separation Distance (mm)	Frequency (GHz)	exclusion thresholds
5.50	5	2.48	1.118

Per KDB 447498 D01, when the minimum test separation distance is <10 mm, a distance of 10 mm is applied to determine SAR test exclusion. The test exclusion threshold is 1.118 which is<= 3, SAR testing is not required.

11. Antenna Location



Distance of The Antenna to the EUT surface and edge						
Antennas	**Front**	**Back**	**Top Side**	**Bottom Side**	**Left Side**	**Right Side**
LTE	<25mm	<25mm	<25mm	>25mm	<25mm	<25mm

General Note: According with FCC KDB 447498 D01, appendix A, <SAR test exclusion thresholds for 100MHz~6GHz and≤50mm＞table, this device SAR test configurations considerations are shown in the table above.

Per KDB 447498 D01, for larger devices, the test separation distance of adjacent edge configuration is determined by the closest separation between the antenna and the user.

12. SAR Test Results Summary

General Note:

1.Per KDB 447498 D01v05r01, the reported SAR is the measured SAR value adjusted for maximum tune-up tolerance.

Scaling Factor = tune-up limit power (mW) / EUT RF power (mW), where tune-up limit is the maximum rated power among all production units.

Reported SAR(W/kg)= Measured SAR(W/kg) Scaling Factor*

2.Per KDB 447498 D01v05r01, for each exposure position, if the highest output channel reported SAR≤0.8W/kg, other channels SAR testing are not necessary

3.Per KDB 941225 D05, start with the largest channel bandwidth and measure SAR for QPSK with 1 RB allocation, using the RB offset and required test channel combination with the highest maximum output power for RB offsets at the upper edge, middle and lower edge of each required test channel.

4.Per KDB 941225 D05, 50% RB allocation for QPSK SAR testing follows 1RB QPSK allocation procedure.

5.Per KDB 941225 D05, For QPSK with 100% RB allocation, SAR is not required when the highest maximum output power for 100 % RB allocation is less than the highest maximum output power in 50% and 1 RB allocations and the highest reported SAR for 1 RB and 50% RB allocation are ≤ 0.8 W/kg. Otherwise, SAR is measured for the highest output power channel; and if the reported SAR is > 1.45 W/kg, the remaining required test channels must also be tested.

6.Per KDB 941225 D05, 16QAM output power for each RB allocation configuration is > not ½ dB higher than the same configuration in QPSK and the reported SAR for the QPSK configuration is ≤ 1.45 W/kg; Per KDB 941225 D05, 16QAM SAR testing is not required.

7.Per KDB 941225 D05, Smaller bandwidth output power for each RB allocation configuration is > not ½ dB higher than the same configuration in the largest supported bandwidth, and the reported SAR for the largest supported bandwidth is ≤ 1.45 W/kg; Per KDB 941225 D05, smaller bandwidth SAR testing is not required.

8.Per KDB865664 D01, for each frequency band, repeated SAR measurement is required only when the measured SAR is ≥0.8W/Kg; if the deviation among the repeated measurement is ≤20%,and the measured SAR <1.45W/Kg, only one repeated measurement is required.

9.When the user enables the personal Wireless router functions for the handsets, actual operationsinclu de simultaneous transmission of both the Wi-Fi transmitting frequency and thus cannot beevaluated for SAR under actual use conditions. The “Portable Hotspot” feature on the handset was NOT activated, to ensure the SAR measurements were evaluated for a single transmissionfrequency RF signal.

11.1 Body and Limbs SAR Results

<LTE>

Plot No.	Band	Mode	Test Position	Gap (mm)	Ch.	Freq. (MHz)	Average Power (dBm)	Tune-Up Limit (dBm)	Scaling Factor	Power Drift (dB)	Measured SAR_{1g} (W/kg)	Reported SAR_{1g} (W/kg)
	LTE Band 2	20MHz/1RB	Back	10	18700	1860	23.34	23.5	1.038	0.07	0.272	0.282
	LTE Band 2	20MHz/50RB	Back	10	18700	1860	22.06	23.5	1.393	0.03	0.165	0.230
#1	LTE Band 2	20MHz/1RB	Front	10	18700	1860	23.34	23.5	1.038	0.12	0.455	**0.472**
	LTE Band 2	20MHz/50RB	Front	10	18700	1860	22.06	23.5	1.393	0.09	0.336	0.468
	LTE Band 2	20MHz/1RB	Left Side	10	18700	1860	23.34	23.5	1.038	0.01	0.321	0.333
	LTE Band 2	20MHz/50RB	Left Side	10	18700	1860	22.06	23.5	1.393	0.02	0.214	0.298
	LTE Band 2	20MHz/1RB	Right Side	10	18700	1860	23.34	23.5	1.038	0.12	0.314	0.326
	LTE Band 2	20MHz/50RB	Right Side	10	18700	1860	22.06	23.5	1.393	0.04	0.231	0.322
	LTE Band 2	20MHz/1RB	Top Side	10	18700	1860	23.34	23.5	1.038	0.04	0.301	0.312
	LTE Band 2	20MHz/50RB	Top Side	10	18700	1860	22.06	23.5	1.393	0.05	0.198	0.276
	LTE Band 2	20MHz/1RB	Bottom Side	10	18700	1860	23.34	23.5	1.038	N/A	N/A	N/A
	LTE Band 2	20MHz/50RB	Bottom Side	10	18700	1860	22.06	23.5	1.393	N/A	N/A	N/A
	LTE Band 4	20MHz/1RB	Back	10	20175	1732.5	23.58	24.0	1.102	0.16	0.239	0.263
	LTE Band 4	20MHz/50RB	Back	10	20175	1732.5	22.17	24.0	1.524	0.15	0.124	0.189
#2	LTE Band 4	20MHz/1RB	Front	10	20175	1732.5	23.58	24.0	1.102	-0.06	0.445	**0.490**
	LTE Band 4	20MHz/50RB	Front	10	20175	1732.5	22.17	24.0	1.524	0.12	0.249	0.379
	LTE Band 4	20MHz/1RB	Left Side	10	20175	1732.5	23.58	24.0	1.102	0.03	0.357	0.393
	LTE Band 4	20MHz/50RB	Left Side	10	20175	1732.5	22.17	24.0	1.524	0.04	0.231	0.352
	LTE Band 4	20MHz/1RB	Right Side	10	20175	1732.5	23.58	24.0	1.102	0.09	0.346	0.381
	LTE Band 4	20MHz/50RB	Right Side	10	20175	1732.5	22.17	24.0	1.524	0.08	0.215	0.328
	LTE Band 4	20MHz/1RB	Top Side	10	20175	1732.5	23.58	24.0	1.102	0.05	0.269	0.296
	LTE Band 4	20MHz/50RB	Top Side	10	20175	1732.5	22.17	24.0	1.524	0.04	0.189	0.288
	LTE Band 4	20MHz/1RB	Bottom Side	10	20175	1732.5	23.58	24.0	1.102	N/A	N/A	N/A
	LTE Band 4	20MHz/50RB	Bottom Side	10	20175	1732.5	22.17	24.0	1.524	N/A	N/A	N/A
	LTE Band 5	10MHz/1RB	Back	10	20525	836.5	23.67	24.0	1.079	0.12	0.276	0.298

	LTE Band 5	10MHz/50RB	Back	10	20525	836.5	22.41	24.0	1.442	0.17	0.172	0.248
#3	LTE Band 5	10MHz/1RB	Front	10	20525	836.5	23.67	24.0	1.079	0.06	0.389	**0.420**
	LTE Band 5	10MHz/50RB	Front	10	20525	836.5	22.41	24.0	1.442	0.02	0.264	0.381
	LTE Band 5	10MHz/1RB	Left Side	10	20525	836.5	23.67	24.0	1.079	0.05	0.301	0.325
	LTE Band 5	10MHz/50RB	Left Side	10	20525	836.5	22.41	24.0	1.442	0.04	0.213	0.307
	LTE Band 5	10MHz/1RB	Right Side	10	20525	836.5	23.67	24.0	1.079	0.09	0.298	0.322
	LTE Band 5	10MHz/50RB	Right Side	10	20525	836.5	22.41	24.0	1.442	0.14	0.201	0.290
	LTE Band 5	10MHz/1RB	Top Side	10	20525	836.5	23.67	24.0	1.079	0.08	0.223	0.241
	LTE Band 5	10MHz/50RB	Top Side	10	20525	836.5	22.41	24.0	1.442	0.09	0.175	0.252
	LTE Band 5	10MHz/1RB	Bottom Side	10	20525	836.5	23.67	24.0	1.079	N/A	N/A	N/A
	LTE Band 5	10MHz/50RB	Bottom Side	10	20525	836.5	22.41	24.0	1.442	N/A	N/A	N/A
	LTE Band 41	20MHz/1RB	Back	10	41140	2645	22.96	23.0	1.009	0.03	0.223	0.225
	LTE Band 41	20MHz/100RB	Back	10	41140	2645	21.72	23.0	1.343	0.14	0.213	0.286
#4	LTE Band 41	20MHz/1RB	Front	10	41140	2645	22.96	23.0	1.009	-0.12	0.421	**0.425**
	LTE Band 41	20MHz/100RB	Front	10	41140	2645	21.72	23.0	1.343	-0.08	0.297	0.399
	LTE Band 41	20MHz/1RB	Left Side	10	41140	2645	22.96	23.0	1.009	0.01	0.315	0.318
	LTE Band 41	20MHz/100RB	Left Side	10	41140	2645	21.72	23.0	1.343	0.09	0.221	0.297
	LTE Band 41	20MHz/1RB	Right Side	10	41140	2645	22.96	23.0	1.009	-0.04	0.310	0.313
	LTE Band 41	20MHz/100RB	Right Side	10	41140	2645	21.72	23.0	1.343	0.17	0.218	0.293
	LTE Band 41	20MHz/1RB	Top Side	10	41140	2645	22.96	23.0	1.009	0.05	0.297	0.300
	LTE Band 41	20MHz/100RB	Top Side	10	41140	2645	21.72	23.0	1.343	0.01	0.196	0.263
	LTE Band 41	20MHz/1RB	Bottom Side	10	41140	2645	22.96	23.0	1.009	N/A	N/A	N/A
	LTE Band 41	20MHz/100RB	Bottom Side	10	41140	2645	21.72	23.0	1.343	N/A	N/A	N/A

13. Simultaneous Transmission Analysis

Simultaneous TX SAR Considerations

No.	Applicable Simultaneous Transmission
1.	NA

14. Measurement Uncertainty

NO	Source	Uncert. ai（%）	Prob. Dist.	Div. k	ci (1g)	ci (10g)	Stand.Uncert. ui (1g)	Stand.Uncert. ui (10g)	*Veff*
1	Repeat	0. 4	N	1	1	1	0. 4	0. 4	9
Instrument									
2	Probe calibration	7	N	2	1	1	3.5	3.5	∞
3	Axial isotropy	4.7	R	$\sqrt{3}$	0.7	0.7	1.9	1.9	∞
4	Hemispherical isotropy	9.4	R	$\sqrt{3}$	0.7	0.7	3.9	3.9	∞
5	Boundary effect	1.0	R	$\sqrt{3}$	1	1	0.6	0.6	∞
6	Linearity	4.7	R	$\sqrt{3}$	1	1	2.7	2.7	∞
7	Detection limits	1.0	R	$\sqrt{3}$	1	1	0.6	0.6	∞
8	Readout electronics	0.3	N	1	1	1	0.3	0.3	∞
9	Response time	0.8	R	$\sqrt{3}$	1	1	0.5	0.5	∞
10	Integration time	2.6	R	$\sqrt{3}$	1	1	1.5	1.5	∞
11	Ambient noise	3.0	R	$\sqrt{3}$	1	1	1.7	1.7	∞
12	Ambient reflections	3.0	R	$\sqrt{3}$	1	1	1.7	1.7	∞
13	Probe positioner mech. restrictions	0.4	R	$\sqrt{3}$	1	1	0.2	0.2	∞
14	Probe positioning with respect to phantom shell	2.9	R	$\sqrt{3}$	1	1	1.7	1.7	∞
15	Max.SAR evaluation	1.0	R	$\sqrt{3}$	1	1	0.6	0.6	∞

Test sample related									
16	Device positioning	3.8	N	1	1	1	3.8	3.8	99
17	Device holder	5.1	N	1	1	1	5.1	5.1	5
18	Drift of output power	5.0	R	$\sqrt{3}$	1	1	2.9	2.9	∞
Phantom and set-up									
19	Phantom uncertainty	4.0	R	$\sqrt{3}$	1	1	2.3	2.3	∞
20	Liquid conductivity (target)	5.0	R	$\sqrt{3}$	0.64	0.43	1.8	1.2	∞
21	Liquid conductivity (meas)	2.5	N	1	0.64	0.43	1.6	1.2	∞
22	Liquid Permittivity (target)	5.0	R	$\sqrt{3}$	0.6	0.49	1.7	1.5	∞
23	Liquid Permittivity (meas)	2.5	N	1	0.6	0.49	1.5	1.2	∞
Combined standard			RSS	$U_C = \sqrt{\sum_{i=1}^{n} C_i^2 U_i^2}$			11.4%	11.3%	236
Expanded uncertainty(P=95%)		$U_c = k U$,k=2					**22.8%**	**22.6%**	

Appendix A. EUT Photos and Test Setup Photos

Front (10mm)

Back(10mm)

Left Side (10mm)

Right Side (10mm)

Top Side (10mm)

Appendix B. Plots of SAR System Check

835MHz Head System Check Date:06/26/2023

DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d154

Communication System: CW; Frequency: 835 MHz;Duty Cycle: 1:1

Medium parameters used (interpolated): f = 835 MHz; σ = 0.93 S/m; ε_r = 54.84; ρ = 1000 kg/m^3

Phantom section: Flat Section

DASY5 Configuration:

•Probe: EX3DV4 - SN7396; ConvF(9.88, 9.88, 9.88); Calibrated: 05,06.2023;

•Sensor-Surface: 4mm (Mechanical Surface Detection)

•Electronics: DAE4 Sn387; Calibrated: Sep.06,2022;

•Phantom: SAM 1; Type: SAM;

•Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

Area Scan (61x91x1): Measurement grid: dx=15.00 mm, dy=15.00 mm

Maximum value of SAR (interpolated) = 2.875 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 50.286 V/m; Power Drift = -0.11 dB

Peak SAR (extrapolated) = 3.175 W/kg

SAR(1 g) = 2.33 W/kg; SAR(10 g) = 1.55 W/kg

Maximum value of SAR (measured) = 2.574 W/kg



1750MHz Head System Check Date:06/27/2023

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2

Communication System: CW; Frequency: 1750 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f =1750 MHz; σ =1.43 S/m; εr =53.16; ρ =1000 kg/m3
Phantom section: Flat Section
Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7396; ConvF(8.24, 8.24, 8.24); Calibrated: May,06.2023;
- Sensor-Surface: 4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06.2022;
- Phantom: SAM 1 ; Type: QD 000 P40 CD; Serial: TP - 1802
- Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

Configuration/Pin=250mW/Area Scan (71x71x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm
Maximum value of SAR (interpolated) = 12.122 W/kg

Configuration/Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 92.35 V/m; Power Drift = -0.03 dB
Peak SAR (extrapolated) = 16.353 W/kg
SAR(1 g) =9.69 W/kg; SAR(10 g) = 5.08 W/kg
Maximum value of SAR (measured) = 12.142 W/kg



1900MHz Head System Check Date:06/28/2023

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d175

Communication System: CW; Frequency: 1900 MHz;Duty Cycle: 1:1

Medium parameters used (interpolated): f = 1900 MHz; σ = 1.49S/m; εr = 52.92; ρ = 1000 kg/m3

Phantom section: Flat Section

DASY5 Configuration:

Probe: EX3DV4 - SN7396; ConvF(7.97, 7.97, 7.97); Calibrated: 05,06.2023;

Sensor-Surface: 3mm (Mechanical Surface Detection)

Electronics: DAE4 Sn387; Calibrated: Sep.06,2022;

Phantom: SAM 1; Type: SAM;

Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.5 (6469)

Area Scan (61x91x1): Measurement grid: dx=15.00 mm, dy=15.00 mm

Maximum value of SAR (interpolated) = 16.895 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 87.671 V/m; Power Drift = 0.08dB

Peak SAR (extrapolated) = 19.868 W/kg

SAR(1 g) = 10.18 W/kg; SAR(10 g) = 5.37 W/kg

Maximum value of SAR (measured) = 15.332 W/kg



2600MHz Head System Check Date:06/30/2023

DUT: Dipole 2600 MHz; Type: D2600V2;

Communication System: CW; Frequency: 2600 MHz;Duty Cycle: 1:1

Medium parameters used (interpolated): f = 2600 MHz; σ = 2.17 S/m; εr = 52.21; ρ = 1000 kg/m3

Phantom section: Flat Section

DASY5 Configuration:

- Probe: EX3DV4 – SN7396; ConvF(7.38, 7.38, 7.38); Calibrated: 05,06.2023;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06.2022
- Phantom: SAM; Type: QD000P40CD; Serial: TP:1670
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

Configuration/Pin=250mW/Area Scan (81x81x1): Interpolated grid: dx=1.200 mm, dy=1.200 mm

Maximum value of SAR (interpolated) = 24.576 W/kg

Configuration/Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 110.147 V/m; Power Drift = 0.13 dB

Peak SAR (extrapolated) = 33.245 W/kg

SAR(1 g) = 13.91 W/kg; SAR(10 g) = 6.43 W/kg

Maximum value of SAR (measured) = 25.668 W/kg



Appendix C. Plots of SAR Test Data

#1 Date: 06/28/2023

LTE Band 2_ Body Front_1RB_Ch18700

Communication System: UID 0, Generic LTE (0); Frequency: 1860.0 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f = 1860.0 MHz; σ = 1.49 S/m; ε_r = 52.92; ρ = 1000 kg/m^3
Phantom section: Flat Section

DASY5 Configuration:

- Probe: EX3DV4 – SN7396; ConvF(7.97, 7.97, 7.97); Calibrated: May,06.2023;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06,2022
- Phantom: SAM; Type: QD000P40CD; Serial: TP:1670
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

BODY/FRONT /Area Scan (81x81x1): Measurement grid: dx=1.500mm, dy=1.500mm
Maximum value of SAR (interpolated) = 0.946 W/kg

BODY/FRONT /Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 23.36 V/m; Power Drift = 0.12 dB
Peak SAR (extrapolated) = 0.982 W/kg
SAR(1 g) = 0.455 W/kg; SAR(10 g) = 0.237 W/kg
Maximum value of SAR (measured) = 0.743 W/kg



#2 Date: 06/27/2023

LTE Band 4_ Body Front_1RB_Ch20175

Communication System: UID 0, Generic LTE (0); Frequency: 1732.5 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f = 1732.5 MHz; σ = 1.43 S/m; ε_r = 53.16; ρ = 1000 kg/m^3
Phantom section: Flat Section

DASY5 Configuration:

- Probe: EX3DV4 – SN7396; ConvF(8.24, 8.24, 8.24); Calibrated: May,06.2023;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06,2022
- Phantom: SAM; Type: QD000P40CD; Serial: TP:1670
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

BODY/FRONT /Area Scan (81x81x1): Measurement grid: dx=1.500mm, dy=1.500mm
Maximum value of SAR (interpolated) = 0.774 W/kg

BODY/FRONT /Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 9.465 V/m; Power Drift = -0.06 dB
Peak SAR (extrapolated) = 0.819 W/kg
SAR(1 g) = 0.445 W/kg; SAR(10 g) = 0.218 W/kg
Maximum value of SAR (measured) = 0.898 W/kg



LTE Band 5_ Body Front_1RB_Ch20525

Communication System: UID 0, Generic LTE (0); Frequency: 836.5 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f = 836.5 MHz; σ = 0.93 S/m; ε_r= 54.87; ρ = 1000 kg/m^3
Phantom section: Flat Section

DASY5 Configuration:

- Probe: EX3DV4 – SN7396; ConvF(9.88, 9.88, 9.88); Calibrated: May 06, 2023;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06,2022
- Phantom: SAM; Type: QD000P40CD; Serial: TP:1670
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

BODY/FRONT /Area Scan (81x81x1): Measurement grid: dx=1.500mm, dy=1.500mm
Maximum value of SAR (interpolated) = 0.812 W/kg

BODY/FRONT /Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 8.304 V/m; Power Drift = 0.06 dB
Peak SAR (extrapolated) = 0.833 W/kg
SAR(1 g) = 0.389 W/kg; SAR(10 g) = 0.198 W/kg
Maximum value of SAR (measured) = 0.904 W/kg



LTE Band 41_ Body Front_1RB_Ch41140

Communication System: UID 0, Generic LTE (0); Frequency: 2645 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f = 2645 MHz; σ = 2.17 S/m; ε_r= 52.21; ρ = 1000 kg/m^3
Phantom section: Flat Section

DASY5 Configuration:

- Probe: EX3DV4 – SN7396; ConvF(10.09, 10.09,10.09); Calibrated: May 06, 2023;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: Sep.06,2022
- Phantom: SAM; Type: QD000P40CD; Serial: TP:1670
- Measurement SW: DASY52, Version 52.8 (2); SEMCAD X Version 14.6.10 (7164)

BODY/FRONT /Area Scan (81x81x1): Measurement grid: dx=1.500mm, dy=1.500mm
Maximum value of SAR (interpolated) = 0.924 W/kg

BODY/FRONT /Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 9.746 V/m; Power Drift = -0.12 dB
Peak SAR (extrapolated) = 0.955 W/kg
SAR(1 g) = 0.421 W/kg; SAR(10 g) = 0.211 W/kg
Maximum value of SAR (measured) = 0.838 W/kg



Appendix D. DASY System Calibration Certificate

In Collaboration with
CTTL speag CALIBRATION LABORATORY
ilac-MRA CNAS 中国认可 国际互认 校准 CALIBRATION CNAS L0570

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Client **Anbotek (Auden)** **Certificate No: Z23-98671**

CALIBRATION CERTIFICATE

Object	EX3DV4 - SN:7396
Calibration Procedure(s)	FF-Z12-006-08 Calibration Procedures for Dosimetric E-field Probes
Calibration date:	May 06 , 2023

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature(22±3)℃ and humidity<70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	101919	20-Jun-22 (CTTL, No.J22X07447)	Jun-21
Power sensor NRP-Z91	101547	20-Jun-22 (CTTL, No.J22X07447)	Jun-21
Power sensor NRP-Z91	101548	20-Jun-22 (CTTL, No.J22X07447)	Jun-21
Reference10dBAttenuator	18N50W-10dB	13-Mar-23(CTTL,No.J23X01547)	Mar-22
Reference20dBAttenuator	18N50W-20dB	13-Mar-23(CTTL, No.J23X01548)	Mar-22
Reference Probe EX3DV4	SN 7433	26-Sep-22(SPEAG,No.EX3-7433_Sep22)	Sep-21
DAE4	SN 549	13-Dec-22(SPEAG, No.DAE4-549_Dec22)	Dec -21
Secondary Standards	**ID #**	**Cal Date(Calibrated by, Certificate No.)**	**Scheduled Calibration**
SignalGeneratorMG3700A	6201052605	27-Jun-22 (CTTL, No.J22X04776)	Jun-21
Network Analyzer E5071C	MY46110673	13-Jan-23 (CTTL, No.J23X00285)	Jan -22

	Name	Function	Signature
Calibrated by:	Yu Zongying	SAR Test Engineer	
Reviewed by:	Lin Hao	SAR Test Engineer	
Approved by:	Qi Dianyuan	SAR Project Leader	

Issued: May06 , 2023

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

In Collaboration with
CTTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Glossary:

TSL	tissue simulating liquid
NORMx,y,z	sensitivity in free space
ConvF	sensitivity in TSL / NORMx,y,z
DCP	diode compression point
CF	crest factor (1/duty_cycle) of the RF signal
A,B,C,D	modulation dependent linearization parameters
Polarization Φ	Φ rotation around probe axis
Polarization θ	θ rotation around an axis that is in the plane normal to probe axis (at measurement center), i θ=0 is normal to probe axis
Connector Angle	information used in DASY system to align probe sensor X to the robot coordinate system

Calibration is Performed According to the Following Standards:

a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013

b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) for hand-held devices used in close proximity to the ear (frequency range of 300MHz to 3GHz)", February 2005

c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010

d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Methods Applied and Interpretation of Parameters:

- *NORMx,y,z:* Assessed for E-field polarization θ=0 (f≤900MHz in TEM-cell; f>1800MHz: waveguide). NORMx,y,z are only intermediate values, i.e., the uncertainties of NORMx,y,z does not effect the E^2-field uncertainty inside TSL (see below ConvF).
- *NORM(f)x,y,z = NORMx,y,z* frequency_response* (see Frequency Response Chart). This linearization is implemented in DASY4 software versions later than 4.2. The uncertainty of the frequency response is included in the stated uncertainty of ConvF.
- *DCPx,y,z:* DCP are numerical linearization parameters assessed based on the data of power sweep (no uncertainty required). DCP does not depend on frequency nor media.
- PAR: PAR is the Peak to Average Ratio that is not calibrated but determined based on the signal characteristics.
- *Ax,y,z; Bx,y,z; Cx,y,z;VRx,y,z:*A,B,C are numerical linearization parameters assessed based on the data of power sweep for specific modulation signal. The parameters do not depend on frequency nor media. VR is the maximum calibration range expressed in RMS voltage across the diode.
- *ConvF and Boundary Effect Parameters:* Assessed in flat phantom using E-field (or Temperature Transfer Standard for f≤800MHz) and inside waveguide using analytical field distributions based on power measurements for f >800MHz. The same setups are used for assessment of the parameters applied for boundary compensation (alpha, depth) of which typical uncertainty valued are given. These parameters are used in DASY4 software to improve probe accuracy close to the boundary. The sensitivity in TSL corresponds to NORMx,y,z* ConvF whereby the uncertainty corresponds to that given for ConvF. A frequency dependent ConvF is used in DASY version 4.4 and higher which allows extending the validity from±50MHz to±100MHz.
- *Spherical isotropy (3D deviation from isotropy):* in a field of low gradients realized using a flat phantom exposed by a patch antenna.
- *Sensor Offset:* The sensor offset corresponds to the offset of virtual measurement center from the probe tip (on probe axis). No tolerance required.
- *Connector Angle:* The angle is assessed using the information gained by determining the *NORMx* (no uncertainty required).

In Collaboration with
CTTL speag CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Probe EX3DV4

SN: 7396

Calibrated: May 06, 2022

Calibrated for DASY/EASY Systems

(Note: non-compatible with DASY2 system!)

In Collaboration with
TTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY/EASY – Parameters of Probe: EX3DV4 – SN: 7396

Basic Calibration Parameters

	Sensor X	Sensor Y	Sensor Z	Unc (k=2)
Norm(μV/(V/m)^2) [A]	0.54	0.53	0.50	±10.0%
DCP(mV) [B]	97.8	104.5	102.5	

Modulation Calibration Parameters

UID	Communication System Name		A dB	B dB√μV	C	D dB	VR mV	Unc [E] (k=2)
0	CW	X	0.0	0.0	1.0	0.00	199.9	±2.4%
		Y	0.0	0.0	1.0		203.3	
		Z	0.0	0.0	1.0		195.0	

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.

[A] The uncertainties of Norm X, Y, Z do not affect the E^2-field uncertainty inside TSL (see Page 5 and Page 6).
[B] Numerical linearization parameter: uncertainty not required.
[E] Uncertainly is determined using the max. deviation from linear response applying rectangular distribution and is expressed for the square of the field value.

In Collaboration with
CTTL speag CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY/EASY – Parameters of Probe: EX3DV4 – SN: 7396

Calibration Parameter Determined in Head Tissue Simulating Media

f [MHz][C]	Relative Permittivity[F]	Conductivity (S/m)[F]	ConvF X	ConvF Y	ConvF Z	Alpha[G]	Depth[G] (mm)	Unct. (k=2)
750	41.9	0.89	9.82	9.82	9.82	0.30	0.85	±12.1%
835	41.5	0.90	9.71	9.71	9.71	0.15	1.36	±12.1%
900	41.5	0.97	9.87	9.87	9.87	0.16	1.37	±12.1%
1750	40.1	1.37	8.61	8.61	8.61	0.25	1.04	±12.1%
1900	40.0	1.40	8.13	8.13	8.13	0.24	1.01	±12.1%
2100	39.8	1.49	8.14	8.14	8.14	0.24	1.04	±12.1%
2300	39.5	1.67	7.85	7.85	7.85	0.40	0.75	±12.1%
2450	39.2	1.80	7.57	7.57	7.57	0.50	0.75	±12.1%
2600	39.0	1.96	7.38	7.38	7.38	0.64	0.68	±12.1%
5250	35.9	4.71	5.33	5.33	5.33	0.45	1.30	±13.3%
5600	35.5	5.07	4.89	4.89	4.89	0.45	1.35	±13.3%
5750	35.4	5.22	4.92	4.92	4.92	0.45	1.45	±13.3%

[C] Frequency validity above 300 MHz of ±100MHz only applies for DASY v4.4 and higher (Page 2), else it is restricted to ±50MHz. The uncertainty is the RSS of ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.

[F] At frequency below 3 GHz, the validity of tissue parameters (ε and σ) can be relaxed to ±10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ε and σ) is restricted to ±5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

[G] Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for the frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

In Collaboration with
CTTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY/EASY – Parameters of Probe: EX3DV4 – SN: 7396

Calibration Parameter Determined in Body Tissue Simulating Media

f [MHz][C]	Relative Permittivity [F]	Conductivity (S/m) [F]	ConvF X	ConvF Y	ConvF Z	Alpha[G]	Depth[G] (mm)	Unct. (k=2)
750	55.5	0.96	10.09	10.09	10.09	0.30	0.90	±12.1%
835	55.2	0.97	9.88	9.88	9.88	0.19	1.32	±12.1%
900	55.0	1.05	9.82	9.82	9.82	0.23	1.15	±12.1%
1750	53.4	1.49	8.24	8.24	8.24	0.24	1.06	±12.1%
1900	53.3	1.52	7.97	7.97	7.97	0.19	1.24	±12.1%
2100	53.2	1.62	8.18	8.18	8.18	0.19	1.39	±12.1%
2300	52.9	1.81	7.88	7.88	7.88	0.55	0.80	±12.1%
2450	52.7	1.95	7.53	7.53	7.53	0.46	0.89	±12.1%
2600	52.5	2.16	7.38	7.38	7.38	0.52	0.80	±12.1%
5250	48.9	5.36	4.93	4.93	4.93	0.45	1.80	±13.3%
5600	48.5	5.77	4.19	4.19	4.19	0.48	1.90	±13.3%
5750	48.3	5.94	4.52	4.52	4.52	0.48	1.95	±13.3%

[C] Frequency validity above 300 MHz of ±100MHz only applies for DASY v4.4 and higher (Page 2), else it is restricted to ±50MHz. The uncertainty is the RSS of ConvF uncertainty at calibration frequency and the uncertainty for the indicated frequency band. Frequency validity below 300 MHz is ± 10, 25, 40, 50 and 70 MHz for ConvF assessments at 30, 64, 128, 150 and 220 MHz respectively. Above 5 GHz frequency validity can be extended to ± 110 MHz.

[F] At frequency below 3 GHz, the validity of tissue parameters (ε and σ) can be relaxed to ±10% if liquid compensation formula is applied to measured SAR values. At frequencies above 3 GHz, the validity of tissue parameters (ε and σ) is restricted to ±5%. The uncertainty is the RSS of the ConvF uncertainty for indicated target tissue parameters.

[G] Alpha/Depth are determined during calibration. SPEAG warrants that the remaining deviation due to the boundary effect after compensation is always less than ± 1% for frequencies below 3 GHz and below ± 2% for the frequencies between 3-6 GHz at any distance larger than half the probe tip diameter from the boundary.

In Collaboration with
CTTL s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Frequency Response of E-Field
(TEM-Cell: ifi110 EXX, Waveguide: R22)



Uncertainty of Frequency Response of E-field: ±7.4% (k=2)

In Collaboration with
CTTL speag
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Receiving Pattern (Φ), θ=0°

f=600 MHz, TEM



f=1800 MHz, R22





Uncertainty of Axial Isotropy Assessment: ±1.2% (k=2)

In Collaboration with
CTTL s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Dynamic Range f(SAR_{head})
(TEM cell, f = 900 MHz)





Uncertainty of Linearity Assessment: ±0.9% (k=2)

Certificate No: Z21-98671 Page 9 of 11

In Collaboration with
CTTL s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Conversion Factor Assessment

f=900 MHz, WGLS R9(H_convF)



f=1750 MHz, WGLS R22(H_convF)



Deviation from Isotropy in Liquid



Uncertainty of Spherical Isotropy Assessment: ±3.2% (K=2)

In Collaboration with
CTTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2218 Fax: +86-10-62304633-2209
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY/EASY – Parameters of Probe: EX3DV4 – SN: 7396

Other Probe Parameters

Sensor Arrangement	Triangular
Connector Angle (°)	156.9
Mechanical Surface Detection Mode	enabled
Optical Surface Detection Mode	disable
Probe Overall Length	337mm
Probe Body Diameter	10mm
Tip Length	9mm
Tip Diameter	2.5mm
Probe Tip to Sensor X Calibration Point	1mm
Probe Tip to Sensor Y Calibration Point	1mm
Probe Tip to Sensor Z Calibration Point	1mm
Recommended Measurement Distance from Surface	1.4mm

Schmid & Partner Engineering AG

s p e a g

Zeughausstrasse 43, 8004 Zurich, Switzerland
Phone +41 44 245 9700, Fax +41 44 245 9779
info@speag.com, http://www.speag.com

IMPORTANT NOTICE

USAGE OF THE DAE 4

The DAE unit is a delicate, high precision instrument and requires careful treatment by the user. There are no serviceable parts inside the DAE. Special attention shall be given to the following points:

Battery Exchange: The battery cover of the DAE4 unit is closed using a screw, over tightening the screw may cause the threads inside the DAE to wear out.

Shipping of the DAE: Before shipping the DAE to SPEAG for calibration, remove the batteries and pack the DAE in an antistatic bag. This antistatic bag shall then be packed into a larger box or container which protects the DAE from impacts during transportation. The package shall be marked to indicate that a fragile instrument is inside.

E-Stop Failures: Touch detection may be malfunctioning due to broken magnets in the E-stop. Rough handling of the E-stop may lead to damage of these magnets. Touch and collision errors are often caused by dust and dirt accumulated in the E-stop. To prevent E-stop failure, the customer shall always mount the probe to the DAE carefully and keep the DAE unit in a non-dusty environment if not used for measurements.

Repair: Minor repairs are performed at no extra cost during the annual calibration. However, SPEAG reserves the right to charge for any repair especially if rough unprofessional handling caused the defect.

DASY Configuration Files: Since the exact values of the DAE input resistances, as measured during the calibration procedure of a DAE unit, are not used by the DASY software, a nominal value of 200 MOhm is given in the corresponding configuration file.

Important Note:
Warranty and calibration is void if the DAE unit is disassembled partly or fully by the Customer.

Important Note:
Never attempt to grease or oil the E-stop assembly. Cleaning and readjusting of the E-stop assembly is allowed by certified SPEAG personnel only and is part of the annual calibration procedure.

Important Note:
To prevent damage of the DAE probe connector pins, use great care when installing the probe to the DAE. Carefully connect the probe with the connector notch oriented in the mating position. Avoid any rotational movement of the probe body versus the DAE while turning the locking nut of the connector. The same care shall be used when disconnecting the probe from the DAE.

Schmid & Partner Engineering

TN_BR040315AD DAE4.doc 11.12.2009

Calibration Laboratory of
Schmid & Partner
Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland

S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: SCS 0108

Client **Anbotek (Auden)** **Certificate No: DAE4-387_Sep10**

CALIBRATION CERTIFICATE

Object	DAE4 - SD 000 D04 BM - SN: 387
Calibration procedure(s)	QA CAL-06.v29 Calibration procedure for the data acquisition electronics (DAE)
Calibration date:	September 06, 2022

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Keithley Multimeter Type 2001	SN: 0810278	15-Aug-21 (No:22092)	Aug-22
Secondary Standards	**ID #**	**Check Date (in house)**	**Scheduled Check**
Auto DAE Calibration Unit	SE UWS 053 AA 1001	05-Jan-22 (in house check)	In house check: Jan-23
Calibrator Box V2.1	SE UMS 006 AA 1002	05-Jan-22 (in house check)	In house check: Jan-23

	Name	Function	Signature
Calibrated by:	Dominique Steffen	Laboratory Technician	
Approved by:	Sven Kühn	Deputy Manager	

Issued: September 06, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Calibration Laboratory of
Schmid & Partner
Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland

S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
S Servizio svizzero di taratura
Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: SCS 0108

Glossary

DAE	data acquisition electronics
Connector angle	information used in DASY system to align probe sensor X to the robot coordinate system.

Methods Applied and Interpretation of Parameters

- *DC Voltage Measurement:* Calibration Factor assessed for use in DASY system by comparison with a calibrated instrument traceable to national standards. The figure given corresponds to the full scale range of the voltmeter in the respective range.
- *Connector angle*: The angle of the connector is assessed measuring the angle mechanically by a tool inserted. Uncertainty is not required.
- The following parameters as documented in the Appendix contain technical information as a result from the performance test and require no uncertainty.
  - *DC Voltage Measurement Linearity:* Verification of the Linearity at +10% and -10% of the nominal calibration voltage. Influence of offset voltage is included in this measurement.
  - *Common mode sensitivity:* Influence of a positive or negative common mode voltage on the differential measurement.
  - *Channel separation:* Influence of a voltage on the neighbor channels not subject to an input voltage.
  - *AD Converter Values with inputs shorted:* Values on the internal AD converter corresponding to zero input voltage
  - *Input Offset Measurement*: Output voltage and statistical results over a large number of zero voltage measurements.
  - *Input Offset Current:* Typical value for information; Maximum channel input offset current, not considering the input resistance.
  - *Input resistance:* Typical value for information: DAE input resistance at the connector, during internal auto-zeroing and during measurement.
  - *Low Battery Alarm Voltage:* Typical value for information. Below this voltage, a battery alarm signal is generated.
  - *Power consumption:* Typical value for information. Supply currents in various operating modes.

DC Voltage Measurement

A/D - Converter Resolution nominal

High Range: 1LSB = 6.1μV , full range = -100...+300 mV
Low Range: 1LSB = 61nV , full range = -1.....+3mV

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

Calibration Factors	X	Y	Z
High Range	404.489 ± 0.02% (k=2)	404.852 ± 0.02% (k=2)	404.862 ± 0.02% (k=2)
Low Range	3.97827 ± 1.50% (k=2)	3.95875 ± 1.50% (k=2)	3.97982 ± 1.50% (k=2)

Connector Angle

Connector Angle to be used in DASY system	53.0 ° ± 1 °

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

Appendix (Additional assessments outside the scope of SCS0108)

1. DC Voltage Linearity

High Range		Reading (µV)	Difference (µV)	Error (%)
Channel X	+ Input	200032.85	-3.31	-0.00
Channel X	+ Input	20007.64	1.88	0.01
Channel X	- Input	-20003.48	1.18	-0.01
Channel Y	+ Input	200034.23	-1.43	-0.00
Channel Y	+ Input	20006.60	0.91	0.00
Channel Y	- Input	-20004.04	0.72	-0.00
Channel Z	+ Input	200035.38	-0.83	-0.00
Channel Z	+ Input	20003.69	-2.11	-0.01
Channel Z	- Input	-20006.38	-1.59	0.01

Low Range		Reading (µV)	Difference (µV)	Error (%)
Channel X	+ Input	2001.63	0.08	0.00
Channel X	+ Input	202.29	0.70	0.35
Channel X	- Input	-197.90	0.60	-0.30
Channel Y	+ Input	2001.33	-0.07	-0.00
Channel Y	+ Input	200.86	-0.60	-0.30
Channel Y	- Input	-199.87	-1.23	0.62
Channel Z	+ Input	2001.61	0.27	0.01
Channel Z	+ Input	200.60	-0.70	-0.35
Channel Z	- Input	-199.51	-0.85	0.43

2. Common mode sensitivity

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

	Common mode Input Voltage (mV)	High Range Average Reading (µV)	Low Range Average Reading (µV)
Channel X	200	13.50	11.56
	- 200	-8.64	-11.18
Channel Y	200	-0.81	-1.28
	- 200	1.05	0.09
Channel Z	200	7.17	6.91
	- 200	-9.46	-9.01

3. Channel separation

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

	Input Voltage (mV)	Channel X (µV)	Channel Y (µV)	Channel Z (µV)
Channel X	200	-	-1.70	0.33
Channel Y	200	10.70	-	-0.38
Channel Z	200	7.11	7.89	-

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

4. AD-Converter Values with inputs shorted

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec

	High Range (LSB)	Low Range (LSB)
Channel X	15969	17466
Channel Y	15661	16162
Channel Z	15990	16190

5. Input Offset Measurement

DASY measurement parameters: Auto Zero Time: 3 sec; Measuring time: 3 sec
Input 10MΩ

	Average (μV)	min. Offset (μV)	max. Offset (μV)	Std. Deviation (μV)
Channel X	0.73	-2.58	3.29	0.62
Channel Y	0.41	-0.49	1.23	0.40
Channel Z	-0.80	-1.88	0.30	0.42

6. Input Offset Current

Nominal Input circuitry offset current on all channels: <25fA

7. Input Resistance (Typical values for information)

	Zeroing (kOhm)	Measuring (MOhm)
Channel X	200	200
Channel Y	200	200
Channel Z	200	200

8. Low Battery Alarm Voltage (Typical values for information)

Typical values	Alarm Level (VDC)
Supply (+ Vcc)	+7.9
Supply (- Vcc)	-7.6

9. Power Consumption (Typical values for information)

Typical values	Switched off (mA)	Stand by (mA)	Transmitting (mA)
Supply (+ Vcc)	+0.01	+6	+14
Supply (- Vcc)	–0.01	-8	-9

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

In Collaboration with
CTTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

中国认可 国际互认 校准 CALIBRATION CNAS L0570

Client Anbotek (Auden) **Certificate No: Z18-97089**

CALIBRATION CERTIFICATE

Object	D835V2 - SN: 4d154
Calibration Procedure(s)	FD-Z11-2-003-01 Calibration Procedures for dipole validation kits
Calibration date:	Jun 16, 2021

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature(22±3)℃ and humidity<70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	101919	1-Jul-20 (CTTL, No.J17X04256)	Jun-21
Power sensor NRP-Z91	101547	1-Jul-20 (CTTL, No.J17X04256)	Jun-21
Reference Probe EX3DV4	SN 7307	19-Feb-21(SPEAG,No.EX3-7307_Feb18)	Feb-22
DAE4	SN 771	02-Feb-21(CTTL-SPEAG,No.Z18-97011)	Feb-22
Secondary Standards	**ID #**	**Cal Date(Calibrated by, Certificate No.)**	**Scheduled Calibration**
Signal Generator E4438C	MY49071430	01-Feb-21 (CTTL, No.J18X00893)	Jan-22
Network Analyzer E5071C	MY46110673	26-Jan-21 (CTTL, No.J18X00894)	Jan-22

	Name	Function	Signature
Calibrated by:	Zhao Jing	SAR Test Engineer	
Reviewed by:	Qi Dianyuan	SAR Project Leader	
Approved by:	Lu Bingsong	Deputy Director of the laboratory	

Issued: Jun 17, 2021

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: 186-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: ctl@chinatl.com Http://www.chinatl.com

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORMx,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013

b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) For hand-held devices used in close proximity to the ear (frequency range of 300MHz to 3GHz)", February 2005

c) IEC 62209-2, "Procedure to measure the Specific Absorption Rate (SAR) For wireless communication devices used in close proximity to the human body (frequency range of 30MHz to 6GHz)", March 2010

d) KDB865664, SAR Measurement Requirements for 100 MHz to 6 GHz

Additional Documentation:

e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY52	52.8.8.1258
Extrapolation	Advanced Extrapolation	
Phantom	Triple Flat Phantom 5.1C	
Distance Dipole Center - TSL	15 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	835 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	41.5	0.90 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	41.0 ± 6 %	0.89 mho/m ± 6 %
Head TSL temperature change during test	<1.0 °C	—	—

SAR result with Head TSL

SAR averaged over 1 cm^3 (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	2.30 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**9.24 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Head TSL	Condition	
SAR measured	250 mW input power	1.50 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**6.02 mW /g ± 20.4 % (k=2)**

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	55.2	0.97 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	55.4 ± 6 %	0.99 mho/m ± 6 %
Body TSL temperature change during test	<1.0 °C	—	—

SAR result with Body TSL

SAR averaged over 1 cm^3 (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	2.43 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**9.57 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Body TSL	Condition	
SAR measured	250 mW input power	1.61 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**6.36 mW /g ± 20.4 % (k=2)**

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Appendix

Antenna Parameters with Head TSL

Impedance, transformed to feed point	49.2Ω- 3.11jΩ
Return Loss	- 29.8dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	46.6Ω- 2.33jΩ
Return Loss	- 27.4dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.508 ns

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.
No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Head TSL Date: 06.16.2021

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN: 4d154

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium parameters used: f = 835 MHz; σ = 0.891 S/m; ε_r = 40.97; ρ = 1000 kg/m^3

Phantom section: Right Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7307; ConvF(10.01, 10.01,10.01); Calibrated: 2/19/2021;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2021-02-02
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51 CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

Dipole Calibration/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 58.14V/m; Power Drift = 0.02 dB

Peak SAR (extrapolated) = 3.41 W/kg

SAR(1 g) = 2.3 W/kg; SAR(10 g) = 1.5 W/kg

Maximum value of SAR (measured) = 2.91 W/kg



0 dB = 2.91 W/kg = 4.64 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Head TSL



In Collaboration wi
s p e a g
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Body TSL Date: 06.16.2021

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 835 MHz; Type: D835V2; Serial: D835V2 - SN: 4d154

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium parameters used: f = 835 MHz; σ = 0.991 S/m; ε_r = 55.41; ρ = 1000 kg/m^3

Phantom section: Center Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7307; ConvF(9.83,9.83, 9.83); Calibrated: 2/19/2021;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2021-02-02
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51 CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

Dipole Calibration/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 54.01 V/m; Power Drift = 0.01 dB

Peak SAR (extrapolated) = 3.53 W/kg

SAR(1 g) = 2.43 W/kg; SAR(10 g) = 1.61 W/kg

Maximum value of SAR (measured) = 3.04 W/kg



0 dB = 3.04 W/kg = 4.83 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Body TSL



Certificate No: Z18-97089 Page 8 of 8

In Collaboration with
TTL speag CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com http://www.chinattl.com

ilac-MRA CNAS 中国认可 国际互认 校准 CALIBRATION CNAS L0570

Client Anbotek (Auden) **Certificate No:** Z22-97090

CALIBRATION CERTIFICATE

Object	D1900V2 - SN: 5d175
Calibration Procedure(s)	FD-Z11-2-003-01 Calibration Procedures for dipole validation kits
Calibration date:	Jun 15, 2022

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature(22±3)℃ and humidity<70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	101919	01-Jul-22(CTTL, No.J22X04256)	Jun-22
Power sensor NRP-Z91	101547	01-Jul-22(CTTL, No.J22X04256)	Jun-22
Reference Probe EX3DV4	SN 7307	19-Feb-22(SPEAG,No.EX3-7307_Feb19)	Feb-22
DAE4	SN 771	02-Feb-22(CTTL-SPEAG,No.Z22-97011)	Feb-22
Secondary Standards	**ID #**	**Cal Date(Calibrated by, Certificate No.)**	**Scheduled Calibration**
Signal Generator E4438C	MY49071430	01-Feb-22(CTTL, No.J19X00893)	Jan-22
Network Analyzer E5071C	MY46110673	26-Jan-22(CTTL, No.J19X00894)	Jan-22

	Name	Function	Signature
Calibrated by:	Zhao Jing	SAR Test Engineer	
Reviewed by:	Qi Dianyuan	SAR Project Leader	
Approved by:	Lu Bingsong	Deputy Director of the laboratory	

Issued: Jun 17, 2022

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: Z22-97090 Page 1 of 8

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.com

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORMx,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013

b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) For hand-held devices used in close proximity to the ear (frequency range of 300MHz to 3GHz)", February 2005

c) IEC 62209-2, "Procedure to measure the Specific Absorption Rate (SAR) For wireless communication devices used in close proximity to the human body (frequency range of 30MHz to 6GHz)", March 2010

d) KDB865664, SAR Measurement Requirements for 100 MHz to 6 GHz

Additional Documentation:

e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.

In Collaboration with
CTTL speag CALIBRATION LABORATORY
Add. No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: mh@chinatl.com Http://www.chinatl.cn

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY52	52.8.8.1258
Extrapolation	Advanced Extrapolation	
Phantom	Triple Flat Phantom 5.1C	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1900 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.0	1.40 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	40.3 ± 6 %	1.38 mho/m ± 6 %
Head TSL temperature change during test	<1.0 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm^3 (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.99 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**40.4 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Head TSL	Condition	
SAR measured	250 mW input power	5.28 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**21.3 mW /g ± 20.4 % (k=2)**

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.3	1.52 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	53.3 ± 6 %	1.54 mho/m ± 6 %
Body TSL temperature change during test	<1.0 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm^3 (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	10.1 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**40.1 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Body TSL	Condition	
SAR measured	250 mW input power	5.39 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**21.5 mW /g ± 20.4 % (k=2)**

In Collaboration with
CTTL speag CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Appendix

Antenna Parameters with Head TSL

Impedance, transformed to feed point	53.2Ω+ 5.44jΩ
Return Loss	- 24.3dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	48.9Ω+ 5.75jΩ
Return Loss	- 24.6dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.304 ns

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.
No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG

In Collaboration with
CTTL s p e a g CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Head TSL Date: 06.15.2022

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN: 5d175

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium parameters used: f = 1900 MHz; σ = 1.381 S/m; ε_r = 40.33; ρ = 1000 kg/m3

Phantom section: Right Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7307; ConvF(8.1, 8.1, 8.1); Calibrated: 2/19/2022;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2/2/2022
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51 CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

System Performance Check/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 103.5V/m; Power Drift = 0.00 dB

Peak SAR (extrapolated) = 18.0W/kg

SAR(1 g) = 9.99 W/kg; SAR(10 g) = 5.28 W/kg

Maximum value of SAR (measured) = 14.1 W/kg

0 dB = 14.1 W/kg = 11.49 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: ctl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Head TSL



In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: ctl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Body TSL Date: 06.15.2019

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: D1900V2 - SN: 5d175

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium parameters used: f = 1900 MHz; σ = 1.537 S/m; ε_r = 53.34; ρ = 1000 kg/m^3

Phantom section: Center Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 - SN7307; ConvF(7.67, 7.67, 7.67); Calibrated: 2/19/2019;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2/2/2019
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51 CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

System Performance Check/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 96.11 V/m; Power Drift = -0.03 dB

Peak SAR (extrapolated) = 17.8 W/kg

SAR(1 g) = 10.1 W/kg; SAR(10 g) = 5.39 W/kg

Maximum value of SAR (measured) = 14.3 W/kg

0 dB = 14.3 W/kg = 11.55 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Body TSL



Certificate No: Z22-97090 Page 8 of 8

Calibration Laboratory of
Schmid & Partner
Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland

S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: SCS 0108

Client **Anbotek (Auden)**

Certificate No: D2600V2-1058_Jun18

CALIBRATION CERTIFICATE

Object	D2600V2 - SN: 1058
Calibration procedure(s)	QA CAL-05.v9 Calibration procedure for dipole validation kits above 700 MHz
Calibration date:	June 19, 2021

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI).
The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date (Certificate No.)	Scheduled Calibration
Power meter EPM-442A	GB37480704	07-Oct-20 (No. 217-02020)	Oct-15
Power sensor HP 8481A	US37292783	07-Oct-20 (No. 217-02020)	Oct-15
Power sensor HP 8481A	MY41092317	07-Oct-20 (No. 217-02021)	Oct-15
Reference 20 dB Attenuator	SN: 5058 (20k)	01-Apr-21 (No. 217-02131)	Mar-16
Type-N mismatch combination	SN: 5047.2 / 06327	01-Apr-21 (No. 217-02134)	Mar-16
Reference Probe ES3DV3	SN: 3205	30-Dec-20 (No. ES3-3205_Dec14)	Dec-15
DAE4	SN: 601	18-Aug-20 (No. DAE4-601_Aug14)	Aug-15
Secondary Standards	**ID #**	**Check Date (in house)**	**Scheduled Check**
RF generator R&S SMT-06	100005	04-Aug-20 (in house check Oct-13)	In house check: Oct-16
Network Analyzer HP 8753E	US37390585 S4206	18-Oct-20 (in house check Oct-14)	In house check: Oct-15

	Name	Function	Signature
Calibrated by:	Leif Klysner	Laboratory Technician	
Approved by:	Katja Pokovic	Technical Manager	

Issued: June 22, 2021

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Calibration Laboratory of
Schmid & Partner
Engineering AG
Zeughausstrasse 43, 8004 Zurich, Switzerland

S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
Servizio svizzero di taratura
S Swiss Calibration Service

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Accreditation No.: SCS 0108

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORM x,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) for hand-held devices used in close proximity to the ear (frequency range of 300 MHz to 3 GHz)", February 2005
c) IEC 62209-2, "Procedure to determine the Specific Absorption Rate (SAR) for wireless communication devices used in close proximity to the human body (frequency range of 30 MHz to 6 GHz)", March 2010
d) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY5	V52.8.8
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	2600 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	39.0	1.96 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	37.6 ± 6 %	2.05 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C	---	---

SAR result with Head TSL

SAR averaged over 1 cm³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	14.7 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	**57.2 W/kg ± 17.0 % (k=2)**

SAR averaged over 10 cm³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	6.57 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	**25.9 W/kg ± 16.5 % (k=2)**

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	52.5	2.16 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	50.4 ± 6 %	2.22 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	---	---

SAR result with Body TSL

SAR averaged over 1 cm³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	14.5 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	**56.8 W/kg ± 17.0 % (k=2)**

SAR averaged over 10 cm³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	6.45 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	**25.5 W/kg ± 16.5 % (k=2)**

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	50.5 Ω - 6.3 jΩ
Return Loss	- 24.0 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	46.7 Ω - 5.2 jΩ
Return Loss	- 24.0 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.151 ns

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.
No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG
Manufactured on	August 14, 2012

DASY5 Validation Report for Head TSL

Date: 19.06.2021

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2600 MHz; Type: D2600V2; Serial: D2600V2 - SN: 1058

Communication System: UID 0 - CW; Frequency: 2600 MHz
Medium parameters used: f = 2600 MHz; σ = 2.05 S/m; ε_r = 37.6; ρ = 1000 kg/m^3
Phantom section: Flat Section
Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: ES3DV3 - SN3205; ConvF(4.49, 4.49, 4.49); Calibrated: 30.12.2020;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 18.08.2020
- Phantom: Flat Phantom 5.0 (front); Type: QD000P50AA; Serial: 1001
- DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

Dipole Calibration for Head/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 102.6 V/m; Power Drift = 0.02 dB
Peak SAR (extrapolated) = 30.9 W/kg
SAR(1 g) = 14.7 W/kg; SAR(10 g) = 6.57 W/kg
Maximum value of SAR (measured) = 19.6 W/kg



0 dB = 19.6 W/kg = 12.92 dBW/kg

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

Impedance Measurement Plot for Head TSL



DASY5 Validation Report for Body TSL

Date: 19.06.2021

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2600 MHz; Type: D2600V2; Serial: D2600V2 - SN: 1058

Communication System: UID 0 - CW; Frequency: 2600 MHz
Medium parameters used: f = 2600 MHz; σ = 2.22 S/m; ε_r = 50.4; ρ = 1000 kg/m^3
Phantom section: Flat Section
Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: ES3DV3 - SN3205; ConvF(4.13, 4.13, 4.13); Calibrated: 30.12.2020;
- Sensor-Surface: 3mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 18.08.2020
- Phantom: Flat Phantom 5.0 (back); Type: QD000P50AA; Serial: 1002
- DASY52 52.8.8(1222); SEMCAD X 14.6.10(7331)

Dipole Calibration for Body/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 97.96 V/m; Power Drift = 0.00 dB
Peak SAR (extrapolated) = 30.1 W/kg
SAR(1 g) = 14.5 W/kg; SAR(10 g) = 6.45 W/kg
Maximum value of SAR (measured) = 19.5 W/kg



0 dB = 19.5 W/kg = 12.90 dBW/kg

Shenzhen Anbotek Compliance Laboratory Limited
Address:1/F.,Building D,Sogood Science and Technology Park, Sanwei Community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com

Impedance Measurement Plot for Body TSL



Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5800 MHz/Zoom Scan, dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm
Reference Value = 65.22 V/m; Power Drift = -0.03 dB
Peak SAR (extrapolated) = 37.1 W/kg
SAR(1 g) = 7.88 W/kg; SAR(10 g) = 2.2 W/kg
Maximum value of SAR (measured) = 19.7 W/kg



0 dB = 18.2 W/kg = 12.60 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

中国认可 国际互认 校准 CALIBRATION CNAS L0570

Client Anbotek (Auden) Certificate No: Z16-97103

CALIBRATION CERTIFICATE

Object	D1750V2 - SN: 1021
Calibration Procedure(s)	FD-Z11-2-003-01 Calibration Procedures for dipole validation kits
Calibration date:	July 1, 2021

This calibration Certificate documents the traceability to national standards, which realize the physical units of measurements(SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature(22±3)℃ and humidity<70%.

Calibration Equipment used (M&TE critical for calibration)

Primary Standards	ID #	Cal Date(Calibrated by, Certificate No.)	Scheduled Calibration
Power Meter NRP2	101919	27-Jun-21 (CTTL, No.J16X04777)	Jun-17
Power sensor NRP-Z91	101547	27-Jun-21 (CTTL, No.J16X04777)	Jun-17
Reference Probe EX3DV4	SN 7307	19-Feb-21(SPEAG,No.EX3-7307_Feb16)	Feb-17
DAE4	SN 771	02-Feb-21(CTTL-SPEAG,No.Z16-97011)	Feb-17
Secondary Standards	**ID #**	**Cal Date(Calibrated by, Certi ficate No.)**	**Scheduled Calibration**
Signal Generator E4438C	MY49071430	01-Feb-21 (CTTL, No.J16X00893)	Jan-17
Network Analyzer E5071C	MY46110673	26-Jan-21 (CTTL, No.J16X00894)	Jan-17

	Name	Function	Signature
Calibrated by:	Zhao Jing	SAR Test Engineer	
Reviewed by:	Qi Dianyuan	SAR Project Leader	
Approved by:	Lu Bingsong	Deputy Director of the laboratory	

Issued: July 4, 2021

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Glossary:

TSL	tissue simulating liquid
ConvF	sensitivity in TSL / NORMx,y,z
N/A	not applicable or not measured

Calibration is Performed According to the Following Standards:

a) IEEE Std 1528-2013, "IEEE Recommended Practice for Determining the Peak Spatial-Averaged Specific Absorption Rate (SAR) in the Human Head from Wireless Communications Devices: Measurement Techniques", June 2013
b) IEC 62209-1, "Procedure to measure the Specific Absorption Rate (SAR) For hand-held devices used in close proximity to the ear (frequency range of 300MHz to 3GHz)", February 2005
c) IEC 62209-2, "Procedure to measure the Specific Absorption Rate (SAR) For wireless communication devices used in close proximity to the human body (frequency range of 30MHz to 6GHz)", March 2010
d) KDB865664, SAR Measurement Requirements for 100 MHz to 6 GHz

Additional Documentation:

e) DASY4/5 System Handbook

Methods Applied and Interpretation of Parameters:

- *Measurement Conditions:* Further details are available from the Validation Report at the end of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- *Antenna Parameters with TSL:* The dipole is mounted with the spacer to position its feed point exactly below the center marking of the flat phantom section, with the arms oriented parallel to the body axis.
- *Feed Point Impedance and Return Loss:* These parameters are measured with the dipole positioned under the liquid filled phantom. The impedance stated is transformed from the measurement at the SMA connector to the feed point. The Return Loss ensures low reflected power. No uncertainty required.
- *Electrical Delay:* One-way delay between the SMA connector and the antenna feed point. No uncertainty required.
- *SAR measured:* SAR measured at the stated antenna input power.
- *SAR normalized:* SAR as measured, normalized to an input power of 1 W at the antenna connector.
- *SAR for nominal TSL parameters:* The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of Measurement multiplied by the coverage factor k=2, which for a normal distribution Corresponds to a coverage probability of approximately 95%.

Sh
Add
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com
400-003-0500
www.anbotek.com.cn

In Collaboration with
CTTL speag CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY52	52.8.8.1258
Extrapolation	Advanced Extrapolation	
Phantom	Triple Flat Phantom 5.1C	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	1750 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	40.1	1.37 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	40.5 ± 6 %	1.36 mho/m ± 6 %
Head TSL temperature change during test	<1.0 °C	----	----

SAR result with Head TSL

SAR averaged over 1 cm^3 (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	9.17 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**36.9 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Head TSL	Condition	
SAR measured	250 mW input power	4.94 mW / g
SAR for nominal Head TSL parameters	normalized to 1W	**19.8 mW /g ± 20.4 % (k=2)**

Body TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	53.4	1.49 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	53.1 ± 6 %	1.51 mho/m ± 6 %
Body TSL temperature change during test	<1.0 °C	----	----

SAR result with Body TSL

SAR averaged over 1 cm^3 (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	9.25 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**36.7 mW /g ± 20.8 % (k=2)**
SAR averaged over 10 cm^3 (10 g) of Body TSL	Condition	
SAR measured	250 mW input power	4.94 mW / g
SAR for nominal Body TSL parameters	normalized to 1W	**19.7 mW /g ± 20.4 % (k=2)**

Sh
Add
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com
400-003-0500
www.anbotek.com.cn

In Collaboration with
s p e a g
CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Appendix

Antenna Parameters with Head TSL

Impedance, transformed to feed point	48.6Ω- 1.40jΩ
Return Loss	- 33.9dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	46.0Ω+ 0.61jΩ
Return Loss	- 27.5dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.318 ns

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.
No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG

Sh
Add
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com
400-003-0500
www.anbotek.com.cn

In Collaboration with
s p e a
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Head TSL Date: 07.01.2021

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN: 1021

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium parameters used: f = 1750 MHz; σ = 1.362 S/m; εr = 40.49; ρ = 1000 kg/m3

Phantom section: Center Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5.Configuration:

- Probe: EX3DV4 - SN7307; ConvF(8.37, 8.37, 8.37); Calibrated: 2/19/2021;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2/2/2021
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51 CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

System Performance Check/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 47.11V/m; Power Drift = 0.03 dB

Peak SAR (extrapolated) = 16.4W/kg

SAR(1 g) = 9.17 W/kg; SAR(10 g) = 4.94 W/kg

Maximum value of SAR (measured) = 13.0 W/kg



0 dB = 13.0 W/kg = 11.14 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Head TSL



Sh
Add
Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.
Tel:(86) 0755-26066440 Fax:(86) 0755-26014772 Email:service@anbotek.com
400-003-0500
www.anbotek.com.cn

In Collaboration with
CTTL speag CALIBRATION LABORATORY
Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

DASY5 Validation Report for Body TSL Date: 07.01.2021

Test Laboratory: CTTL, Beijing, China

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: D1750V2 - SN: 1021

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium parameters used: f = 1750 MHz; σ = 1.505 S/m; ε_r = 53.06; ρ = 1000 kg/m^3

Phantom section: Left Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2007)

DASY5 Configuration:

- Probe: EX3DV4 -SN7307; ConvF(8.18, 8.18, 8.18); Calibrated: 2/19/2021;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn771; Calibrated: 2/2/2021
- Phantom: Triple Flat Phantom 5.1C; Type: QD 000 P51CA; Serial: 1161/1
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7372)

System Performance Check/Zoom Scan (7x7x7) (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 94.11 V/m; Power Drift = 0.04 dB

Peak SAR (extrapolated) = 16.4 W/kg

SAR(1 g) = 9.25 W/kg; SAR(10 g) = 4.94 W/kg

Maximum value of SAR (measured) = 13.1 W/kg



0 dB = 13.1 W/kg = 11.17 dBW/kg

In Collaboration with
s p e a g
CALIBRATION LABORATORY

Add: No.51 Xueyuan Road, Haidian District, Beijing, 100191, China
Tel: +86-10-62304633-2079 Fax: +86-10-62304633-2504
E-mail: cttl@chinattl.com Http://www.chinattl.cn

Impedance Measurement Plot for Body TSL



Certificate No: Z19-97103 Page 8 of 8

*****END OF REPORT*****