

ND 8442-1

AUDACY	M/N: LCE20A1000	S/N: 1B000001 
120/277 VAC	20 AMP 50/60 Hz LIGHTING LOAD	
For Electronic Ballasts and LED Drivers only		
FCC ID: 2AAMXLCE20A1000		
IC: 11250A - LCE20A1000	LISTED Energy Management Equipment E359679	
This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.		
S/N: 1B000001	IDEAL INDUSTRIES, INC.	S/N: 1B000001 
	Pat. Pending	

Notes to Supplier:

- First two digits of S/N # are fixed. Remaining digits are hexadecimal format and sequential.
- Bar code format: 3 of 9
- Label dimension must be 3 inches wide by 1.5 inches tall
- Must print in a minimum of 600 dpi resolution or similar. All other resolutions must be approved by IDEAL Engineering.
- Vendor or supplier must verify bar code can be read using iOS device Audacy application and using Motorola part number "LS2208-7AZU0100ZNA" laser line scanner.
- Must use UL approved label material, verbiage and lettering.