

Appendix A

Detailed System Check Results

1. System Performance Check
System Performance Check 750 MHz Head
System Performance Check 835 MHz Head
System Performance Check 1750 MHz Head
System Performance Check 1950 MHz Head
System Performance Check 2450 MHz Head
System Performance Check 2600 MHz Head
System Performance Check 3700 MHz Head
System Performance Check 3900 MHz Head
System Performance Check 5250 MHz Head
System Performance Check 5600 MHz Head

SystemPerformance Check 750MHz Head


D750V3-SN 1160

Communication System: ; Frequency: 750.000
Medium: Head Simulating Liquid. Medium parameters used: f= 750.000 MHz; σ = 0.872 S/m; ϵ_r = 43.6

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(10.71, 10.71, 10.71); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 90.0 mm): Measurement Grid: 10.0 mm x 15.0 mm
SAR (1g) = 2.02 W/kg; SAR (10g) = 1.36 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm
Power Drift = -0.00 dB
SAR (1g) = 2.08 W/kg; SAR (10g) = 1.38 W/kg;
M2/M1 [%]=82.9
Dist 3dB Peak [mm]=16.8



SystemPerformance Check 835MHz Head


D835V2-SN 4d105

Communication System: ; Frequency: 835.000
Medium: Head Simulating Liquid. Medium parameters used: f= 835.000 MHz; σ = 0.938 S/m; ϵ_r = 42.2

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(10.29, 10.29, 10.29); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 90.0 mm): Measurement Grid: 10.0 mm x 15.0 mm
SAR (1g) = 2.54 W/kg; SAR (10g) = 1.69 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm
Power Drift = 0.00 dB
SAR (1g) = 2.61 W/kg; SAR (10g) = 1.71 W/kg;
M2/M1 [%]=82.7
Dist 3dB Peak [mm]=16.4



System Performance Check 1750 MHz Head


D1750V2-SN1149

Communication System: D1750; Frequency: 1750.000
Medium: Head Simulating Liquid. Medium parameters used: $f=1750.000$ MHz; $\sigma=1.31$ S/m; $\epsilon_r=40.3$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(8.75, 8.75, 8.75); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (90.0 mm x 150.0 mm): Measurement Grid: 15.0 mm x 15.0 mm
SAR (1g) = 8.69 W/kg; SAR (10g) = 4.62 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 8.0 mm x 8.0 mm x 5.0 mm
Power Drift = -0.01 dB
SAR (1g) = 8.75 W/kg; SAR (10g) = 4.73 W/kg;
M2/M1 [%]=56.0
Dist 3dB Peak [mm]=11.3



System Performance Check 1950MHz Head


D1950V3-SN 1138

Communication System: ; Frequency: 1950.000
Medium: Head Simulating Liquid. Medium parameters used: f= 1950.000 MHz; σ = 1.38 S/m; ϵ_r = 40.2

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(8.4, 8.4, 8.4); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 90.0 mm): Measurement Grid: 10.0 mm x 15.0 mm
SAR (1g) = 10.2 W/kg; SAR (10g) = 5.46 W/kg;

Zoom Scan (32.0 mm x 32.0 mm x 30.0 mm): Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm
Power Drift = -0.01 dB
SAR (1g) = 10.7 W/kg; SAR (10g) = 5.51 W/kg;
M2/M1 [%]=78.8
Dist 3dB Peak [mm]=10.3



System Performance Check 2450MHz Head


D2450V2-SN 733

Communication System: ; Frequency: 2450.000
Medium: Head Simulating Liquid. Medium parameters used: f= 2450.000 MHz; σ = 1.75 S/m; ϵ_r = 39.2

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(7.85, 7.85, 7.85); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 96.0 mm): Measurement Grid: 10.0 mm x 12.0 mm
SAR (1g) = 13.0 W/kg; SAR (10g) = 6.00 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = 0.01 dB
SAR (1g) = 13.1 W/kg; SAR (10g) = 6.14 W/kg;
M2/M1 [%]=79.1
Dist 3dB Peak [mm]=9.0



System Performance Check 2600MHz Head


D2600V2-SN 1125

Communication System: ; Frequency: 2600.000
Medium: Head Simulating Liquid. Medium parameters used: f= 2600.000 MHz; σ = 1.92 S/m; ϵ_r = 38.7

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(7.7, 7.7, 7.7); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 96.0 mm): Measurement Grid: 10.0 mm x 12.0 mm
SAR (1g) = 14.5 W/kg; SAR (10g) = 6.47 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = -0.08 dB
SAR (1g) = 14.6 W/kg; SAR (10g) = 6.57 W/kg;
M2/M1 [%]=77.9
Dist 3dB Peak [mm]=9.0



System Performance Check 3700MHz Head


D3700V2-SN 1046

Communication System: ; Frequency: 3700.000
Medium: Head Simulating Liquid. Medium parameters used: f= 3700.000 MHz; σ = 3.09 S/m; ϵ_r = 39.5

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(6.83, 6.83, 6.83); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 96.0 mm): Measurement Grid: 10.0 mm x 12.0 mm
SAR (1g) = 6.88 W/kg; SAR (10g) = 2.52 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 6.92 W/kg; SAR (10g) = 2.59 W/kg;
M2/M1 [%]=73.7
Dist 3dB Peak [mm]=8.3



System Performance Check 3900MHz Head


D3900V2-SN 1026

Communication System: ; Frequency: 3900.000
Medium: Head Simulating Liquid. Medium parameters used: f= 3900.000 MHz; σ = 3.41 S/m; ϵ_r = 37.2

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(6.72, 6.72, 6.72); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 5.64 W/kg; SAR (10g) = 2.14 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 28.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 6.16 W/kg; SAR (10g) = 2.26 W/kg;
M2/M1 [%]=72.5
Dist 3dB Peak [mm]=9.0



System Performance Check 5250MHz Head


D5GHzV2-SN 1165

Communication System: ; Frequency: 5250.000
Medium: Head Simulating Liquid. Medium parameters used: $f= 5250.000$ MHz; $\sigma= 4.82$ S/m; $\epsilon_r = 36.3$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(5.55, 5.55, 5.55); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 7.85 W/kg; SAR (10g) = 2.33 W/kg;

Zoom Scan (24.0 mm x 24.0 mm x 22.0 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 8.34 W/kg; SAR (10g) = 2.38 W/kg;
M2/M1 [%]=65.0
Dist 3dB Peak [mm]=7.4



SystemPerformance Check 5600MHz Head

D5GHzV2-SN 1165

Communication System: ; Frequency: 5600.000
Medium: Head Simulating Liquid. Medium parameters used: f= 5600.000 MHz; σ = 5.21 S/m; ϵ_r = 35.4

- DASY8 Configuration:
- Probe: EX3DV4 - SN7636; ConvF(4.95, 4.95, 4.95); Calibrated: 2025-08-26
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2024-10-18
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2146
 - Measurement Software: cDASY8 V16.4.0.5005

Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 7.85 W/kg; SAR (10g) = 2.39 W/kg;

Zoom Scan (24.0 mm x 24.0 mm x 22.0 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.03 dB
SAR (1g) = 8.93 W/kg; SAR (10g) = 2.51 W/kg;
M2/M1 [%]=62.5
Dist 3dB Peak [mm]=7.2

