

System Check_H2450

DUT: Dipole 2450 MHz; Type:D2450V2; SN:927

Communication System: CW; Frequency: 2450 MHz;Duty Cycle: 1:1
Medium: H2450 Medium parameters used: f = 2450 MHz; $\sigma = 1.79 \text{ S/m}$; $\epsilon_r = 40.105$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : 22.2 °C; Liquid Temperature : 22.0 °C

- DASY5 Configuration:
- Probe: EX3DV4 - SN3970; ConvF(8.06, 8.06, 8.06); Calibrated: 2022/4/18;
 - Sensor-Surface: 4mm (Mechanical Surface Detection)
 - Electronics: DAE4 Sn1418; Calibrated: 2022/3/24
 - Phantom: ELI v5.0; Type: QDOVA002AA; Serial: TP:1231
 - Measurement SW: DASY52, Version 52.8 (7); SEMCAD X Version 14.6.10 (7164)

Pin=250mW/Area Scan (41x51x1): Interpolated grid: dx=2.000 mm, dy=2.000 mm
Maximum value of SAR (interpolated) = 24.5 W/kg

Pin=250mW/Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 114.7 V/m; Power Drift = 0.14 dB
Peak SAR (extrapolated) = 30.4 W/kg
SAR(1 g) = 13.1 W/kg; SAR(10 g) = 6.10 W/kg
Maximum value of SAR (measured) = 23.0 W/kg

