

Manufactured By



www.fmtweb.com



SMARTFILL FUEL CONTROLLER

File No. MH61323

Model No:

Serial No:

Date of Manufacture:

RATINGS

Inputs:

AC Models: 90 Vac (0.21 A) - 250 Vac (0.1 A), 50/60 Hz

DC Models: 12 Vdc (1.2 A) - 24 Vdc (0.5 A)

Pulser Input: 15 Vdc, 2.5 mA

Nozzle Switch: 3.3 Vdc, 0.2 mA

Power Delay Switch: 36 Vdc, 2 A

Outputs:

For use with dispensing devices containing the following:

Relay Outputs (Pumps 1 - 4):

AC Switching: 240 Vac, 10 A, 50/60 Hz

DC Switching: 24 Vdc, 5 A

FCC ID: 2ARC8-SF3-OPT

Contains FCC ID: RI7LE910CXWWX

CAUTION: This product has more than one power supply connection point. Disconnect all power supplies before servicing. Junction box of sufficient volume. Not suitable for direct connection to intrinsically safe equipment. See installation instructions. For use with peripheral equipment as specified in the installation instructions.

CAUTION: Signal wiring connected in this box must be rated at a minimum of 120 V.

Avertissement: le câblage de signal connecté dans ce boîtier doit être d'une puissance nominale d'au moins 120 V.

Avertissement: ce produit dispose de plusieurs connecteurs d'alimentation. Débranchez toutes les sources d'alimentations avant de procéder à l'entretien.