Appendix A. System Check Plots

Table of Contents
System Performance Check
System validation

Date: 2021-09-07

Place of testing: HUAWEI SAR/HAC Lab

SystemPerformanceCheck-D2450-EX

DUT: Dipole; Type: D2450V2; Serial: 860

Communication System: UID 0, CW (0); Frequency: 2450 MHz;Duty Cycle: 1:1
Medium parameters used (interpolated): f = 2450 MHz; σ = 1.758 S/m; ε_r = 40.996; ρ = 1000 kg/m^3
Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3736; ConvF(7.23, 7.23, 7.23) @ 2450 MHz; Calibrated: 2021-03-03
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), z = 1.0, 31.0
- Electronics: DAE4 Sn852; Calibrated: 2021-04-26
- Phantom: SAM5; Type: SAM; Serial: 1892
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Configuration/d=10mm, Pin=250mW/Area Scan (8x11x1): Measurement grid: dx=12mm, dy=12mm

Info: Interpolated medium parameters used for SAR evaluation.
Maximum value of SAR (measured) = 17.5 W/kg

Configuration/d=10mm, Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 110.3 V/m; Power Drift = -0.01 dB
Peak SAR (extrapolated) = 26.1 W/kg
SAR(1 g) = 12.7 W/kg; SAR(10 g) = 6.01 W/kg
Smallest distance from peaks to all points 3 dB below = 9 mm
Ratio of SAR at M2 to SAR at M1 = 49.1%

Info: Interpolated medium parameters used for SAR evaluation.
Maximum value of SAR (measured) = 21.0 W/kg



0 dB = 17.5 W/kg = 12.43 dBW/kg

System Validation

Per FCC KDB 865664 D02, SAR system verification is required to confirm measurement accuracy. The SAR systems (including SAR probes, system components and software versions) used for this device were validated against its performance specifications prior to the SAR measurements. Reference dipoles are used with the required tissue-equivalent media for system validation, according to the procedures outlined in FCC KDB 865664 D01 and IEEE 1528-2013.Since SAR probe calibrations are frequency dependent, each probe calibration point must be validated at a frequency within the valid frequency range of the probe calibration point, using the system that normally operates with the probe for routine SAR measurements and according to the required tissue-equivalent media.

a tabulated summary of the system validation status, measurement frequencies, SAR probes, calibrated signal type(s) and tissue dielectric parameters has been included.

FREQ. [Mhz]	DATE	PROBE SN	PROBE TYPE	PROBE CAL POINT		PERM (εr)	COND (σ)	CW VALIDATION			MOD.VALIDATION		
								SENSI-TIVITY	PROBE LINARITY	PROBE ISOTROPY	MOD. TYPE	DUTY. FACTORE	PAR
750	2021-3-30	3736	EX3DV4	750	Head	41.20	0.911	PASS	PASS	PASS	N/A	N/A	N/A
835	2021-3-30	3736	EX3DV4	850	Head	40.86	0.943	PASS	PASS	PASS	GMSK	PASS	N/A
900	2021-3-30	3736	EX3DV4	850	Head	40.62	0.968	PASS	PASS	PASS	NA	NA	N/A
1750	2021-3-30	3736	EX3DV4	1750	Head	38.47	1.363	PASS	PASS	PASS	NA	NA	N/A
1900	2021-3-30	3736	EX3DV4	1900	Head	38.20	1.451	PASS	PASS	PASS	GMSK	PASS	N/A
2000	2021-3-31	3736	EX3DV4	2000	Head	39.50	1.446	PASS	PASS	PASS	N/A	N/A	N/A
2300	2021-3-31	3736	EX3DV4	2300	Head	39.18	1.600	PASS	PASS	PASS	TDD	PASS	N/A
2450	2021-3-30	3736	EX3DV4	2450	Head	37.27	1.798	PASS	PASS	PASS	OFDM/TDD	PASS	PASS
2600	2021-3-31	3736	EX3DV4	2600	Head	38.80	1.874	PASS	PASS	PASS	TDD	PASS	N/A
3300	2021-4-2	3736	EX3DV4	3300	Head	37.80	2.660	PASS	PASS	PASS	TDD	PASS	N/A
3500	2021-4-2	3736	EX3DV4	3500	Head	37.42	2.831	PASS	PASS	PASS	TDD	PASS	N/A
3700	2021-4-2	3736	EX3DV4	3700	Head	37.07	3.006	PASS	PASS	PASS	TDD	PASS	N/A
3900	2021-4-2	3736	EX3DV4	3900	Head	36.72	3.185	PASS	PASS	PASS	TDD	PASS	N/A
4100	2021-4-2	3736	EX3DV4	4100	Head	36.40	3.375	PASS	PASS	PASS	TDD	PASS	N/A
4500	2021-4-2	3736	EX3DV4	4400	Head	35.70	3.770	PASS	PASS	PASS	TDD	PASS	N/A
4700	2021-4-2	3736	EX3DV4	4600	Head	35.33	3.973	PASS	PASS	PASS	TDD	PASS	N/A
4900	2021-4-2	3736	EX3DV4	4950	Head	34.98	4.177	PASS	PASS	PASS	TDD	PASS	N/A
5250	2021-4-2	3736	EX3DV4	5250	Head	34.53	4.531	PASS	PASS	PASS	OFDM/TDD	PASS	N/A
5600	2021-4-2	3736	EX3DV4	5600	Head	33.94	4.879	PASS	PASS	PASS	OFDM/TDD	PASS	N/A
5750	2021-4-2	3736	EX3DV4	5750	Head	33.68	5.033	PASS	PASS	PASS	OFDM/TDD	PASS	N/A

Table of SAR System validation summary:

NOTE: While the probes have been calibrated for both CW and modulated signals, all measurements were performed using communication systems calibrated for CW signals only. Modulations in the table above represent test configurations for which the measurement system has been validated per FCC KDB Publication 865664D01 for scenarios when CW probe calibrations are used with other signal types. SAR systems were validated for modulated signals with a periodic duty cycle, such as GMSK, or with a high peak to average ratio (>5dB), such as OFDM according to KDB 865664.