

Appendix A: SAR Plots of System Verification

Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/7/25

Date:

System Check_750Mhz

DUT: Dipole 750 MHz D750V3;


Communication System: UID 0, CW (0); Frequency: 750 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 750 \text{ MHz}$; $\sigma = 0.916 \text{ S/m}$; $\epsilon_r = 43.523$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $23.2 \text{ }^\circ\text{C}$; Liquid Temperature : $22.9 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(9.08, 9.77, 9.02) @ 750 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14 (7483)

Area Scan (7x15x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 2.87 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 59.32 V/m ; Power Drift = -0.02 dB
Peak SAR (extrapolated) = 3.46 W/kg
SAR(1 g) = 2.21 W/kg ; SAR(10 g) = 1.44 W/kg
Smallest distance from peaks to all points 3 dB below = 16 mm
Ratio of SAR at M2 to SAR at M1 = 60%
Maximum value of SAR (measured) = 2.90 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/7/26

Date:

System Check_835Mhz

DUT: Dipole 835 MHz D835V2;

Communication System: UID 0, CW (0); Frequency: 835 MHz; Duty Cycle: 1:1
Medium parameters used : $f = 835 \text{ MHz}$; $\sigma = 0.918 \text{ S/m}$; $\epsilon_r = 43.377$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $23.1 \text{ }^\circ\text{C}$; Liquid Temperature : $22.8 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(8.77, 9.44, 8.71) @ 835 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x14x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 3.02 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$

Reference Value = 60.62 V/m ; Power Drift = 0.01 dB


Peak SAR (extrapolated) = 3.88 W/kg

SAR(1 g) = 2.36 W/kg ; SAR(10 g) = 1.53 W/kg

Smallest distance from peaks to all points 3 dB below = 16 mm

Ratio of SAR at M2 to SAR at M1 = 61.1%

Maximum value of SAR (measured) = 3.28 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/7/29

Date:

System Check_835Mhz

DUT: Dipole 835 MHz D835V2;SN:4d061;


Communication System: UID 0, CW (0); Frequency: 835 MHz; Duty Cycle: 1:1
Medium parameters used : $f = 835 \text{ MHz}$; $\sigma = 0.915 \text{ S/m}$; $\epsilon_r = 43.373$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.6 \text{ }^\circ\text{C}$; Liquid Temperature : $22.3 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(8.77, 9.44, 8.71) @ 835 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x14x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 3.05 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 60.62 V/m ; Power Drift = 0.01 dB
Peak SAR (extrapolated) = 3.88 W/kg
SAR(1 g) = 2.33 W/kg ; SAR(10 g) = 1.51 W/kg
Smallest distance from peaks to all points 3 dB below = 14 mm
Ratio of SAR at M2 to SAR at M1 = 41.1%
Maximum value of SAR (measured) = 3.31 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/7/30

Date:

System Check_1800Mhz_

DUT: Dipole 1800 MHz D1800V2;SN:2d148;

Communication System: UID 0, CW (0); Frequency: 1800 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 1800 \text{ MHz}$; $\sigma = 1.418 \text{ S/m}$; $\epsilon_r = 40.463$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.5 \text{ }^\circ\text{C}$; Liquid Temperature : $22.2 \text{ }^\circ\text{C}$


DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(7.58, 8.16, 7.53) @ 1800 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- DMeasurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x8x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 11.2 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 107.1 V/m ; Power Drift = -0.01 dB
Peak SAR (extrapolated) = 18.8 W/kg

SAR(1 g) = 9.87 W/kg ; SAR(10 g) = 5.19 W/kg
Smallest distance from peaks to all points 3 dB below = 10.1 mm
Ratio of SAR at M2 to SAR at M1 = 52.6%
Maximum value of SAR (measured) = 15.6 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/1

Date:

System Check_1800Mhz

DUT: Dipole 1800 MHz D1800V2;SN:2d148;

Communication System: UID 0, CW (0); Frequency: 1800 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 1800 \text{ MHz}$; $\sigma = 1.421 \text{ S/m}$; $\epsilon_r = 40.466$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $23.2 \text{ }^\circ\text{C}$; Liquid Temperature : $22.9 \text{ }^\circ\text{C}$


DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(7.58, 8.16, 7.53) @ 1800 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x8x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 11.8 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 107.1 V/m ; Power Drift = -0.01 dB
Peak SAR (extrapolated) = 18.8 W/kg

SAR(1 g) = 9.92 W/kg ; SAR(10 g) = 5.21 W/kg
Smallest distance from peaks to all points 3 dB below = 10.1 mm
Ratio of SAR at M2 to SAR at M1 = 48.6%
Maximum value of SAR (measured) = 15.6 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/2

Date:

System Check_1900Mhz

DUT: Dipole 1900 MHz D1900V2;SN:5d092;

Communication System: UID 0, CW (0); Frequency: 1900 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 1900 \text{ MHz}$; $\sigma = 1.452 \text{ S/m}$; $\epsilon_r = 40.271$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $23.3 \text{ }^\circ\text{C}$; Liquid Temperature : $23.0 \text{ }^\circ\text{C}$


DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(7.33, 7.89, 7.28) @ 1900 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x8x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 11.8 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 110.7 V/m ; Power Drift = -0.03 dB
Peak SAR (extrapolated) = 18.9 W/kg

SAR(1 g) = 9.86 W/kg ; SAR(10 g) = 5.23 W/kg
Maximum value of SAR (measured) = 15.6 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/3

Date:

System Check_1900Mhz

DUT: Dipole 1900 MHz D1900V2;SN:5d092;

Communication System: UID 0, CW (0); Frequency: 1900 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 1900 \text{ MHz}$; $\sigma = 1.458 \text{ S/m}$; $\epsilon_r = 40.268$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.1 \text{ }^\circ\text{C}$; Liquid Temperature : $21.8 \text{ }^\circ\text{C}$


DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(7.33, 7.89, 7.28) @ 1900 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52,Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x8x1): Measurement grid: $dx=15\text{mm}$, $dy=15\text{mm}$
Maximum value of SAR (measured) = 10.4W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$
Reference Value = 110.7 V/m ; Power Drift = -0.04 dB
Peak SAR (extrapolated) = 18.9 W/kg

SAR(1 g) = 9.98 W/kg ; SAR(10 g) = 5.26 W/kg
Smallest distance from peaks to all points 3 dB below = 10.1 mm
Ratio of SAR at M2 to SAR at M1 = 45.6%
Maximum value of SAR (measured) = 16.6 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/4

Date:

System Check_2450Mhz

DUT: Dipole 2450 MHz D2450V2;


Communication System: UID 0, CW (0); Frequency: 2450 MHz; Duty Cycle: 1:1
Medium parameters used (interpolated): $f = 2450 \text{ MHz}$; $\sigma = 1.839 \text{ S/m}$; $\epsilon_r = 40.816$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.8 \text{ }^\circ\text{C}$; Liquid Temperature : $22.5 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(6.77, 7.28, 6.72) @ 2450 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM 1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x7x1): Measurement grid: $dx=12\text{mm}$, $dy=12\text{mm}$
Maximum value of SAR (measured) = 16.8 W/kg

Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=5\text{mm}$, $dy=5\text{mm}$, $dz=5\text{mm}$
Reference Value = 111.8 V/m ; Power Drift = 0.09 dB
Peak SAR (extrapolated) = 27.1 W/kg
SAR(1 g) = 5.32 W/kg ; SAR(10 g) = 2.51 W/kg
Smallest distance from peaks to all points 3 dB below = 12.1 mm
Ratio of SAR at M2 to SAR at M1 = 54.1%
Maximum value of SAR (measured) = 21.7 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/4

Date:

System Check_5250Mhz

DUT: Dipole D5GHzV2;


Communication System: UID 0, CW (0); Frequency: 5250 MHz; Duty Cycle: 1:1
Medium parameters used (interpolated): $f = 5250 \text{ MHz}$; $\sigma = 4.575 \text{ S/m}$; $\epsilon_r = 35.745$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.8 \text{ }^\circ\text{C}$; Liquid Temperature : $22.5 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(5.18, 5.57, 5.14) @ 5250 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x5x1): Measurement grid: $dx=10\text{mm}$, $dy=10\text{mm}$
Maximum value of SAR (measured) = 15.5 W/kg

Zoom Scan (7x7x12)/Cube 0: Measurement grid: $dx=4\text{mm}$, $dy=4\text{mm}$, $dz=2\text{mm}$
Reference Value = 68.87 V/m ; Power Drift = 0.08 dB
Peak SAR (extrapolated) = 30.8 W/kg
SAR(1 g) = 7.99 W/kg ; SAR(10 g) = 2.18 W/kg
Maximum value of SAR (measured) = 19.8 W/kg



Test Laboratory: TÜV Rheinland (Shenzhen) Co., Ltd.
2026/8/4

Date:

System Check_5800Mhz

DUT: Dipole D5GHzV2;

Communication System: UID 0, CW (0); Frequency: 5800 MHz; Duty Cycle: 1:1
Medium parameters used: $f = 5800 \text{ MHz}$; $\sigma = 5.189 \text{ S/m}$; $\epsilon_r = 34.259$; $\rho = 1000 \text{ kg/m}^3$
Ambient Temperature : $22.8 \text{ }^\circ\text{C}$; Liquid Temperature : $22.5 \text{ }^\circ\text{C}$

DASY Configuration:

- Probe: EX3DV4 - SN7506; ConvF(4.66, 5.02, 4.63) @ 5250 MHz; Calibrated: 2025/11/28
- Sensor-Surface: 1.4mm (Mechanical Surface Detection), $z = 1.0, 23.0$
- Electronics: DAE4 Sn1557; Calibrated: 2025/11/21
- Phantom: SAM1; Type: QD 000 P40 CB; Serial: 1961
- Measurement SW: DASY52, Version 52.10 (4); SEMCAD X Version 14.6.14(7483)

Area Scan (6x5x1): Measurement grid: $dx=10\text{mm}$, $dy=10\text{mm}$
Maximum value of SAR (measured) = 14.3 W/kg

Zoom Scan (7x7x12)/Cube 0: Measurement grid: $dx=4\text{mm}$, $dy=4\text{mm}$, $dz=2\text{mm}$
Reference Value = 66.73 V/m ; Power Drift = 0.07 dB
Peak SAR (extrapolated) = 34.2 W/kg
SAR(1 g) = 7.82 W/kg ; SAR(10 g) = 2.13 W/kg
Smallest distance from peaks to all points 3 dB below = 8.3 mm
Ratio of SAR at M2 to SAR at M1 = 46.3%
Maximum value of SAR (measured) = 20.2 W/kg

