

Declaration of conformity

We, TowerIQ, Inc.

(Name of manufacturer or his authorized representative)

13723 Riverport Drive C/O Potter Electric Signal Company

Saint Louis Missouri

United States

Declare under our own responsibility that the operation frequency of the product Name: In-building 2-Way Emergency Radio Communication Enhancement booster

Model: TQ-GuardianA2A

is authorized frequencies below:

700MHz: Downlink: 769MHz~775MHz, Uplink: 799MHz~805MHz

800MHz: Downlink: 851MHz~861MHz, Uplink: 806MHz~816MHz

We are acknowledging that the FCC rules are violated if the device operates on unauthorized frequencies.

In additionally, please be kindly noted that the warning label messages and the Class A disclosure will be also shown in online and point-of-sale marketing materials and on outside packaging of device.

Saint Louis Missouri 16/9/21

MICHAEL M'ISAR
REGULATORY ENGR.
