

Appendix C:Plots of SAR System Check

System Check_Head_750MHz

DUT: Dipole 750 MHz D750V2; Type: D750V2; Serial: 1214

Communication System: UID 0, CW (0); Communication System Band: D750 (750.0 MHz);

Frequency: 750 MHz;

Medium parameters used: $f = 750$ MHz; $\sigma = 0.928$ S/m; $\epsilon_r = 43.853$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(9.82, 10.29, 9.84); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (61x131x1): Interpolated grid: dx=1.500 mm, dy=1.500 mm

Maximum value of SAR (interpolated) = 2.32 W/kg


Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Reference Value = 50.912 V/m; Power Drift = 0.16 dB

Peak SAR (extrapolated) = 2.64 W/kg

SAR(1 g) = 2.26 W/kg; SAR(10 g) = 1.21 W/kg

Maximum value of SAR (measured) = 1.92 W/kg



System Check_Head_835MHz

DUT: Dipole 835 MHz D835V2; Type: D835V2; Serial: 4d164

Communication System: UID 0, CW (0); Communication System Band: D835 (835.0 MHz);

Frequency: 835 MHz;

Medium parameters used (interpolated): $f = 835 \text{ MHz}$; $\sigma = 0.931 \text{ S/m}$; $\epsilon_r = 42.426$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(9.61, 10.08, 9.63); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (61x121x1): Interpolated grid: $dx=1.500 \text{ mm}$, $dy=1.500 \text{ mm}$

Maximum value of SAR (interpolated) = 2.65 W/kg


Zoom Scan (5x5x7)/Cube 0: Measurement grid: $dx=8\text{mm}$, $dy=8\text{mm}$, $dz=5\text{mm}$

Reference Value = 55.897 V/m; Power Drift = -0.18 dB

Peak SAR (extrapolated) = 3.01 W/kg

SAR(1 g) = 2.54 W/kg; SAR(10 g) = 1.43 W/kg

Maximum value of SAR (measured) = 3.52 W/kg



System Check_Head_1750MHz

DUT: Dipole 1750 MHz D1750V2; Type: D1750V2; Serial: 1107


Communication System: UID 0, CW (0); Communication System Band: D1750 (1750.0 MHz);
Frequency: 1750 MHz;
Medium parameters used (interpolated): $f = 1750$ MHz; $\sigma = 1.328$ S/m; $\epsilon_r = 38.892$; $\rho = 1000$ kg/m³
Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(8.02, 8.41, 8.04); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (41x101x1): Interpolated grid: dx=1.000 mm, dy=1.000 mm
Maximum value of SAR (interpolated) = 5.92 W/kg

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 76.916 V/m; Power Drift = -0.08 dB
Peak SAR (extrapolated) = 6.89 W/kg
SAR(1 g) = 9.58 W/kg; SAR(10 g) = 3.89 W/kg
Maximum value of SAR (measured) = 10.9 W/kg



System Check_Head_2450MHz

DUT: Dipole 2450 MHz D2450V2; Type: D2450V2; Serial: 1018


Communication System: UID 0, CW; Communication System Band: D2450 (2450.0 MHz);
Frequency: 2450 MHz;
Medium parameters used: $f = 2450$ MHz; $\sigma = 1.867$ S/m; $\epsilon_r = 37.813$; $\rho = 1000$ kg/m³
Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(7.26, 7.62, 7.28); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (81x81x1): Interpolated grid: dx=1.200 mm, dy=1.200 mm
Maximum value of SAR (interpolated) = 16.7 W/kg

Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm, dy=5mm, dz=5mm
Reference Value = 81.234 V/m; Power Drift = -0.13 dB
Peak SAR (extrapolated) = 26.0 W/kg
SAR(1 g) = 13.84 W/kg; SAR(10 g) = 6.23 W/kg
Maximum value of SAR (measured) = 19.5 W/kg



System Check_Head_5250MHz

DUT: Dipole 5GHz; Type: D5GHzV2; Serial: D5GHzV2 - SN:1093

Communication System: UID 0, CW (0); Communication System Band: D5GHz (5000.0 - 6000.0 MHz); Frequency: 5250 MHz;

Medium parameters used: $f = 5250$ MHz; $\sigma = 4.816$ S/m; $\epsilon_r = 36.791$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(5.70, 5.98, 5.71); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (41x81x1): Interpolated grid: dx=1.200 mm, dy=1.200 mm

Maximum value of SAR (interpolated) = 12.5 W/kg


Zoom Scan (8x8x8)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=4mm

Reference Value = 20.662 V/m; Power Drift = -0.03 dB

Peak SAR (extrapolated) = 28.0 W/kg

SAR(1 g) = 8.99 W/kg; SAR(10 g) = 3.68 W/kg

Maximum value of SAR (measured) = 15.6 W/kg



System Check_Head_5750MHz

DUT: Dipole 5GHz; Type: D5GHzV2; Serial: D5GHzV2 - SN:1093

Communication System: UID 0, CW (0); Communication System Band: D5GHz (5000.0 - 6000.0 MHz); Frequency: 5750 MHz;

Medium parameters used: $f = 5750$ MHz; $\sigma = 5.097$ $\epsilon_r = 34.716 = 1000$ kg/m³

Phantom section: Flat Section

DASY Configuration:

- Probe: EX3DV4 - SN3959; ConvF(5.35, 5.61, 5.36); Calibrated: 9/10/2025;
- Sensor-Surface: 2mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn387; Calibrated: 13/10/2025
- Phantom: ELI v8.0; Type: QDOVA004AA; Serial: 2058
- DASY52 52.8.7(1137); SEMCAD X 14.6.10(7164)

Area Scan (41x81x1): Interpolated grid: dx=1.200 mm, dy=1.200 mm

Maximum value of SAR (interpolated) = 19.7 W/kg


Zoom Scan (8x8x8)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=4mm

Reference Value = 18.231 V/m; Power Drift = -0.05 dB

Peak SAR (extrapolated) = 36.2 W/kg

SAR(1 g) = 8.28 W/kg; SAR(10 g) = 2.42 W/kg

Maximum value of SAR (measured) = 19.1 W/kg



Shenzhen Anbotek Compliance Laboratory Limited

Any unauthorized modification, forgery, or falsification of this document constitutes a violation of law and is subject to legal penalties. If you have any questions, you may scan the QR code to download the report for verification or contact us via email.

Hotline: 400-003-0500 web: www.anbotek.com E-mail: service@anbotek.com