Date: 2026-03-19

System Check_Head_3500MHz

DUT: D3500V2 - SN1014

Communication System: CW; Frequency: 3500.000 MHz
Medium: HSL_600-7200_260319 Medium parameters used: f= 3500.000 MHz; σ= 2.77 S/m; ε_r = 40.1
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.94, 5.93, 5.67); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.33 W/kg; SAR (10g) = 1.26 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 3.35 W/kg; SAR (8g) = 1.44 W/kg; SAR (10g) = 1.28 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 76.4 %
TSL Correction: Positive only



Date: 2026-04-01

System Check_Head_3500MHz

DUT: D3500V2 - SN1014

Communication System: CW; Frequency: 3500.000 MHz
Medium: HSL_600-7200_260401 Medium parameters used: f= 3500.000 MHz; σ= 2.81 S/m; ε_r = 38.0
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.94, 5.93, 5.67); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.38 W/kg; SAR (10g) = 1.28 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 3.38 W/kg; SAR (8g) = 1.47 W/kg; SAR (10g) = 1.30 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 76.8 %
TSL Correction: Positive only



Date: 2026-01-03

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260103 Medium parameters used: f= 3700.000 MHz; σ= 2.89 S/m; ε_r = 40.5
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.34, 6.24, 6.28); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1776; Calibrated: 2025-02-12
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.27 W/kg; SAR (10g) = 1.23 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.00 dB
SAR (1g) = 3.40 W/kg; SAR (8g) = 1.41 W/kg; SAR (10g) = 1.25 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 73.9 %
TSL Correction: Positive only



Date: 2026-01-05

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260105 Medium parameters used: f= 3700.000 MHz; σ= 2.82 S/m; ε_r = 37.2
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.53, 6.24, 6.94); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.17 W/kg; SAR (10g) = 1.16 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.21 W/kg; SAR (8g) = 1.33 W/kg; SAR (10g) = 1.17 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 74.1 %
TSL Correction: Positive only



Date: 2026-01-22

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260122 Medium parameters used: f= 3700.000 MHz; σ= 2.93 S/m; ε_r = 37.6
Ambient Temperature: 23.4°C; Liquid Temperature: 22.4°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.34, 6.24, 6.28); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1776; Calibrated: 2025-02-12
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.37 W/kg; SAR (10g) = 1.24 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 3.42 W/kg; SAR (8g) = 1.42 W/kg; SAR (10g) = 1.25 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 74.4 %
TSL Correction: Positive only



Date: 2026-02-02

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260202 Medium parameters used: f= 3700.000 MHz; σ= 2.83 S/m; ε_r = 40.3
Ambient Temperature: 23.4°C; Liquid Temperature: 22.4°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.53, 6.24, 6.94); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.21 W/kg; SAR (10g) = 1.16 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.04 dB
SAR (1g) = 3.25 W/kg; SAR (8g) = 1.34 W/kg; SAR (10g) = 1.18 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 73.8 %
TSL Correction: Positive only



Date: 2026-02-03

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260203 Medium parameters used: f= 3700.000 MHz; σ= 2.86 S/m; ε_r = 39.1
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.53, 6.24, 6.94); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.26 W/kg; SAR (10g) = 1.19 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 3.30 W/kg; SAR (8g) = 1.36 W/kg; SAR (10g) = 1.21 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 73.6 %
TSL Correction: Positive only



Date: 2026-02-04

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260204 Medium parameters used: f= 3700.000 MHz; σ= 2.93 S/m; ε_r = 37.9
Ambient Temperature: 23.2°C; Liquid Temperature: 22.2°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.34, 6.24, 6.28); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn778; Calibrated: 2026-01-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.41 W/kg; SAR (10g) = 1.27 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.46 W/kg; SAR (8g) = 1.45 W/kg; SAR (10g) = 1.28 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 74.6 %
TSL Correction: Positive only



Date: 2026-02-07

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260207 Medium parameters used: f= 3700.000 MHz; σ= 2.90 S/m; ε_r = 39.3
Ambient Temperature: 23.7°C; Liquid Temperature: 22.7°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.34, 6.24, 6.28); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn778; Calibrated: 2026-01-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.39 W/kg; SAR (10g) = 1.24 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.04 dB
SAR (1g) = 3.44 W/kg; SAR (8g) = 1.43 W/kg; SAR (10g) = 1.26 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 74.7 %
TSL Correction: Positive only



Date: 2026-02-10

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260210 Medium parameters used: f= 3700.000 MHz; σ= 2.89 S/m; ε_r = 37.3
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(6.61, 6.72, 6.43); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.91 W/kg; SAR (10g) = 1.14 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.18 W/kg; SAR (8g) = 1.32 W/kg; SAR (10g) = 1.17 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 75.1 %
TSL Correction: Positive only



Date: 2026-02-11

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260211 Medium parameters used: f= 3700.000 MHz; σ= 2.92 S/m; ε_r = 37.6
Ambient Temperature: 23.1°C; Liquid Temperature: 22.1°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.53, 6.24, 6.94); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.35 W/kg; SAR (10g) = 1.25 W/kg;
TSL Correction: No correction

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.37 W/kg; SAR (8g) = 1.41 W/kg; SAR (10g) = 1.25 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 73.8 %
TSL Correction: No correction



Date: 2026-02-13

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260213 Medium parameters used: f= 3700.000 MHz; σ= 2.86 S/m; ε_r = 37.4
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(6.61, 6.72, 6.43); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=16.5dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.89 W/kg; SAR (10g) = 1.11 W/kg;
TSL Correction: Positive only

Pin=16.5dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.04 dB
SAR (1g) = 3.09 W/kg; SAR (8g) = 1.29 W/kg; SAR (10g) = 1.14 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 75.6 %
TSL Correction: Positive only



Date: 2026-02-18

System Check_Head 3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260218 Medium parameters used: f= 3700.000 MHz; σ= 2.93 S/m; ε_r = 37.7
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.53, 6.24, 6.94); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.37 W/kg; SAR (10g) = 1.23 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.40 W/kg; SAR (8g) = 1.42 W/kg; SAR (10g) = 1.25 W/kg
Smallest distance from peaks to all points 3 dB below = 8.1 mm
Ratio of SAR at M2 to SAR at M1 = 74.2 %
TSL Correction: Positive only



Date: 2026-02-24

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260224 Medium parameters used: f= 3700.000 MHz; σ= 2.97 S/m; ε_r = 37.7
Ambient Temperature: 23.4°C; Liquid Temperature: 22.4°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.54 W/kg; SAR (10g) = 1.32 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.62 W/kg; SAR (8g) = 1.53 W/kg; SAR (10g) = 1.35 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 75.8 %
TSL Correction: Positive only



Date: 2026-03-02

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260302 Medium parameters used: f= 3700.000 MHz; σ= 2.93 S/m; ε_r = 37.5
Ambient Temperature: 23.2°C; Liquid Temperature: 22.2°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.47 W/kg; SAR (10g) = 1.29 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.51 W/kg; SAR (8g) = 1.49 W/kg; SAR (10g) = 1.32 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 76.3 %
TSL Correction: Positive only



Date: 2026-03-09

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260309 Medium parameters used: f= 3700.000 MHz; σ= 3.00 S/m; ε_r = 38.0
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.34, 6.24, 6.28); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn778; Calibrated: 2026-01-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.52 W/kg; SAR (10g) = 1.31 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.54 W/kg; SAR (8g) = 1.49 W/kg; SAR (10g) = 1.31 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 74.6 %
TSL Correction: Positive only



Date: 2026-03-14

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260314 Medium parameters used: f= 3700.000 MHz; σ= 2.87 S/m; ε_r = 37.0
Ambient Temperature: 23.2°C; Liquid Temperature: 22.2°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.29 W/kg; SAR (10g) = 1.21 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.02 dB
SAR (1g) = 3.33 W/kg; SAR (8g) = 1.38 W/kg; SAR (10g) = 1.22 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 75.1 %
TSL Correction: Positive only



Date: 2026-03-19

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260319 Medium parameters used: f= 3700.000 MHz; σ= 2.95 S/m; ε_r = 39.8
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.46 W/kg; SAR (10g) = 1.27 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.02 dB
SAR (1g) = 3.48 W/kg; SAR (8g) = 1.46 W/kg; SAR (10g) = 1.29 W/kg
Smallest distance from peaks to all points 3 dB below = 8.3 mm
Ratio of SAR at M2 to SAR at M1 = 75.4 %
TSL Correction: Positive only



Date: 2026-04-01

System Check_Head_3700MHz

DUT: D3700V2 - SN1006

Communication System: CW; Frequency: 3700.000 MHz
Medium: HSL_600-7200_260401 Medium parameters used: f= 3700.000 MHz; σ= 2.98 S/m; ε_r = 37.8
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.39 W/kg; SAR (10g) = 1.24 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.45 W/kg; SAR (8g) = 1.45 W/kg; SAR (10g) = 1.28 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 75.7 %
TSL Correction: Positive only



Date: 2026-02-07

System Check_Head_3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260207 Medium parameters used: f= 3900.000 MHz; σ= 3.10 S/m; ε_r = 39.0
Ambient Temperature: 23.7°C; Liquid Temperature: 22.7°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.37, 6.27, 6.31); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn778; Calibrated: 2026-01-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.18 W/kg; SAR (10g) = 1.11 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.23 W/kg; SAR (8g) = 1.29 W/kg; SAR (10g) = 1.13 W/kg
Smallest distance from peaks to all points 3 dB below = 8.3 mm
Ratio of SAR at M2 to SAR at M1 = 72.9 %
TSL Correction: Positive only



Date: 2026-02-10

System Check_Head 3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260210 Medium parameters used: f= 3900.000 MHz; σ= 3.05 S/m; ε_r = 37.0
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(6.53, 6.64, 6.35); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.00 W/kg; SAR (10g) = 1.05 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.16 W/kg; SAR (8g) = 1.28 W/kg; SAR (10g) = 1.12 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 71.7 %
TSL Correction: Positive only



Date: 2026-02-11

System Check_Head 3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260211 Medium parameters used: f= 3900.000 MHz; σ= 3.09 S/m; ε_r = 37.4
Ambient Temperature: 23.1°C; Liquid Temperature: 22.1°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.45, 6.17, 6.86); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.14 W/kg; SAR (10g) = 1.12 W/kg;
TSL Correction: No correction

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.15 W/kg; SAR (8g) = 1.29 W/kg; SAR (10g) = 1.13 W/kg
Smallest distance from peaks to all points 3 dB below = 8.1 mm
Ratio of SAR at M2 to SAR at M1 = 72.9 %
TSL Correction: No correction



Date: 2026-02-13

System Check_Head 3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260213 Medium parameters used: f= 3900.000 MHz; σ= 3.02 S/m; ε_r = 37.2
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(6.53, 6.64, 6.35); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=16.5dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.60 W/kg; SAR (10g) = 0.961 W/kg;
TSL Correction: Positive only

Pin=16.5dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.02 dB
SAR (1g) = 2.83 W/kg; SAR (8g) = 1.14 W/kg; SAR (10g) = 1.00 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 74.6 %
TSL Correction: Positive only



Date: 2026-02-18

System Check_Head 3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260218 Medium parameters used: f= 3900.000 MHz; σ= 3.11 S/m; ε_r = 37.4
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(6.45, 6.17, 6.86); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.00 W/kg; SAR (10g) = 1.08 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.02 dB
SAR (1g) = 3.13 W/kg; SAR (8g) = 1.25 W/kg; SAR (10g) = 1.10 W/kg
Smallest distance from peaks to all points 3 dB below = 8.1 mm
Ratio of SAR at M2 to SAR at M1 = 72.6 %
TSL Correction: Positive only



Date: 2026-03-02

System Check_Head_3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260302 Medium parameters used: f= 3900.000 MHz; σ= 3.10 S/m; ε_r = 37.2
Ambient Temperature: 23.2°C; Liquid Temperature: 22.2°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.32 W/kg; SAR (10g) = 1.16 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = 0.03 dB
SAR (1g) = 3.37 W/kg; SAR (8g) = 1.37 W/kg; SAR (10g) = 1.20 W/kg
Smallest distance from peaks to all points 3 dB below = 8.6 mm
Ratio of SAR at M2 to SAR at M1 = 74.9 %
TSL Correction: Positive only



Date: 2026-03-09

System Check_Head_3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260309 Medium parameters used: f= 3900.000 MHz; σ= 3.18 S/m; ε_r = 37.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7814; ConvF(6.37, 6.27, 6.31); Calibrated: 2025-06-19
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn778; Calibrated: 2026-01-15
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2127; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.21 W/kg; SAR (10g) = 1.14 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.02 dB
SAR (1g) = 3.25 W/kg; SAR (8g) = 1.31 W/kg; SAR (10g) = 1.15 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 73.0 %
TSL Correction: Positive only



Date: 2026-04-01

System Check_Head_3900MHz

DUT: D3900V2 - SN1092

Communication System: CW; Frequency: 3900.000 MHz
Medium: HSL_600-7200_260401 Medium parameters used: f= 3900.000 MHz; σ= 3.11 S/m; ε_r = 36.9
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(5.9, 5.89, 5.63); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.09 W/kg; SAR (10g) = 1.08 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 29.1 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.14 W/kg; SAR (8g) = 1.27 W/kg; SAR (10g) = 1.11 W/kg
Smallest distance from peaks to all points 3 dB below = 8.0 mm
Ratio of SAR at M2 to SAR at M1 = 74.7 %
TSL Correction: Positive only



Date: 2026-03-10

System Check_Head 2450MHz

DUT: D2450V2 - SN736

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260310 Medium parameters used: f= 2450.000 MHz; σ= 1.83 S/m; ε_r = 42.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(7.06, 6.75, 7.51); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.66 W/kg; SAR (10g) = 1.23 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = 0.00 dB
SAR (1g) = 2.63 W/kg; SAR (8g) = 1.34 W/kg; SAR (10g) = 1.22 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 80.1 %
TSL Correction: Positive only



Date: 2026-03-12

System Check_Head_2450MHz

DUT: D2450V2 - SN736

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260312 Medium parameters used: f= 2450.000 MHz; σ= 1.81 S/m; ε_r = 39.4
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(7.16, 7.29, 6.97); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.40 W/kg; SAR (10g) = 1.12 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = 0.03 dB
SAR (1g) = 2.46 W/kg; SAR (8g) = 1.28 W/kg; SAR (10g) = 1.16 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 82.5 %
TSL Correction: Positive only



Date: 2026-03-15

System Check_Head_2450MHz

DUT: D2450V2 - SN929

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260315 Medium parameters used: f= 2450.000 MHz; σ= 1.84 S/m; ε_r = 39.6
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(7.16, 7.29, 6.97); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.53 W/kg; SAR (10g) = 1.18 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = -0.01 dB
SAR (1g) = 2.54 W/kg; SAR (8g) = 1.31 W/kg; SAR (10g) = 1.19 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 81.8 %
TSL Correction: Positive only



Date: 2026-03-18

System Check_Head_2450MHz

DUT: D2450V2 - SN929

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260318 Medium parameters used: f= 2450.000 MHz; σ= 1.77 S/m; ε_r = 39.5
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(7.16, 7.29, 6.97); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.34 W/kg; SAR (10g) = 1.13 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = -0.02 dB
SAR (1g) = 2.45 W/kg; SAR (8g) = 1.27 W/kg; SAR (10g) = 1.15 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 81.9 %
TSL Correction: Positive only



Date: 2026-03-25

System Check_Head_2450MHz

DUT: D2450V2 - SN736

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260325 Medium parameters used: f= 2450.000 MHz; σ= 1.86 S/m; ε_r = 39.9
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(7.16, 7.29, 6.97); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.56 W/kg; SAR (10g) = 1.20 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = 0.01 dB
SAR (1g) = 2.62 W/kg; SAR (8g) = 1.36 W/kg; SAR (10g) = 1.23 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 82.5 %
TSL Correction: Positive only



Date: 2026-03-27

System Check_Head_2450MHz

DUT: D2450V2 - SN736

Communication System: CW; Frequency: 2450.000 MHz
Medium: HSL_600-7200_260327 Medium parameters used: f= 2450.000 MHz; σ= 1.82 S/m; ε_r = 39.0
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(7.16, 7.29, 6.97); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 2.44 W/kg; SAR (10g) = 1.17 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 31.2 mm): Measurement Grid: 5.0 mm x 5.0 mm x 1.5 mm
Power Drift = 0.00 dB
SAR (1g) = 2.53 W/kg; SAR (8g) = 1.32 W/kg; SAR (10g) = 1.19 W/kg
Smallest distance from peaks to all points 3 dB below = 9.0 mm
Ratio of SAR at M2 to SAR at M1 = 82.1 %
TSL Correction: Positive only



Date: 2026-01-19

System Check_Head_5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260119 Medium parameters used: f= 5250.000 MHz; σ= 4.52 S/m; ε_r = 34.4
Ambient Temperature: 23.6°C; Liquid Temperature: 22.6°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(4.98, 4.97, 4.75); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.50 W/kg; SAR (10g) = 0.990 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.02 dB
SAR (1g) = 3.72 W/kg; SAR (8g) = 1.24 W/kg; SAR (10g) = 1.07 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 62.7 %
TSL Correction: Positive only



Date: 2026-03-05

System Check_Head_5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260305 Medium parameters used: f= 5250.000 MHz; σ= 4.53 S/m; ε_r = 34.6
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.52, 5.62, 5.37); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=16.9dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.10 W/kg; SAR (10g) = 0.955 W/kg;
TSL Correction: Positive only

Pin=16.9dBm/Zoom Scan (28.0 mm x 28.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.08 dB
SAR (1g) = 3.59 W/kg; SAR (8g) = 1.21 W/kg; SAR (10g) = 1.05 W/kg
Smallest distance from peaks to all points 3 dB below = 7.2 mm
Ratio of SAR at M2 to SAR at M1 = 62.7 %
TSL Correction: Positive only



Date: 2026-03-11

System Check_Head 5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260311 Medium parameters used: f= 5250.000 MHz; σ= 4.50 S/m; ε_r = 34.8
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(5.46, 5.22, 5.81); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.43 W/kg; SAR (10g) = 0.990 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.03 dB
SAR (1g) = 3.71 W/kg; SAR (8g) = 1.24 W/kg; SAR (10g) = 1.06 W/kg
Smallest distance from peaks to all points 3 dB below = 7.2 mm
Ratio of SAR at M2 to SAR at M1 = 62.4 %
TSL Correction: Positive only



Date: 2026-03-15

System Check_Head_5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260315 Medium parameters used: f= 5250.000 MHz; σ= 4.56 S/m; ε_r = 34.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.52, 5.62, 5.37); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.11 W/kg; SAR (10g) = 0.931 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.64 W/kg; SAR (8g) = 1.23 W/kg; SAR (10g) = 1.06 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 62.9 %
TSL Correction: Positive only



Date: 2026-03-17

System Check_Head_5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260317 Medium parameters used: f= 5250.000 MHz; σ= 4.51 S/m; ε_r = 34.6
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.52, 5.62, 5.37); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=16.9dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.05 W/kg; SAR (10g) = 0.977 W/kg;
TSL Correction: Positive only

Pin=16.9dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.06 dB
SAR (1g) = 3.62 W/kg; SAR (8g) = 1.21 W/kg; SAR (10g) = 1.03 W/kg
Smallest distance from peaks to all points 3 dB below = 7.2 mm
Ratio of SAR at M2 to SAR at M1 = 63.1 %
TSL Correction: Positive only



Date: 2026-03-23

System Check_Head_5250MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5250.000 MHz
Medium: HSL_600-7200_260323 Medium parameters used: f= 5250.000 MHz; σ= 4.54 S/m; ε_r = 34.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.52, 5.62, 5.37); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=16.8dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.06 W/kg; SAR (10g) = 0.940 W/kg;
TSL Correction: Positive only

Pin=16.8dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.04 dB
SAR (1g) = 3.55 W/kg; SAR (8g) = 1.19 W/kg; SAR (10g) = 1.03 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 62.3 %
TSL Correction: Positive only



Date: 2026-01-19

System Check_Head_5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260119 Medium parameters used: f= 5600.000 MHz; σ= 4.90 S/m; ε_r = 33.8
Ambient Temperature: 23.6°C; Liquid Temperature: 22.6°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(4.61, 4.6, 4.4); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.81 W/kg; SAR (10g) = 1.06 W/kg;
TSL Correction: Positive only

Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 4.07 W/kg; SAR (8g) = 1.34 W/kg; SAR (10g) = 1.15 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 59.6 %
TSL Correction: Positive only



Date: 2026-03-05

System Check_Head_5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260305 Medium parameters used: f= 5600.000 MHz; σ= 4.87 S/m; ε_r = 34.2
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.15, 5.24, 5.01); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.26 W/kg; SAR (10g) = 0.993 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (28.0 mm x 28.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.05 dB
SAR (1g) = 3.84 W/kg; SAR (8g) = 1.28 W/kg; SAR (10g) = 1.11 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 59.1 %
TSL Correction: Positive only



Date: 2026-03-11

System Check_Head 5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260311 Medium parameters used: f= 5600.000 MHz; σ= 4.87 S/m; ε_r = 34.1
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(5.03, 4.81, 5.35); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.66 W/kg; SAR (10g) = 1.05 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.00 dB
SAR (1g) = 4.05 W/kg; SAR (8g) = 1.33 W/kg; SAR (10g) = 1.15 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 58.9 %
TSL Correction: Positive only



Date: 2026-03-15

System Check_Head_5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260315 Medium parameters used: f= 5600.000 MHz; σ= 4.93 S/m; ε_r = 34.0
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.15, 5.24, 5.01); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.22 W/kg; SAR (10g) = 0.954 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.02 dB
SAR (1g) = 3.79 W/kg; SAR (8g) = 1.29 W/kg; SAR (10g) = 1.11 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 59.3 %
TSL Correction: Positive only



Date: 2026-03-17

System Check_Head_5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260317 Medium parameters used: f= 5600.000 MHz; σ= 4.83 S/m; ε_r = 33.8
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.15, 5.24, 5.01); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=16.9dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.16 W/kg; SAR (10g) = 1.00 W/kg;
TSL Correction: Positive only

Pin=16.9dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 3.80 W/kg; SAR (8g) = 1.25 W/kg; SAR (10g) = 1.07 W/kg
Smallest distance from peaks to all points 3 dB below = 7.2 mm
Ratio of SAR at M2 to SAR at M1 = 59.2 %
TSL Correction: Positive only



Date: 2026-03-23

System Check_Head_5600MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5600.000 MHz
Medium: HSL_600-7200_260323 Medium parameters used: f= 5600.000 MHz; σ= 4.88 S/m; ε_r = 33.9
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.15, 5.24, 5.01); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.39 W/kg; SAR (10g) = 1.03 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.08 dB
SAR (1g) = 3.94 W/kg; SAR (8g) = 1.31 W/kg; SAR (10g) = 1.13 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 59.4 %
TSL Correction: Positive only



Date: 2026-01-19

System Check_Head_5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260119 Medium parameters used: f= 5800.000 MHz; σ= 5.12 S/m; ε_r = 33.5
Ambient Temperature: 23.6°C; Liquid Temperature: 22.6°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7785; ConvF(4.55, 4.54, 4.34); Calibrated: 2025-11-26
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1707; Calibrated: 2025-11-20
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2126; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.59 W/kg; SAR (10g) = 1.01 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.02 dB
SAR (1g) = 3.87 W/kg; SAR (8g) = 1.28 W/kg; SAR (10g) = 1.10 W/kg
Smallest distance from peaks to all points 3 dB below = 7.6 mm
Ratio of SAR at M2 to SAR at M1 = 57.4 %
TSL Correction: Positive only



Date: 2026-03-05

System Check_Head_5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260305 Medium parameters used: f= 5800.000 MHz; σ= 5.11 S/m; ε_r = 33.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.03, 5.12, 4.9); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.19 W/kg; SAR (10g) = 0.967 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (28.0 mm x 28.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.09 dB
SAR (1g) = 3.76 W/kg; SAR (8g) = 1.25 W/kg; SAR (10g) = 1.08 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 57.7 %
TSL Correction: Positive only



Date: 2026-03-11

System Check_Head 5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260311 Medium parameters used: f= 5800.000 MHz; σ= 5.12 S/m; ε_r = 33.8
Ambient Temperature: 23.8°C; Liquid Temperature: 22.8°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(4.92, 4.71, 5.23); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.59 W/kg; SAR (10g) = 1.02 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.05 dB
SAR (1g) = 4.01 W/kg; SAR (8g) = 1.31 W/kg; SAR (10g) = 1.13 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 57.3 %
TSL Correction: Positive only



Date: 2026-03-15

System Check_Head_5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260315 Medium parameters used: f= 5800.000 MHz; σ= 5.18 S/m; ε_r = 33.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.03, 5.12, 4.9); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.09 W/kg; SAR (10g) = 0.916 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 3.70 W/kg; SAR (8g) = 1.25 W/kg; SAR (10g) = 1.08 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 57.2 %
TSL Correction: Positive only



Date: 2026-03-17

System Check_Head_5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260317 Medium parameters used: f= 5800.000 MHz; σ= 5.17 S/m; ε_r = 33.4
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.03, 5.12, 4.9); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.09 W/kg; SAR (10g) = 0.975 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.03 dB
SAR (1g) = 3.72 W/kg; SAR (8g) = 1.23 W/kg; SAR (10g) = 1.05 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 56.9 %
TSL Correction: Positive only



Date: 2026-03-23

System Check_Head_5800MHz

DUT: D5GHzV2 - SN1006

Communication System: CW; Frequency: 5800.000 MHz
Medium: HSL_600-7200_260323 Medium parameters used: f= 5800.000 MHz; σ= 5.18 S/m; ε_r = 33.3
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.03, 5.12, 4.9); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=17.0dBm/Area Scan (40.0 mm x 80.0 mm): Measurement Grid: 10.0 mm x 10.0 mm
SAR (1g) = 3.49 W/kg; SAR (10g) = 1.05 W/kg;
TSL Correction: Positive only

Pin=17.0dBm/Zoom Scan (24.0 mm x 24.0 mm x 22.9 mm): Measurement Grid: 4.0 mm x 4.0 mm x 1.4 mm
Power Drift = -0.03 dB
SAR (1g) = 4.13 W/kg; SAR (8g) = 1.37 W/kg; SAR (10g) = 1.18 W/kg
Smallest distance from peaks to all points 3 dB below = 7.4 mm
Ratio of SAR at M2 to SAR at M1 = 59.0 %
TSL Correction: Positive only



Date: 2026-03-27

System Check_Head 6500MHz

DUT: D6.5GHzV2 - SN1083

Communication System: CW; Frequency: 6500.000 MHz
Medium: HSL_600-7200_260327 Medium parameters used: f= 6500.000 MHz; σ= 6.10 S/m; ε_r = 32.4
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(5.3, 5.07, 5.63); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=20.0dBm/Area Scan (51.0 mm x 85.0 mm): Measurement Grid: 8.5 mm x 8.5 mm
SAR (1g) = 28.3 W/kg; SAR (10g) = 5.49 W/kg;
TSL Correction: Positive only

Pin=20.0dBm/Zoom Scan (23.8 mm x 23.8 mm x 22.9 mm): Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm
Power Drift = 0.00 dB
SAR (1g) = 32.1 W/kg; SAR (8g) = 7.22 W/kg; SAR (10g) = 5.93 W/kg
Smallest distance from peaks to all points 3 dB below = 4.8 mm
Ratio of SAR at M2 to SAR at M1 = 51.9 %
psAPD (1.0cm2, sq) = 321 [W/m2]; psAPD (4.0cm2, sq) = 144 [W/m2]
TSL Correction: Positive only



Date: 2026-03-28

System Check_Head 6500MHz

DUT: D6.5GHzV2 - SN1083

Communication System: CW; Frequency: 6500.000 MHz
Medium: HSL_600-7200_260328 Medium parameters used: f= 6500.000 MHz; σ= 6.06 S/m; ε_r = 32.4
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(5.3, 5.07, 5.63); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=20.0dBm/Area Scan (51.0 mm x 85.0 mm): Measurement Grid: 8.5 mm x 8.5 mm
SAR (1g) = 28.0 W/kg; SAR (10g) = 5.44 W/kg;
TSL Correction: Positive only

Pin=20.0dBm/Zoom Scan (23.8 mm x 23.8 mm x 22.9 mm): Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm
Power Drift = 0.01 dB
SAR (1g) = 31.8 W/kg; SAR (8g) = 7.16 W/kg; SAR (10g) = 5.88 W/kg
Smallest distance from peaks to all points 3 dB below = 4.8 mm
Ratio of SAR at M2 to SAR at M1 = 51.8 %
psAPD (1.0cm2, sq) = 318 [W/m2]; psAPD (4.0cm2, sq) = 143 [W/m2]
TSL Correction: Positive only



Date: 2026-03-28

System Check_Head_6500MHz

DUT: D6.5GHzV2 - SN1083

Communication System: CW; Frequency: 6500.000 MHz
Medium: HSL_600-7200_260328 Medium parameters used: f= 6500.000 MHz; σ= 6.11 S/m; ε_r = 32.7
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(5.51, 5.61, 5.37); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2144_Gap; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0--

Pin=20.0dBm/Area Scan (51.0 mm x 85.0 mm): Measurement Grid: 8.5 mm x 8.5 mm
SAR (1g) = 24.6 W/kg; SAR (10g) = 5.17 W/kg;
TSL Correction: Positive only

Pin=20.0dBm/Zoom Scan (23.8 mm x 23.8 mm x 22.9 mm): Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm
Power Drift = 0.06 dB
SAR (1g) = 30.5 W/kg; SAR (8g) = 6.83 W/kg; SAR (10g) = 5.62 W/kg
Smallest distance from peaks to all points 3 dB below = 4.8 mm
Ratio of SAR at M2 to SAR at M1 = 50.6 %
psAPD (1.0cm2, sq) = 305 [W/m2]; psAPD (4.0cm2, sq) = 137 [W/m2]
TSL Correction: Positive only



Date: 2026-04-15

System Check_Head_6500MHz

DUT: D6.5GHzV2 - SN1083

Communication System: CW; Frequency: 6500.000 MHz
Medium: HSL_600-7200_260415 Medium parameters used: f= 6500.000 MHz; σ= 6.19 S/m; ε_r = 34.1
Ambient Temperature: 23.5°C; Liquid Temperature: 22.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN7625; ConvF(5.3, 5.07, 5.63); Calibrated: 2025-12-09
- Sensor-Surface: 1.4 mm
- Electronics: DAE4ip Sn1800; Calibrated: 2025-06-16
- Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2145; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=20.0dBm/Area Scan (51.0 mm x 85.0 mm): Measurement Grid: 8.5 mm x 8.5 mm
SAR (1g) = 26.4 W/kg; SAR (10g) = 5.34 W/kg;
TSL Correction: Positive only

Pin=20.0dBm/Zoom Scan (23.8 mm x 23.8 mm x 22.9 mm): Measurement Grid: 3.4 mm x 3.4 mm x 1.4 mm
Power Drift = -0.01 dB
SAR (1g) = 31.8 W/kg; SAR (8g) = 7.18 W/kg; SAR (10g) = 5.91 W/kg
Smallest distance from peaks to all points 3 dB below = 4.8 mm
Ratio of SAR at M2 to SAR at M1 = 52.2 %
psAPD (1.0cm2, sq) = 318 [W/m2]; psAPD (4.0cm2, sq) = 144 [W/m2]
TSL Correction: Positive only



Date: 2026-04-10

System Check_13MHz

DUT: CLA-13 - SN1011

Communication System: CW; Frequency: 13.000 MHz
Medium: HSL_13_260410 Medium parameters used: f= 13.000 MHz; σ= 0.719 S/m; ε_r = 53.5
Ambient Temperature: 23.5°C; Liquid Temperature: 23.5°C

DASY8 Configuration:
- Probe: EX3DV4 - SN3931; ConvF(17.55, 17.18, 17.51); Calibrated: 2025-10-23
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1697; Calibrated: 2025-11-19
- Phantom: ELI V8.0 (20deg probe tilt); Serial: 2204; Section: Flat
- Measurement Software: 16.4.0.5005
- UID: CW, 0

Pin=30.0dBm/Area Scan (40.0 mm x 90.0 mm): Measurement Grid: 10.0 mm x 15.0 mm
SAR (1g) = 0.544 W/kg; SAR (10g) = 0.432 W/kg;
TSL Correction: Positive only

Pin=30.0dBm/Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 6.0 mm x 6.0 mm x 1.5 mm
Power Drift = -0.01 dB
SAR (1g) = 0.499 W/kg; SAR (8g) = 0.309 W/kg; SAR (10g) = 0.309 W/kg
Smallest distance from peaks to all points 3 dB below = 14.4 mm
Ratio of SAR at M2 to SAR at M1 = 72.2 %
TSL Correction: Positive only



Measurement Report for Device

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	Software Version	DUT Type
Device,	70.0 x 50.0 x 8.0	3.2.0.1840	5G Verification Source

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Frequency [MHz]	Conversion Factor
5G	FRONT, 10.00	10000.0	1.0

Hardware Setup

Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave - 1044	Air -	EUmmWV3 - SN9424_F1-55GHz, 2026-03-12	DAE4 Sn656, 2026-01-15

Scans Setup

Scan Type	5G Scan
Grid Extents [mm]	120.0 x 120.0
Grid Steps [lambda]	0.25 x 0.25
Sensor Surface [mm]	10.0

Measurement Results

Date	2026-04-01
Avg. Area [cm^2]	4.00
psPDn+ [W/m^2]	55.2
psPDtot+ [W/m^2]	55.4
H_{max} [A/m]	0.410
E_{max} [V/m]	154
$max_{(Stot)}$ [W/m^2]	62.6
Power Drift [dB]	-0.05
IPDn	95.6



Measurement Report for Device

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	Software Version	DUT Type
Device,	70.0 x 50.0 x 8.0	3.2.0.1840	5G Verification Source

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Frequency [MHz]	Conversion Factor
5G	FRONT, 10.00	10000.0	1.0

Hardware Setup

Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave - 1044	Air -	EUmmWV3 - SN9424_F1-55GHz, 2026-03-12	DAE4 Sn656, 2026-01-15

Scans Setup

Scan Type	5G Scan
Grid Extents [mm]	120.0 x 120.0
Grid Steps [lambda]	0.25 x 0.25
Sensor Surface [mm]	10.0

Measurement Results

Date	2026-04-08
Avg. Area [cm^2]	4.00
psPDn+ [W/m^2]	55.4
psPDtot+ [W/m^2]	55.6
H_{max} [A/m]	0.407
E_{max} [V/m]	157
$max_{(Stot)}$ [W/m^2]	62.9
Power Drift [dB]	0.07
IPDn	100