

Appendix A

System Validation Plots

Table of Contents

1. D2450V2-SN: 904 Validation Plot 3

1. D2450V2-SN: 904 Validation Plot

Date: 18.05.2026

Test Laboratory: Guangdong Dongdian Testing Service Co., Ltd.

2450

DUT: Dipole 2450 MHz D2450V2; Type: D2450V2; Serial: D2450V2 - SN:904

Communication System: UID 0, CW (0); Communication System Band: D2450 (2450.0 MHz); Frequency: 2450 MHz; Communication System PAR: 0 dB; PMF: 1
Medium parameters used: $f = 2450$ MHz; $\sigma = 1.733$ S/m; $\epsilon_r = 39.805$; $\rho = 1000$ kg/m³
Phantom section: Flat Section
Measurement Standard: DASYS (IEEE/IEC/ANSI C63.19-2011)

DASY Configuration:

- Probe: EX3DV4 - SN3906; ConvF(7.9, 7.9, 7.9) @ 2450 MHz; Calibrated: 28.05.2025
- Sensor-Surface: 3mm (Mechanical Surface Detection), Sensor-Surface: 4mm (Mechanical Surface Detection), $z = 1.0, 31.0$
- Electronics: DAE4 Sn1366; Calibrated: 28.05.2025
- Phantom: ELI v5.0; Type: QDOVA002AA; Serial: TP:1197
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Configuration/tilt/Area Scan (6x11x1): Measurement grid: $dx=10$ mm, $dy=10$ mm
Maximum value of SAR (measured) = 6.28 W/kg

Configuration/tilt/Zoom Scan (7x7x7)/Cube 0: Measurement grid: $dx=5$ mm, $dy=5$ mm, $dz=5$ mm
Reference Value = 54.60 V/m; Power Drift = 0.11 dB
Peak SAR (extrapolated) = 10.3 W/kg
SAR(1 g) = 5.26 W/kg; SAR(10 g) = 2.55 W/kg
Smallest distance from peaks to all points 3 dB below = 10 mm
Ratio of SAR at M2 to SAR at M1 = 52.9%
Maximum value of SAR (measured) = 5.99 W/kg

