

File : c:/idx3/SYSTEM/SARMEAS3/data/Normal/0112926_ZOOM.VLT
Start : 29-Nov-101 05:57:03 pm End : 29-Nov-101 06:12:55 pm

Radio Type : Validation
Model Number :
Serial Number : C
Frequency : 835 MHz
Peak Trans. Pwr : 0.250 W
Start Trans. Pwr: 0.250 W
Antenna Type : Dipole
Antenna Posn. : Internal
Phantom Type : Flat
Phantom Posn. : E Field
Scan Type : ZOOM/SAR
Probe Name : PCTEST
Field Type : E Field
Orientation : 0 Degrees

Mixture Type = Brain
Mixture Dielectric Constant = 41.500
Mixture Conductivity = 0.900

Comment :
835 MHz Brain Validation
SN: C

Robot : PCTEST

Probe Offset = 0.20 cm
Sensor Factor = 0.0108
Conversion Factor = 0.325

PCTEST Amplifier Channel Settings : 0.239 0.278 0.294

Max Location : X = 1.500, Y = -2.000, Z = 0.000 (cm) Value = 101.253

Measured Values (volts) =
9.975E-002 7.499E-002 6.126E-002 5.159E-002 4.321E-002 3.764E-002
3.264E-002 2.797E-002 2.391E-002 2.107E-002 1.924E-002 1.651E-002
1.477E-002 1.300E-002 1.135E-002 9.757E-003 8.477E-003 7.363E-003
7.077E-003 6.347E-003 5.514E-003


Calc. Voltage @ Surface (Vs) = 0.1210

Voltage @ 1.00 cm (Vt) = 0.0498

Ave. Voltage (Vs+Vt)/2 = 0.0854

Ave. SAR over 1 g (mW/g) = 2.5699

SAR Scan
File : 01112926_ZOOM
Start : 29-Nov-101 05:57:03 pm End : 29-Nov-101 06:12:55 pm
Validation//C;835MHz;W;Dipole/Internal;
Flat/E Field;ZOOM/SAR;PCTEST/E Field/0 DegreesBrain/41.500/0.900




File : 02012926_ZOOM

Start : 29-Nov-101 05:57:03 pm End : 29-Nov-102 06:12:55 pm

Validation//C;835MHz;W;Dipole/Internal;

Flat/E Field;ZOOM/SAR;PCTEST/E Field/0 DegreesBrain/41.500/0.900



File : 02012926_ZOOM

Start : 29-Nov-101 05:57:03 pm End : 29-Nov-102 06:12:55 pm

Validation//C;835MHz;W;Dipole/Internal;

Flat/E Field;ZOOM/SAR;PCTEST/E Field/0 DegreesBrain/41.500/0.900

