



Cellular 500W Module Pit Installation Guide

DRAFT

Cellular 500W Module Pit Installation Guide

October 13, 2021

815-0617-00 REV 000

Copyright © 2021 Itron, Inc. All rights reserved.

Confidentiality Notice

Confidential Information of Itron®, Inc., provided under nondisclosure obligations. The information contained herein is proprietary and confidential and is being provided subject to the condition that (i) it be held in confidence except to the extent required otherwise by law and (ii) it will be used only for the purposes described herein. Any third party that is given access to this information shall be similarly bound in writing.

Trademark Notice

Itron is a registered trademark of Itron, Inc.

All other product names and logos in this documentation are used for identification purposes only and may be trademarks or registered trademarks of their respective companies.

For more information about Itron or Itron products, go to www.itron.com.

If you have questions or comments about a software or hardware product, contact Itron Technical Support Services.

Contact

Email: support@itron.com

Itron Access: <https://access.itron.com>

Telephone Itron Technical Support North America: 1-877-487-6602

For technical support contact information by region, go to www.itron.com and select your country and language.

For suggestions, questions, or other feedback concerning Itron product documentation, contact us at: ItronDocumentation@itron.com

DRAFT

Contents

New in This Document	5
1 Introduction	6
Related Documents	7
Security	8
Transmission Modes	8
Mobile Mode	8
Network Mode	9
Operating Modes	9
Battery Life	10
Low Battery	10
Events and Alarms	10
Mobile Mode	10
Network Mode	11
Firmware Functionality	11
2 Initialization, Connection, and Programming	13
Start Up	13
Programming	13
Encoder-type Meter Register Connections	14
Pulser-type Register Connections	16
Cable Extension	16
Operation Verification	16
3 Cellular 500W Pit Module Installation	18
Mounting Accessories	19
Pit Modules with Integral Connectors	19
Through-lid Installation	19
Required Tools and Hardware	20
Rod Mount Installation	22
Required Tools and Hardware	22
Wall Mount Installation	26

DRAFT

	To mount the module to a pit wall	26
4	Accessory Installation	29
	Inline Connector Installation	29
	Remote Disconnect Valve Installation	30
	Itron Cable Armor Installation	31
	Installing the Cable Armor	31
	Leak Sensor Installation	33
5	Completing Gel-cap Connections Using the Itron Splice Kit	34
	Required materials	34
	To Complete Gel-Cap Connections	34
A	Troubleshooting	37
B	Important Safety and Compliance Information	38
	USA, FCC Part 15 Spectrum Compliance	38
	USA, FCC Class B-Part 15	38
	Modifications and Repairs	38
	Modifications and Repairs	39
	Canada, ISED Spectrum Compliance	39
	RF Exposure (FCC/ISED)	39
	Lithium Battery Safety	39
	Electromagnetic Compatibility	40
	Electrostatic Discharge	40
	Do Not Drop	40

DRAFT

New in This Document

Revision	Date	Description
REV 000	October 2021	First date of publication.

DRAFT

1

Introduction


The Cellular 500W Pit Module (ECW-1700-001) is a cellular radio frequency transmitting module that attaches to water registers or meters to collect consumption usage, event, and alarm data. The Cellular 500W pit module transmits in Mobile Mode, offering Mobile Handheld, Hard-to-Read Mobile, High-Power Mobile, or Network Mode.

Note: The Cellular 500W Pit Module works with cable lengths up to 300 feet. Use an Itron-approved extension cable.

The images below illustrate the different Cellular 500W Pit Module variants. This document notes differences between the two as needed.



Important! The three port variant is not currently available for sale.



Cellular 500W Pit Modules ship from the factory in Factory Mode, which prevents unwanted radio transmissions during transit. After installation and programming, the pit modules acquire and transmit meter or register data in accordance with the selected pit module parameter settings. Cellular 500W Pit Modules support protocols for a variety of meter manufacturer's registers. Refer to the [Water Meter and Telemetry Module Compatibility Matrix](#) for the list of supported meters and registers.

Cellular 500W Pit Modules feature the following capabilities:

- **Datalogging.** The Cellular 500W Pit Module provides 3,840 buckets of interval data configurable from 1 minute to 1 hour (for example, 160 days of hourly data or 40 days of 15 minute data).

DRAFT

Note: Interval data functionality is dependent on the module's firmware version. For more information, see [Firmware Functionality on page 11](#).

- In Mobile Mode, the module provides 960 buckets of hourly interval data and can be set to transmit in Mobile and Handheld Mode, Mobile High Power Mode, or Hard to Read Mode.
 - **Mobile High Power Mode.** The module transmits a high-powered RF message every 60 seconds. In Mobile High Power Mode, the expected battery life is 20 years.
 - **Mobile and Handheld Mode.** The module transmits a medium-powered RF message every 15 seconds. In Mobile and Handheld Mode, the expected battery life is 20 years.
 - **(Optional) Hard to Read Mode.** The module transmits a high-powered RF message every 30 seconds. In Hard to Read Mode, the expected battery life decreases to 15 years in this mode. The hard to read mobile mode should only be used for exceptionally hard-to-read applications (such as meters installed in sub-basements).
- **Leak Detection and Reverse Flow Detection.** Cellular 500W Pit Modules feature robust algorithms that provide leak and reverse flow detection.
- **(Optional) Leak Sensor Installation**
 - The optional Leak Sensor analyzes water flow sound patterns to detect water leaks. Leak sensor analysis data is uploaded to the mlogonline Network Leak Monitoring online portal. Systems with optional Leak Sensor devices access leak information through their utility-specific, secure mlogonline portal. For more information, see [Leak Sensor Installation on page 33](#) and the *mlogonline Network Leak Monitoring System User Guide*.
- **(Optional) Telemetry devices**
 - An optional remote water disconnect valve provides water utilities with a non-intrusive means of managing customer disconnects and reconnects that traditionally required on-site visits. The remotely-controlled disconnect valve helps lower the utility's costs by eliminating routine move-in/move-out service calls. For more information, see [Remote Disconnect Valve Installation on page 30](#).

Note: Remote water disconnect operation requires a module with enhanced security enabled. To learn more about enabling enhanced security, see the *Field Deployment Manager (FDM) Tools Mobile Application Guide*.

Related Documents

The following documents may also be useful to readers. These documents and others can be accessed and viewed on Itron Access (<https://access.itron.com>).

- *Cellular 500W Module Remote Mount Installation Guide*
- *Cellular 500W Module Technical Reference Guide*

DRAFT

- *Cellular 500W Module Spec Sheet*
- *Field Deployment Manager (FDM) Tools Configuration Guide*
- *Field Deployment Manager (FDM) Tools Mobile Application Guide*
- *OpenWay® Collection Manager Device Interface Guide*
- *500W Module Ordering Guide*

Security

Users have the option of enabling enhanced security in Cellular 500W Pit Modules. Itron Security Manager (ISM) is a feature of the OpenWay® system that ensures certain pit module commands are issued through secure radio communications between the handheld computer, Mobile Collector, or OpenWay Network.

There are two fundamental security processes used in the OpenWay system to ensure secured commands are confidential and valid.

- **Authentication.** Authentication is the process of confirming that an artifact is genuine or valid. Authentication in the Cellular 500W Pit Module is the process of verifying the request is from a valid source and in its original form.
- **Encryption.** Encryption is the process of transforming information to make it unreadable to anyone who does not have a valid security key. There are two types of encryption: symmetric and asymmetric. Symmetric encryption uses a shared key to decrypt or encrypt information. Asymmetric encryption uses a private key to encrypt and a public key to decrypt. Data transmissions over the network are protected using AES-256 encryption.

Transmission Modes

The Cellular 500W Pit Module is an IPv6 Wisun compliant device that operates in Mobile Mode or Network Mode.

Mobile Mode

In Mobile Mode, the module transmits every nine seconds over multiple RF channels to report on:

- meter register value
- cut cable or communication error event
- reverse flow (encoder version selected)
- system leak status
- low battery indicator

DRAFT

Network Mode

In Network Mode, the module reports four interrogation cycles daily. Each interrogation collects six hours of 3,840 buckets of interval and event data. Interval data is configurable from 1 minute to 1 hour (for example, 160 days of hourly data or 40 days of 15 minute data). Interval options are 5, 15, or 30 minutes.

Note: Interval data configuration is dependent on the module's firmware version. See [Firmware Functionality on page 1](#) for more information.

The Cellular 500W Pit Module also sends a local access beacon message every 60 seconds that allows users to gather contingency readings locally when needed.



Caution: If you perform a switch to Network Mode or switch to Mobile Mode operation, it results in a loss of interval data.

The Cellular 500W Pit Module does not require an FCC or ISSED license when operating using the 902 to 928 MHz in the ISM frequency band .

When using the cellular modem, the Cellular 500W Pit Module operates in Band 13 (777-787 Tx and 746-756 Rx) and Band 4 (1710-1755 Tx and 2110-2155 Rx) as defined by the 3GPP LTE standard.

Operating Modes

The pit module has the following operating modes.

■ Factory Mode

- Pit modules ship from the factory in Factory Mode.
- The pit module's transmitter is off.
- The pit module's receiver listens for a programming command.
- The pit modules attempt to read the register every hour.
- Last Good Read and Extended event or alarm flags may be set when a register is not connected.
- If the pit module reads a connected register, the pit module automatically switches to Run Mode.

■ Audit Mode

- Audit mode reduces the normal read latency time associated with standard modes of operation and is often used after initial installation.
- This mode is useful in network installations where the normal bubble rate is very slow.

DRAFT

- Audit Mode remains active for 30 days and then reverts to the initial programmed mode.
- Audit Mode is intended to be used once.
- **Run Mode**
 - Pit module normal operation mode.
 - The Cellular 500W Pit Module transmitted message is dependent on its factory settings or setting programmed with FDM for standard consumption messages (SCM+).
 - For SCM+ (Mobile), the pit module default bubble-up rate is 10 seconds.
- **Quiet Mode**
 - Meter manufacturers can configure the pit module for Quiet Mode after initializing and direct mounting the pit module in the factory.
 - The pit module awakens from Quiet Mode and enters run mode in one of the following ways:
 - The pit module detects consumption at the top of the hour (last hourly interval is greater than 1 or less than -1).
 - The pit module receives a two-way command (for example, a **Read Endpoint** using FDM software).

Battery Life

The Cellular 500W Pit Module is powered by a single non-replaceable, long-life lithium batteries and has an expected battery life of 20 years, dependent on use case.

Low Battery

The Cellular 500W Pit Modules include a low battery indicator that helps utilities proactively plan and manage field module replacements.

Events and Alarms

The events and alarms available to a Cellular 500W Pit Module vary based on the mode it is operating in.

Mobile Mode

Extended Alarm Flag

This is retrievable with two-way communication.

DRAFT

Register Error Flag

- The Register Error flag sets if the Register Error Detected flag is active for 24 hours.
- The Register Error Flag remains active for 40 days in Mobile Mode.

Register Error Detected

- Register Error Detected indicates that the Cellular 500W Pit Module is not communicating with the register/meter. The event or alarm flag automatically clears after the Cellular 500W Pit Module receives a successful read from the register.

Note: The Register Error Detected flag may be an indicator of a damaged register.

Low Battery Warning

- The low battery warning allows the utility to easily identify which water modules are nearing end-of-life in a mixed population and gives the utility the opportunity to schedule replacement.

The pit modules include a battery life estimator. The estimator is based on the number of data packets sent at the various power levels and the age (self-discharge) of the Cellular 500W Pit Module.

Note: The low battery warning is a single flag that is set when the battery has less than 10% remaining capacity, which typically corresponds to 2 years of battery life remaining. Battery life is evaluated daily at midnight.

Network Mode

The Cellular 500W Pit Module reports the tampers available in Mobile Mode *and* extended meter alarms available from solid-state and electronic meters connected to the Cellular 500W Pit Module. The extended alarms include:

- Empty pipe
- Temperature
- High flow
- Meter low battery
- Meter tampering
- Reverse flow
- Zero consumption

Firmware Functionality

This section lists the Cellular 500W Pit Module firmware information and lists functionality by version.

DRAFT

Firmware part number	Global software release version (GSR)	FDM Check Endpoint firmware version	Over-the-air firmware part number	Firmware functionality
FMW-xxx-xxx-[4.4.2]	5.4	4.4.0	DFW-xxx-xxx	■ Initial firmware release ■ Network Mode ■ Mobile Mode ■ 60-minute interval data ■ Firmware download

DRAFT

2

Initialization, Connection, and Programming

This chapter provides the instructions to initialize, connect, and program the pit module.

Requirements are based on the network system mode. The Cellular 500W Pit Module's auto-sensing technology eliminates the need to program the module at the time of installation for most popular registers by automatically detecting the connected register type.

Start Up

When started, the pit module automatically:

- Detects the connected register type at the top of the hour, exits Factory Mode, and enters Run Mode.
- Detects an Itron Leak Sensor.

The Cellular 500W Pit Module programming is required to:

- Change the operation mode
- Enter a utility ID or lock type.
- To enter an E-Coder 8-digit driver.
- Commission security

Itron strongly recommends performing a **Check Endpoint** with a handheld computer running FDM to verify that the pit module is operating correctly after installation. Performing a **Check Endpoint** will:

- Initiate an immediate connection to the cellular network and a register read.
- Verify communication with the Leak Sensor or remote shut-off valve.
- Check for event or alarm flags.

Programming

Programming the pit module requires one of the following handheld computers running Field Deployment Manager (FDM) or FDM Tools version 4.4.0 or later.

- FC300SR handheld computer
- Itron Mobile Radio (IMR) connected to a user-supplied computer or Bluetooth device

For normal activation, connect the pit module to the water meter register. The Cellular 500W Pit Module polls for a register every hour. The pit module automatically activates after it detects the register.

DRAFT



Caution: Do not program configuration changes to the Cellular 500W Pit Module until it is connected to the water meter register.

- The FC300SR or Itron Mobile Radio are the only devices that support programming for the Cellular 500W Pit Module.
- Keep a minimum of 12 inches between the Cellular 500W Pit Module and programming device while programming configuration changes are completed.
- Do not place the programming device antenna directly on the pit module.

Encoder-type Meter Register Connections

Pit module connections are made by the meter manufacturer for encoder-type registers. This information describes those connections.



Caution: Itron recommends pit module connections be completed using the inline connector. In rare instances, if a spliced connection is made, the Itron splice kit must be used (Itron part number OEM-0034-002). For more information, see [Completing Gel-cap Connections Using the Itron Splice Kit on page 34](#).

	Pit module wire color	
	Black (power/clock)	White (ground)
Register manufacturer	Register screw terminal	
Badger ADE E Series HR E LCD HR E Mechanical	Red	Black
Badger M5000 Mag Meter	Red Terminal: Input +	Black Terminal: Input - and Out 4-
Diehl Hydrus	Red	Black
Elster AMCO InVision Scancode AquaMaster AquaMaster III	Green	Black
Elster AMCO SM 700 (Severn Trent) Q200 (Sensus Protocol)	Red	Black

DRAFT

	Pit module wire color	
	Black (power/clock)	White (ground)
Register manufacturer	Register screw terminal	
evoQ4 (Sensus Protocol)		
Elster AMCO evoQ4 Mag	White	Black
Itron (Actaris) Cyble Coder	Red	Black
Kamstrup flowIQ2100	Red	Black
MasterMeter AccuLinx Octave	Red	Black
McCrometer	Clock/red	Gnd port/black
Metron Farnier OER	Red	Black
Mueller (Hersey) Translator SSR	Red	Black
Sensus ECR ICE iPERL SRII OMNI	Red	Black
Neptune ProRead ProRead AutoDetect E-Coder ARB-V	Black	Green
Performance ETR	Red	Black
RG3 Tomahawk	Red	Black
Siemens Mag Meter Mag8000CT-7ME6820 Mag8000-7ME6810	91	93
Zenner (Hendey) ETR	Red	Black

DRAFT

Pulser-type Register Connections

Pit module connections are made by the meter manufacturer for pulser-type registers. This information describes those connections.



Caution: Itron recommends pit module connections be completed using the inline connector. In rare instances, if a spliced connection is made, the Itron splice kit must be used (Itron part number OEM-0034-002). For more information, see [Completing Gel-cap Connections Using the Itron Splice Kit on page 34](#)

	Module wire color	
	Black	White
	Register screw color designator	
Badger RTR (3-wire)	Black	Green
Badger RTR (2-wire)	Black	No connection
Badger M5000 Mag Meter	Black terminal: Out 1-	White terminal: Out 1+
Cadillac Meter CMAG/EMAG Magnetic Flow	COM	DO1/DO2
Elster Digital	Green	Red
Elster V100T	Red	Blue
- Itron (Actaris) - Flostar (2-wire) - Cyble Sensor	Remaining wire must be connected to both ERT module wires	
Krohne IFC	Term H	Term B
RG3 Tomahawk	Black	Green
Sensus PMM	Black	Bare

Cable Extension

Order the 25 foot inline connector extension cable assembly (CFG-0151-404) to extend the pit module's cable.

Operation Verification

Use one of the following handheld computers to verify data consumption:

- FC300SR handheld computer
- Itron Mobile Radio connected to a user-supplied computer or Bluetooth device

DRAFT



Caution: Verifying the Cellular 500W Pit Module operation requires an FC300SR handheld computer or Itron Mobile Radio running FDM 4.0 or higher. Legacy Itron handheld programming devices cannot read the pit modules.

Each handheld radio requires special setup and configuration parameters to successfully read and program the pit module. Refer to the respective meter reading application for specific instructions.

When comparing the actual register value to that reported by the pit module, keep in mind the Cellular 500W Pit Module's consumption value is updated once an hour when it is in Run Mode.

DRAFT

3

Cellular 500W Pit Module Installation

Install the pit module using one of the following methods. (For mounting option accessories, see [Mounting Accessories on page 19](#).)

Through-lid

The pit module mounts in lids with hole sizes from 1.75 inches to 2 inches. Installation requires the Pit mount kit. For more information, see [Through-lid Installation on page 19](#).

Rod mount

The pit module mounts on a 0.5 inch outside diameter rod. Installation requires the rod mount adapter.

Wall mount

The pit module mounts to a wall or other vertical surface. Installation requires the rod mount adapter. For more information, see [Wall Mount Installation on page 26](#).

For Cellular 500W pit boxes, the type of installation method is based on the location of the meter in the pit box and the lid material. Itron recommends mounting the pit module in pit boxes with in plastic lids (or other composite materials) for optimum network performance. The pit modules are temperature rated from -30° C to +60° C. Do not install the pit module in locations that may exceed the temperature rating.



Important! The Cellular 500W Pit Module is shipped with a protective cover over the connectors. The protective cover must be fully engaged over the connectors until the module is installed to protect the module's connectors from damage.



DRAFT



Warning! While Itron modules are designed to withstand a drop, dropping the module may damage the device and void the warranty.

Pit module positioning other than upright will negatively affect radio performance.

Internal circuit card components are sensitive to electrostatic discharge. Be careful not to touch any part of the meter body, register housing, or module prior to discharging any static buildup on your person. To discharge yourself, touch a grounded metal object such as the metal water pipe or an earth-grounded metal structure.

Mounting Accessories

The Cellular 500W can be purchased along with multiple mounting accessories. For more information, see the *500W Module Ordering Guide*.



Caution: Shield unconnected pit module connectors on field-installed modules with protective environmental caps. Do not leave an exposed connector in the field. Environmental caps employ multiple seals to increase connector life.

Pit Modules with Integral Connectors

Prior to connecting inline connectors to the pit module connectors, remove the environmental cap. If pit modules with integral connectors (ECW-1700-001) and the registers are not installed at the same time, secure the protective environmental connector cap on the pit module connector using an Itron security seal (MSC-0018-001). Cable ties are not shipped with the pit module, but can be ordered from Itron. Use the protective cap (on the pit module side) in the field for up to one year.

After installation is complete, recycle or discard installation waste. Do not leave materials on the customer's premises.

Through-lid Installation

This section provides instructions to mount the pit module in a plastic or composite pit lid of 0.5 inch to 2.5 inch thickness with a drilled, round 1.75 inch, 1.875 inch, or 2 inch hole.

DRAFT



Required Tools and Hardware

This mounting method requires the pit lid mounting hardware (CFG-1601-001).

Note: Pit lid mounting is not intended for applications involving vehicular traffic.

This section provides the instructions to install the pit module in a pit lid with a hole using the pit lid mounting bracket. Verify that you have the following items to complete the installation.




1	Pit lid with a pre-drilled hole	User-supplied
2	Through-the-lid retainer clip	CFG-1601-001
3	Retainer clip collar	
4	Cellular 500W Pit Module Note: There are variants of the Cellular 500W, some of which do not include the middle red port.	ECW-1700-001

To mount the module in a through-lid

1. Insert the retainer clip into the pit lid hole with the convex surface on the top of the pit lid.



2. From the bottom side of the lid, screw on the threaded retainer clip collar until the beveled top rests against the pit lid.



Note: Ensure that the beveled edge of the clip collar is toward the top of the pit lid.

3. Align and insert the retainer clip tab (1) into the retainer clip receptacle (2) on the pit module housing.



4. Verify that the clip locks into place and the retainer clip collar is hand-tightened against the pit lid.

DRAFT



Caution: Carefully align the pit module through lid assembly. If the assembly is improperly aligned, the pit lid may not close.



Pit lid mounting installation is complete.

Rod Mount Installation



Important! Rod mount installation requires the rod mount adapter. For more information, see [Mounting Accessories on page 19](#).

500W ERT Pit Modules can mount below the pit lid on a customer-supplied 0.5 inch diameter rod. A mounting rod is available from Itron. For more information, see the *500W Module Ordering Guide*.



Caution: Consider the following when installing the pit module on a rod mount:

- The rod installation area must be free from other pipes, wires, or facilities that may be damaged by driving a rod into the ground.
- You must follow local codes when using the rod mount installation method.
- Failure to use a 0.5 inch rod and follow instructions may result in an unreliable installation.
- Pit module positioning other than upright will negatively affect radio performance.

Required Tools and Hardware

The following tools are required for rod mount installation.

- Hammer
- 0.5 inch outside diameter rod (you may use either a square or round rod)*
- Tape measure
- Rod-driving tool (optional)
- Rod cutting tool

DRAFT

*For mounting rods available from Itron, see [Mounting Accessories on page 19](#) or the *Water Modules Ordering Guide*.

To mount the module on a rod


1. Remove the pit lid. Inspect the area to make sure there are no buried cables, pipes, or other obstructions.
2. Measure the pit box depth from the top of the lip (where the lid will rest) to the bottom of the pit. Be sure to measure the depth at the point where you will drive the rod into the ground.
3. Add 12 inches to the pit box depth measurement taken in Step 2. The resulting total represents the minimum length of rod needed. Soil types and moisture conditions may require longer rod lengths to ensure that the pit module is well supported and remains vertical.
4. Without touching the meter body or adjacent pipes, position the rod as close to the center of the pit as possible. Drive the rod into the ground. Ensure that the rod remains vertical.



Note: The rod shown has an end cap to protect the rod while driving it into the ground.

5. Drive the rod into the ground so the top of the rod is approximately 3.5 inches below the bottom of the pit lid.

DRAFT



- If you cannot drive the rod in enough to equal the necessary spacing, cut the remaining rod length to the proper height using an abrasive cut-off tool.



Caution: Cutting fiberglass creates dust particles. Practice proper safety precautions when using cut-off tools to prevent exposure to fiberglass dust particles.

- If the rod is the correct depth but remains loose in the soil, replace the rod with a longer version.
6. The top of the rod must be 3-1/2 inches below the bottom of the lid. Place the module on the rod. Completely insert the rod into the pit module's rod mount hole. Do not force the pit module onto the rod. If the pit module does not slide freely on the rod, remove the pit module and examine the pit module rod hole and rod for burrs or obstructions.
 7. You may secure the pit module to the rod with a self-drilling screw through the hole in the top of the pit module's rod mount cavity.



DRAFT

8. Connect the register (black connector, 1) and optional telemetry device (blue connector, 2) into the appropriate connection.



9. Turn the connector locking ring to secure the connection.



Caution: Turn only the locking ring. Turning the entire connector could damage the connector pins.

10. Installation is complete when the pit module is perpendicular to the underside of the lid. The pit module must not contact the pit structure or lid.



Caution: Verify that the pit lid does not touch the pit module when the lid is replaced. There must be a 1 to 2 inch space between the top of the pit module and the bottom of the pit lid. If the pit module is installed too high or too low, or is touching any of the surrounding surfaces, adjust the installation as necessary.



DRAFT

Wall Mount Installation

Select a flat vertical mounting surface. Install the pit module in an upright position. Locate the pit module as high as possible in a Cellular 500W pit box. Maintain a distance of one to two inches from the bottom of the pit box lid.



Caution! Observe the following guidelines for mounting the pit module using the wall mount procedure:

- Any module positioning other than upright will negatively affect radio performance.
- Use inline connectors to connect the Cellular 500W Pit Module to the register or meter. If a splice is required to connect the register or meter, you must use the Itron splice kit (OEM-0034-002).
- The pit module works accurately with Itron-approved cable type and lengths up to 300 feet.

To mount the module to a pit wall

1. Select a vertical, flat surface in the pit box.
2. Insert the rod/wall mounting bracket tab (1) into the module tab receptacle (2).



3. Position the pit module vertically so the top of the pit module is between one to two inches below the bottom of the lid.

DRAFT

4. Mark the location of the top mounting hole.



5. Drill a pilot hole in the pit box wall. Follow the screw manufacturer's recommendation for the pilot hole size.
6. For concrete-type pit boxes, it may be necessary to use a screw anchor. Choose an anchor appropriate for a #10 pan head screw.



Caution: Do not over-tighten the mounting screws. Over-tightening the mounting screws may break the pit module mounting tabs.

7. Start a screw into the pilot hole. Using the top hole of the pit module, set the pit module over the screw head and slide it down so the screw is now at the top of the notch. Carefully tighten the screw until snug. Over-tightening the mounting screw could damage the pit module housing.

Note: If the mounting location requires a screw anchor, mark the location of the bottom anchor and remove the pit module. Drill the required mounting hole, insert the anchor, and re-attach the pit module.

8. Holding the pit module in the upright position, drill the second pilot hole. Use the bottom mounting hole as a template.

DRAFT



Caution: Any module position other than upright will negatively affect radio performance.

9. Screw the bottom screw into the pilot hole until snug. Do not over-tighten the mounting screw.

Wall mounting the Cellular 500W Pit Module is complete.

4

Accessory Installation

This chapter provides the installation procedures for Cellular 500W Pit Module accessories, including:

- [Inline Connector Installation on page 29](#)
- [Remote Disconnect Valve Installation on page 30](#)
- [Itron Cable Armor Installation on page 31](#)
- [Leak Sensor Installation on page 33](#)

Inline Connector Installation

Note: If an inline connector is not used or the pit module is already connected to the water meter or register, skip this section.

1. Remove the protective environmental cap from the module connector.



Caution: Verify that the connector ends are clean and dry before assembly.

2. If any of the following conditions occur, do not install the modules.
 - Any of the three pins are damaged or missing.
 - The O-ring is missing.
 - The cable is cut or nicked.
3. Remove the protective cap from the register or accessory connector.
4.
 - Align the connectors.
 - Push until snug.
 - Twist the register cable's black coupling nut to align the two tabs.



5. Connect the register cable to the pit module connector.

DRAFT

Install the security seal as shown. Push it until it snaps into place.



6. For future meter or pit module servicing, break the security seal by pulling the seal apart. The original protective connector caps can be reused if kept clean and dry. Install a new security seal after servicing either device. To order replacement security seals, see the *500W Module Ordering Guide*. Environmental caps employ multiple seals to protect the connector from the environment. Environmental cap design allows utilities to install the pit module and, at a future date, install a Leak Sensor.
7. Shield connectors with protective environmental caps (for more information, see [Mounting Accessories on page 19](#)). Do not leave an exposed connector in the field.

Remote Disconnect Valve Installation

The Smart Earth Technologies (SET) Remote Disconnect Valve is used in conjunction with both indoor (basement) and outdoor (mounting on the exterior of the house) pit module installations. Water disconnect devices mount on a water service pipe or meter insetter (meter horn) and connect to the center telemetry connector (blue) on the pit module. For more information, see [Mounting Accessories on page 19](#).

The pit module automatically detects the presence of connected water disconnect devices within 22.5 minutes and begins reading disconnect valve data. To immediately detect the water disconnect valve and begin reading data, perform a **Check Endpoint** with a handheld computer running FDM software.

Note: Remote water disconnect operation requires a pit module with enhanced security enabled.

The Cellular 500W Pit Module supports the following valve states:

- **Connected.** The water flow is open and flowing at 100% configured capacity.
- **Disconnected.** The water flow is shut off with no water flowing. The remote water

DRAFT

disconnect valve provides the ability to remotely open (reconnect) the valve.

- **Restricted.** The water is restricted and flowing at the configured installation flow.

The Remote Disconnect Valve connects to the pit module's orange, blue, and purple/white wires.

Itron Cable Armor Installation

The Itron cable armor provides a layer of protection for the module's cable jacket. Itron cable armor is available in five-foot sections.

This section describes the procedure for installing Itron cable armor in a field installation.



Warning! Use caution when you are installing the cable armor.

- Itron cable armor is stainless steel and may have sharp edges.
- If you remove the inline connector from the pit module to install the cable armor, you must use an Itron handheld to reprogram the pit module using FDM Endpoint Tools.
- Perform a **Check Endpoint** function (with FDM Endpoint Tools) after you reprogram the pit module to verify communication with the meter register.

Installing the Cable Armor

1. Remove the pit module from the pit.

Note: If it is possible in your field installation, keep the pit module connected to the register.

2. Cut a two to three inch strip of electrical tape.



3. Wrap the entire piece of electrical tape around the pit module cable near the inline connector.



4. Beginning over the installed electrical tape, twist the Itron cable armor onto the pit module cable using a right-handed twist.



Important! You must twist—not wrap—the cable armor onto the pit module cable. Wrapping the cable armor can cause the stainless steel jacket to warp. You must begin twisting the cable armor over portion of the cable protected by the electrical tape. If you do not begin to twist the cable armor over the protected portion of the pit module cable, a cut cable could cause an pit module/register communication failure.



5. Continue to twist the cable armor onto the pit module cable until the cable armor covers the entire cable.
6. Remove any leftover materials from the customer premises. Discard or recycle leftover materials.

DRAFT

Leak Sensor Installation

Installation of the Leak Sensor with a Cellular 500W Pit Module requires the Leak Sensor with an inline connector (Itron part number LDS-1601-001). The Leak Sensor connects to the telemetry connector on the pit module.

If the Leak Sensor five foot cable is not long enough to reach the Cellular 500W Pit Module, an extension cable is available from Itron (CFG-0151-404). The maximum cable length between the Leak Sensor and the Cellular 500W Pit Module should not surpass thirty feet.



Caution: If the pit module is installed to enable communications for the Leak Sensor but a register is not connected, replace the register connector's cap with the environmental cap removed from the blue telemetry connector to protect the register connector.

5

Completing Gel-cap Connections Using the Itron Splice Kit



Caution: Module wire terminations must be properly sealed with a non-conductive gel material to prevent water intrusion.

Required materials

- E-9R 3M® gel connector crimping tool (or other 3M approved crimping tool)
- Itron splice kit (part number OEM-0034-002)


To Complete Gel-Cap Connections

1. Push two wires as far as possible into the connector.



Caution: Do not strip insulation from the ends of the wires before inserting them into the connector.

2. Carefully place the connector and wires into the jaws of the crimping tool. Make sure the wires remain fully inserted in the gel-cap connector.




DRAFT

3. Crimp the connector by squeezing the handles until the connector cap is fully seated. Continue to apply pressure for three seconds.



A connector is crimped properly when the top of the movable yellow center (1) is flush with the top of the connector body (2).



Warning! Crimping the connector forces some sealant out of connector. The sealant protects the inside of the connector against insects, moisture, and other contaminants. The sealant may cause minor eye and skin irritation. Avoid eye contact. Avoid prolonged or repeated skin contact. Contact Itron Support for Safety Data Sheets.



4. After the connections between the Cellular 500W Pit Module and the register or meter wire are completed, arrange the connectors in a single file.

DRAFT



5. Insert the connectors and wires into the splice tube until the connectors and wires are completely immersed in the non-conductive gel material.



6. Separate the cable wires to the sides and close the splice tube cover.



7. Remove any leftover materials from the customer premises.

DRAFT

A Troubleshooting

This information is provided to help you troubleshoot issues related to Cellular 500W Pit Modules.

The following table describes possible issues and provides suggested actions to resolve the issue.

Issue	Action
Cannot program the pit module.	Check the programming device and software version. Program pit module using the FC300 handheld computer running Field Deployment Manager (FDM) software v4.0 or higher.
Cannot read the pit module.	A pit module that is not programmed will not transmit an SCM+ message. Reprogram the pit module and perform a reread. If a pit module is not initially programmed, it will not bubble-up and listen for an SCM+ message.
The pit module is reporting an invalid read.	A pit module that has set the Register Error flag will cause an Invalid Read to display in the FDM Consumption field.
Marginal readability due to Cellular 500W Pit Module location (for example, a pit module deep inside a pit).	Consider reprogramming the pit module for Hard-to-read (H2R) mode. Programming the pit module for hard-to-read mode increases the output to high power. Note: Hard-to-read mode will reduce battery life.
The handheld programmer is locked up and button presses produce no response.	<i>Soft boot</i> the handheld. Reference the documentation for your programming device. For more information, see Related Documents on page 7 .

DRAFT



Important Safety and Compliance Information

This section provides important information for your safety and product compliance.

USA, FCC Part 15 Spectrum Compliance

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:

1. This device may not cause harmful interference, and
2. This device must accept any interference received, including interference that may cause undesired operation.

This device must be installed to provide a separation distance of at least 20 centimeters (7.9 inches) from all persons to be compliant with regulatory RF exposure.

USA, FCC Class B-Part 15

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio or TV technician for help.

Modifications and Repairs

To ensure system performance, this device and antenna shall not be changed or modified without the express approval of Itron. Per FCC and ISED rules, unapproved modifications or operation beyond or in conflict with these instructions for use could void the user's authority to operate the equipment.

DRAFT

Modifications and Repairs



Warning! This unit cannot be modified and is not repairable. Attempts to modify or repair this module will void the warranty per FCC and ISED rules.

Canada, ISED Spectrum Compliance

Compliance Statement Canada	Déclaration de Conformité
This device complies with Innovation, Science and Economic Development Canada (ISED) license-exempt RSS standard(s). Operation is subject to the following two conditions: (1) this device may not cause interference, (2) this device must accept any interference, including interference that may cause undesired operation of the device. Under Innovation, Science and Economic Development Canada (ISED) regulations, this radio transmitter may only operate using an antenna of a type and maximum (or lesser) gain approved for the transmitter by Industry Canada. To reduce potential radio interference to other users, the antenna type and its gain should be so chosen that the equivalent isotropically radiated power (e.i.r.p.) is not more than that necessary for successful communication.	Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes: (1) l'appareil ne doit pas produire de brouillage, (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement. Conformément à la réglementation d'Industrie Canada, le présent émetteur radio peut fonctionner avec une antenne d'un type et d'un gain maximal (ou inférieur) approuvé pour l'émetteur par Industrie Canada. Dans le but de réduire les risques de brouillage radioélectrique à l'intention des autres utilisateurs, il faut choisir le type d'antenne et son gain de sorte que la puissance isotrope rayonnée équivalente (p.i.r.e.) ne dépasse pas l'intensité nécessaire à l'établissement d'une communication satisfaisante.

RF Exposure (FCC/ISED)

This equipment complies with radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 20 cm between the radiator and your body. This transmitter must not be co-located or operating in conjunction with any other antenna or transmitter.

Cet équipement est conforme aux limites d'exposition aux radiations dans un environnement non contrôlé. Cet équipement doit être installé et utilisé à distance minimum de 20 cm entre le radiateur et votre corps. Cet émetteur ne doit pas être co-localisées ou opérant en conjonction avec tout autre antenne ou transmetteur.

Lithium Battery Safety



Warning! Follow these procedures to avoid injury to yourself or others.

- The lithium battery may cause a fire or chemical burn if it is not disposed of properly.
- Do not recharge, disassemble, heat above 212°Fahrenheit (100°C Celsius), crush, expose to water, or incinerate the lithium battery. Fire, explosion, and severe burn hazard.

DRAFT

- The battery used in this device may present a risk of fire or chemical burn if mistreated.
- Keep the lithium battery away from children.

Electromagnetic Compatibility



Warning! Use only approved accessories with this equipment. Unapproved modifications or operation beyond or in conflict with these instructions for use may void authorization by the authorities to operate the equipment.

Electrostatic Discharge



Warning! Internal circuit components can be sensitive to electrostatic discharge. Before installation, discharge electrostatic buildup by touching a metal pipe or other earth-grounded metal object prior to touching the meter body, register housing, or Itron device.

Do Not Drop



Warning! While Itron modules are designed to withstand a drop, dropping the module may damage the device and void the warranty.