

Peter Walthers
Sr. Compliance Engineer
Environmental & Combustion Controls

Automation & Control Solutions
Honeywell, Inc.
MN10-121A
1985 Douglas Drive North
Golden Valley, Minnesota 55422-3992

Ph: 763-954-5256
Fax: 763-954-5454
Peter.Walthers@honeywell.com

Date: 04/04/2016

The DD15 unit will consist of a simple housing designed to mount inside the Daikin VRV unit. This product will contain 1 PWBA. This PWBA will contain the STM32F303 32-bit host micro to manage the INNCOM CBL32 firmware, S5bus wired communications and Deep Mesh RF wireless communications using the CC2520 2.4Ghz radio and CC2591 front-end amplifier for wireless 802.15.4 communication. The PWB will contain the Mitsumi 1192 programmed IC with HBS protocol for proprietary communication on the P1/P2 system bus towards the Daikin VRV.

This is an original application for the certification of FCC ID: HS9-DD15 under FCC 15.247.

Sincerely,



Peter Walthers
Sr. Regulatory Compliance Engineer
HONEYWELL INTERNATIONAL INC.
ACS, Environmental & Combustion Controls
Golden Valley, Minnesota, 55422 United States