

**HAC\_E\_Dipole\_835\_180222****DUT: HAC-Dipole 835 MHz**

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  S/m,  $\epsilon_r = 1$ ;  $\rho = 0$  kg/m<sup>3</sup>

Ambient Temperature : 23.5 °C

**DASY5 Configuration**

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2018/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn854; Calibrated: 2017/5/2
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7373)

**E Scan - measurement distance from the probe sensor center to CD835 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x361x1): Interpolated grid:**

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 123.4 V/m; Power Drift = -0.01 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 109.6 V/m

Average value of Total=(109.6+107.6) / 2 = 108.6 V/m

**PMF scaled E-field**



|                                      |                                      |                                      |
|--------------------------------------|--------------------------------------|--------------------------------------|
| <b>Grid 1 M4</b><br><b>106.0 V/m</b> | <b>Grid 2 M4</b><br><b>109.6 V/m</b> | <b>Grid 3 M4</b><br><b>108.3 V/m</b> |
| <b>Grid 4 M4</b><br><b>62.68 V/m</b> | <b>Grid 5 M4</b><br><b>63.73 V/m</b> | <b>Grid 6 M4</b><br><b>63.05 V/m</b> |
| <b>Grid 7 M4</b><br><b>105.9 V/m</b> | <b>Grid 8 M4</b><br><b>107.6 V/m</b> | <b>Grid 9 M4</b><br><b>105.9 V/m</b> |

**Cursor:**

Total = 109.6 V/m

E Category: M4

Location: -1, -75.5, 9.7 mm



0 dB = 109.6 V/m = 40.80 dBV/m

**HAC\_E\_Dipole\_1880\_180222****DUT: HAC Dipole 1880 MHz**

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  S/m,  $\epsilon_r = 1$ ;  $\rho = 0$  kg/m<sup>3</sup>

Ambient Temperature : 23.5 °C

**DASY5 Configuration**

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2018/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn854; Calibrated: 2017/5/2
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7373)

**E Scan - measurement distance from the probe sensor center to CD1880 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1):** Interpolated grid:

$dx=0.5000$  mm,  $dy=0.5000$  mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 144.9 V/m; Power Drift = 0.10 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 93.35 V/m

Average value of Total=(91.47+93.35) / 2 = 92.41 V/m

**PMF scaled E-field**



|                                      |                                      |                                      |
|--------------------------------------|--------------------------------------|--------------------------------------|
| Grid 1 <b>M3</b><br><b>90.21 V/m</b> | Grid 2 <b>M3</b><br><b>91.47 V/m</b> | Grid 3 <b>M3</b><br><b>90.01 V/m</b> |
| Grid 4 <b>M3</b><br><b>70.88 V/m</b> | Grid 5 <b>M3</b><br><b>72.25 V/m</b> | Grid 6 <b>M3</b><br><b>71.49 V/m</b> |
| Grid 7 <b>M3</b><br><b>91.58 V/m</b> | Grid 8 <b>M3</b><br><b>93.35 V/m</b> | Grid 9 <b>M3</b><br><b>91.40 V/m</b> |

**Cursor:**

Total = 93.35 V/m

E Category: M3

Location: 0, 31, 9.7 mm



0 dB = 93.35 V/m = 39.40 dBV/m

**HAC\_E\_Dipole\_2450\_180305****DUT: HAC Dipole 2450 MHz**

Communication System: CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  S/m,  $\epsilon_r = 1$ ;  $\rho = 0$  kg/m<sup>3</sup>

Ambient Temperature : 23.3 °C

**DASY5 Configuration**

- Probe: EF3DV3 - SN4047; ConvF(1, 1, 1); Calibrated: 2018/1/8;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn853; Calibrated: 2017/7/19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7373)

**E Scan - measurement distance from the probe sensor center to CD2450 = 10mm & 15mm 2/Hearing Aid Compatibility Test at 15mm distance (41x181x1):** Interpolated grid: dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 79.25 V/m; Power Drift = 0.01 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 92.62 V/m

Average value of Total=(90.72+92.62) / 2 = 91.67 V/m

**PMF scaled E-field**



|                                      |                                      |                                      |
|--------------------------------------|--------------------------------------|--------------------------------------|
| Grid 1 <b>M3</b><br><b>89.74 V/m</b> | Grid 2 <b>M3</b><br><b>90.72 V/m</b> | Grid 3 <b>M3</b><br><b>87.84 V/m</b> |
| Grid 4 <b>M3</b><br><b>79.76 V/m</b> | Grid 5 <b>M3</b><br><b>80.14 V/m</b> | Grid 6 <b>M3</b><br><b>78.25 V/m</b> |
| Grid 7 <b>M3</b><br><b>91.25 V/m</b> | Grid 8 <b>M3</b><br><b>92.62 V/m</b> | Grid 9 <b>M3</b><br><b>89.70 V/m</b> |

**Cursor:**

Total = 92.62 V/m

E Category: M3

Location: 0.5, 24.5, 8.7 mm



0 dB = 92.62 V/m = 39.33 dBV/m

**HAC\_E\_Dipole\_2600\_180222****DUT: HAC Dipole 2600 MHz**

Communication System: CW ; Frequency: 2600 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  S/m,  $\epsilon_r = 1$ ;  $\rho = 0$  kg/m<sup>3</sup>

Ambient Temperature : 23.5 °C

**DASY5 Configuration**

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2018/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn854; Calibrated: 2017/5/2
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7373)

**E Scan - measurement distance from the probe sensor center to CD2600 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1):** Interpolated grid:

dx=0.5000 mm, dy=0.5000 mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 72.61 V/m; Power Drift = 0.05 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 92.36 V/m

Average value of Total=(84.42+92.36) / 2 = 88.39 V/m

**PMF scaled E-field**



|                                      |                                      |                                      |
|--------------------------------------|--------------------------------------|--------------------------------------|
| Grid 1 <b>M3</b><br><b>83.91 V/m</b> | Grid 2 <b>M3</b><br><b>84.42 V/m</b> | Grid 3 <b>M3</b><br><b>82.63 V/m</b> |
| Grid 4 <b>M3</b><br><b>87.54 V/m</b> | Grid 5 <b>M3</b><br><b>89.24 V/m</b> | Grid 6 <b>M3</b><br><b>88.20 V/m</b> |
| Grid 7 <b>M3</b><br><b>90.76 V/m</b> | Grid 8 <b>M3</b><br><b>92.36 V/m</b> | Grid 9 <b>M3</b><br><b>90.94 V/m</b> |

**Cursor:**

Total = 92.36 V/m

E Category: M3

Location: 0, 20, 9.7 mm



0 dB = 92.36 V/m = 39.31 dBV/m

**HAC\_E\_Dipole\_2600\_180228****DUT: HAC Dipole 2600 MHz**

Communication System: CW ; Frequency: 2600 MHz; Duty Cycle: 1:1

Medium: Air Medium parameters used:  $\sigma = 0$  S/m,  $\epsilon_r = 1$ ;  $\rho = 0$  kg/m<sup>3</sup>

Ambient Temperature : 23.3 °C

**DASY5 Configuration**

- Probe: ER3DV6 - SN2358; ConvF(1, 1, 1); Calibrated: 2018/1/19;
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn853; Calibrated: 2017/7/19
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BA;
- Measurement SW: DASY52, Version 52.8 (8); SEMCAD X Version 14.6.10 (7373)

**E Scan - measurement distance from the probe sensor center to CD2600 = 10mm & 15mm/Hearing Aid Compatibility Test at 15mm distance (41x181x1):** Interpolated grid:

$dx=0.5000$  mm,  $dy=0.5000$  mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 72.50 V/m; Power Drift = 0.01 dB

PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 92.18 V/m

Average value of Total=(84.26+92.18) / 2 = 88.22 V/m

**PMF scaled E-field**



|                                      |                                      |                                      |
|--------------------------------------|--------------------------------------|--------------------------------------|
| Grid 1 <b>M3</b><br><b>83.74 V/m</b> | Grid 2 <b>M3</b><br><b>84.26 V/m</b> | Grid 3 <b>M3</b><br><b>82.47 V/m</b> |
| Grid 4 <b>M3</b><br><b>87.38 V/m</b> | Grid 5 <b>M3</b><br><b>89.07 V/m</b> | Grid 6 <b>M3</b><br><b>88.03 V/m</b> |
| Grid 7 <b>M3</b><br><b>90.58 V/m</b> | Grid 8 <b>M3</b><br><b>92.18 V/m</b> | Grid 9 <b>M3</b><br><b>90.76 V/m</b> |

**Cursor:**

Total = 92.18 V/m

E Category: M3

Location: 0, 20, 9.7 mm



0 dB = 92.18 V/m = 39.29 dBV/m