

ORIGINALFORMAT A3

FLEX CONTROLLED FIELDS

NO.	FIELD	SITE	PART NO.	MARKING FORMAT	EXAMPLE FORMAT
A	MODEL	ALL	-FLEX	<MODEL>	1208XX
B	SERIAL NO.	ALL	-FLEX	<YYAABC1234567>	22BKRL0011234
C	PRODUCTION DATE	ALL	-FLEX	<MM-YYYY>	03-2022
D	QR CODE LINKED TO MY ASSETS	ALL	-FLEX	<QR-CODE>	

REVISION

01

ECO NO.

SME-11379

ISSUED

PC-AA

APP'D

EAp-AS

DATE


2303

DESCRIPTION

1208C EX CERTIFICATION LABEL DRAWING

Description product variant	Model	Language	Part Number	Model string
Rosemount™ 1208C Level and Flow Transmitter	1208C	English	7000007-428	1208CG
Rosemount™ 1208C Level and Flow Transmitter	1208C	English	7000007-429	1208CN
Rosemount™ 1208CG Level and Flow Transmitter	1208C	Chinese	7000007-430	1208CGC
Rosemount™ 1208CN Level and Flow Transmitter	1208C	Chinese	7000007-431	1208CNC

STRING CONTROLLED FIELDS

NO.	FIELD	MODEL	PART NO.	PART. REV.	MARKING FORMAT	LANGUAGE
1.	BASE LAYER	1208A,1208C	-0001	AA	According to base layer artwork illustration	English
		1208C	-0002	AA	According to base layer artwork illustration	Chinese
2.	CONNECTION DIAGRAM	1208C	-0202	AA		All
3.	WARNING	1208C	-0301	AA	SUBSTITUTION OF COMPONENTS MAY IMPAIR INTRINSIC SAFETY. TO PREVENT IGNITION OF FLAMMABLE OR COMBUSTIBLE ATMOSPHERES, DISCONNECT POWER BEFORE SERVICING. INSTALL PER CONTROL DRAWING LA SUBSTITUTION DE COMPOSANTS PEUT COMPROMETTRE LA SÉCURITÉ INTRINSÈQUE. POUR ÉVITER L'ALLUMAGE DE PRODUITS INFLAMMABLES OU ATMOSPÈRES COMBUSTIBLES, DÉBRANCHEZ L'ALIMENTATION AVANT L'ENTRÉEN INSTALLER SELON LE SCHEMA DE CONTRÔLE	All
4.	LOGOS	1208C	-0401	AA		All
5.	LOGOS	1208C	-0502	AA		All
6.	SUPPLY	1208C	-0602	AB	HART® 4-20 mA 14-35 VDC 22.5mA	All
7.	MADE IN	1208C	-0703	AB	泰国制造	Chinese
		1208C	-0704	AB	Made in Thailand	English
8.	RADIO OUT.	1208C BT	-0903	AA	K8C1208CLB 2827A-1208CLB 1208CLB1	All
		1208C	-0904	AA	K8C1208CL 2827A-1208CL 1208CL1	All

1. LABEL TO BE CUSTOMIZED ACCORDING TO FLEX CONTROLLED FIELDS
2. ALL APPROVAL LOGOS IN ACC. WITH RESP. LOGOTYPE.

FM APPROVED PRODUCT.
No revisions to this drawing
without prior Factory Mutual
Approval.

D7000007-910

ISSUED BY
PC-AA

APPROVED BY
EAp-AS

UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS ARE IN MILLIMETERS.
REMOVE ALL BURRS AND SHARP EDGES.

MACHINING: ISO 2768

CASTING: ISO 8062

WELDING: EN-ISO 13920

FINISH: ✓

ANGLES:

1 ST ANGLE

SCALE
1:1

SIZE
A3

Adobe Illustrator

DO NOT SCALE PRINT

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN

EMERSON™

LAYOUTVÄGEN 1, 435 33 MÖLNLYCKE , SWEDEN

TITLE

ROSEMOUNT 1208C EX CERT LABEL DRAWING

DRAWING NO.

D7000007-910

ISSUE

01

SHEET

1/2

ORIGINALFORMAT A3

REVISION

ECO NO.

ISSUED

APP'D

DATE

01

SME-11379

PC-AA

EAp-AS

2245

DESCRIPTION

1208 CERTIFICATION DRAWING

EMERSON | ROSEMOUNT

MODEL 1208XX

SERIAL 22BKRL0011234

DATE MFG: 03-2022

FCC ID: K8C1208CL

IC: 2827A-1208CL

HVIN: 1208CL1

Level & Flow Transmitter

Made in Thailand


SUPPLY: HART® 4-20 mA

== 14-35 VDC 22.5mA

ENCL. TYPE: 4X/6P, IP66/68, IK07

MWP: 3 BAR





1 BN L+

2 WH NC

4 BK NC

3 BU L-





Certificate Holder

Mölnlycke, Sweden

Rosemount Tank Radar AB

Layoutvägen 1, 435 33 Mölnlycke, SWE

SUBSTITUTION OF COMPONENTS MAY IMPAIR INTRINSIC SAFETY. TO PREVENT IGNITION OF FLAMMABLE OR COMBUSTIBLE ATMOSPHERES, DISCONNECT POWER BEFORE SERVICING. INSTALL PER CONTROL DRAWING

LA SUBSTITUTION DE COMPOSANTS PEUT COMPROMETTRE LA SÉCURITÉ INTRINSÈQUE. POUR ÉVITER L'ALLUMAGE DE PRODUITS INFLAMMABLES OU ATMOSPHERES COMBUSTIBLES, DÉBRANCHEZ L'ALIMENTATION AVANT L'ENTRÉRIEN INSTALLER SELON LE SCHEMA DE CONTRÔLE


EMERSON

ROSEMOUNT™

1208
Level and Flow Transmitter

EXAMPLE LABEL 1208C

EMERSON | ROSEMOUNT

型号 1208XX

出厂编号 22BKRL0011234

制造日期 03-2022

FCC ID: K8C1208CL

IC: 2827A-1208CL

HVIN: 1208CL1

液位 & 流量变送器

泰国制造


电源电压: HART® 4-20 mA

== 14-35 VDC 22.5mA

ENCL. TYPE: 4X/6P, IP66/68, IK07

MWP: 3 BAR





1 BN L+

2 WH NC

4 BK NC

3 BU L-





证书持有者

Mölnlycke, Sweden

Rosemount Tank Radar AB

Layoutvägen 1, 435 33 Mölnlycke, SWE

SUBSTITUTION OF COMPONENTS MAY IMPAIR INTRINSIC SAFETY. TO PREVENT IGNITION OF FLAMMABLE OR COMBUSTIBLE ATMOSPHERES, DISCONNECT POWER BEFORE SERVICING. INSTALL PER CONTROL DRAWING

LA SUBSTITUTION DE COMPOSANTS PEUT COMPROMETTRE LA SÉCURITÉ INTRINSÈQUE. POUR ÉVITER L'ALLUMAGE DE PRODUITS INFLAMMABLES OU ATMOSPHERES COMBUSTIBLES, DÉBRANCHEZ L'ALIMENTATION AVANT L'ENTRÉRIEN INSTALLER SELON LE SCHEMA DE CONTRÔLE


EMERSON

ROSEMOUNT™

1208
Level and Flow Transmitter
液位/流量变送器

EXAMPLE LABEL 1208CN

1. LABEL TO BE CUSTOMIZED ACCORDING TO FLEX CONTROLLED FIELDS
2. ALL APPROVAL LOGOS IN ACC. WITH RESP. LOGOTYPE.

FM APPROVED PRODUCT.
No revisions to this drawing
without prior Factory Mutual
Approval.

D7000007-910

ISSUED BY PC-AA		DRAWN WEEK 2303		PRODUCT CODE 1208		 EMERSON™ LAYOUTVÄGEN 1, 435 33 MÖLNLYCKE , SWEDEN	
APPROVED BY EAp-AS		APP'D WEEK 2303		DOC TYPE 6			
UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS ARE IN MILLIMETERS. REMOVE ALL BURRS AND SHARP EDGES.						TITLE ROSEMOUNT 1208C EX CERT LABEL DRAWING	
- GENERAL TOLERANCES -							
MACHINING: ISO 2768		FINISH: ✓		DRAWING NO. D7000007-910			
CASTING: ISO 8062		ANGLES:					
WELDING: EN-ISO 13920				ISSUE 01			
1 ST ANGLE 		SCALE 1:1		SIZE A3		SHEET 2/2	
				Adobe Illustrator DO NOT SCALE PRINT			
THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN							