

Chapter 7

Evaluation Software

7 Evaluation Software


7.1. Software installation.

Check to see if there has been any prior installation of the software. If a previous installation was detected, it must be removed before installing the new version. This may be done by clicking the UNINSTALL.EXE file on the CD-ROM.


To install the software, insert the CD-ROM disk into your system's CD-ROM drive. Click on the install icon and follow setup instructions that appear on the screen.

7.2. Communication Setup - Readers Administration.

The Readers Administration screen may be accessed by clicking on the Readers menu button on the top of the screen, and then on Readers Administration.




Alternatively, click on the Readers Administration icon or type Ctrl+R.



7.2.1. Defining the readers connected.

Reader ID and Reader Address are used to add/remove readers. The readers may be connected using either RS232 or RS485.




RS232 communication allows the connection of a single reader to a PC. As only one user is connected, there is no necessity to define a specific reader address.

The Reader ID is located on the back of the Reader, in barcode


and numeric format. To add a Reader, insert the Reader ID and click on the ADD button. To remove a Reader, use the mouse to mark it and click on the REMOVE button.

RS485 communication allows several readers to be connected to a single PC. Prior to configuration, the User must decide on the placement of the readers and in accordance with the layout decide upon a specific Reader Address for each reader.



7.2.2. Setting up the communication channel.

In the **Readers/Channel (CommPort) Administration** box, click on the Com. Port drop down list to define your communication port. Click on the Baud Rate drop down menu list to the right of the Com. Port drop down list to define Baud Rate. Once you have made your selection, click on the Set Comm Port button.



NOTE: The Baud Rate is determined by the PC's capabilities; the Reader itself can work at any of the Baud Rates defined in the drop down list.

7.3. Readers Setup

To start the Reader Setup, press on the "Reader Setup" icon (Item 1 in Figure 7.1) or select "Readers" and "Reader Setup" as shown in Figure No. 7.2.

Two groups of parameters are operated from that screen: MCU Setup and RF Modem Setup.




Fig. 7.1




Fig. 7.2

7.3.1. MCU Setup

Firmware Version, Loader Version, and Reader ID are Read-Only parameters of the MCU Setup screen (Figure 7.1.) Reader Address is the only parameter that can be modified.

7.3.2. RF Modem Setup

The first parameter, Firmware Version is a Read-Only parameter. All other parameters can be modified at any time.

To get the existing parameters in the DataReader, select the appropriate Reader in the "Reader" box (Item 1 in Figure 7.3). Click on the "Refresh" button if the parameters are not updated automatically.

After writing the new parameters, for both the MCU and RF Modem, click on the "Apply" button.




Fig. 7.3

7.4. Built-In Test

In order to perform the test, click on “Readers” and then “Built-In” Test as shown in Figure 7.4. The “Test” window will open (Figure No. 7.5).




Fig. 7.4

Begin the process by selecting the DataReader to be tested at the box marked as Item 1 in Figure 7.5.

To get the results of the last test, press on the “Get Current Reader Status” bar. To run a new test, press on the “Execute Built-In Test” bar and the new results will be displayed.




Fig. 7.5

The “Voltage Values” displayed (Item 2 in Figure 7.5) are the actual values measured in the DataReader: The first value (2.544) represents the MCU, the second (0) represents the RF Modem 1 (not installed) and the third value (2.56) represents RF Modem 2.

A detailed explanation of the abbreviations in this window (Item 3 in Figure 7.5) is provided hereunder:

7.5. Login-Password Setup, Password Change

When the program is started for the first time after installation of the Evaluation Software, it will open at the lowest level of authorization. A password is not required at this time.




Fig. 7.6

To allow only authorized access using a password, click on "Tools" as shown in Figure 7.6. The "Options" (Figure 7.7) will open.

The "Options" window is used for changing the User, Administrator or Distributor passwords. Following Setup of the Evaluation software, the passwords are:
For User: *user*
For Administrator: *admin*




Fig. 7.7

In order to change the password for any of the three levels of authorization, key the appropriate information in the boxes and press on the "Change Password" button. If you wish to change the password of a certain user (User or Administrator), you must login as that user.

If you wish to access the Evaluation Software without going through the "Login" window (Figure 7.8), check the box titled "Always login using this user type of Password" (Item 1 in Figure 7.7).



Fig. 7.8

If you wish the “Login” window to come up each time the Evaluation Software is activated (Password Protection) clear the checkbox titled “Always Login Using this user type and password”. If this box is checked, the “Login “ window will not come up when opening the Evaluation Software. You will, however, always login as the user type you selected. If the lower checkbox (Item 2 in Figure 7.7) is checked, the “Login” window will come up with the selected user type as a default.

7.6. Download DataReader Software Utility

7.6.1. MCU Software Update

The DataReader's MCU Software update procedure is initiated from the "Hi-G-Tek DataSeal Evaluation Software" screen.




Fig. 7.9

Select "Tools" in the main menu and "Update Reader's Software" and mark "MCU" as shown in Figure 7.9

When the "MCU Download" window comes up, select the DataReader to get the software update. The update can be performed to one DataReader, chained in the system at a time.




Fig. 7.10

If only one reader is connected you may choose the "All Readers (Address=0)" as shown in Figure 7.10.. If more than one reader is chained, the address of the specific reader needs to be selected. Press on the "Browse" button and mark the file containing the software update. When the target reader and the file to be downloaded are presented in the window (as shown in Figure 7.10), press on the "Start" button to execute the download process.

Note: In the event that communication between the PC and the DataReader is not established within 10 seconds a message will come up as shown in Figure 7.11.




Fig. 7.11

7.6.2. RF Modem Software Update

The **DataReader's** RF Modem Software update procedure is initiated from the "Hi-G-Tek DataSeal Evaluation Software" screen.




Fig. 7.12

Select "Tools" in the main menu and "Update Reader's Software" and mark "RF Modem" as shown in Figure 7.12.

When the "Device Download Utility" window comes up, select the DataReader which will get the software update. The update can be performed to one DataReader chained in the system at a time.




Fig. 7.13

If only one reader is connected you may choose the "All Readers (Address=0)" as shown in Figure 7.10. If more than one reader is chained, the address of the specific reader needs to be selected (as shown in figure 7.13).

Press on the "Browse" button and mark the file containing the software update. Press on the "Browse" button and mark the file containing the software update. Select "Device" in the DataReader targeted for update: The RF Modem is at location 2.

When the target reader, the file to be downloaded and the location of the RF Modem are presented in the window (as shown in Figure 7.13), press on the "Start" button to execute the download process.

7.7. Performing Verify and Set Cycles


Access the Verify and Set menu by clicking on the Seals menu button on the top of the screen, and then on Verify and Set. Alternatively, click on the Verify and Set icon or type Ctrl+I.



7.7.1 Selecting the Reader.


A specific Reader must be selected prior to the initialization of a COMMAND session.

To select a Reader, click on the Reader drop-down list and select the appropriate Reader from the list.



7.7.2 Broadcast Sessions.

In Broadcast Verify mode, the reader sends interrogation messages to all the seals.



7.7.2.1 Setting Sessions Parameters

All numbers are represented as decimal digit values. The Tcm and Na parameters are not in use, and their value is 0. An explanation of the parameters follows below.

Broadcast Verify	
ADI:	0
Reader session:	5220 ms
Single Interrogation	
Cyclical Interrogation	
Addressed Verify and Set	
Seal Status:	
Tcm	0
Tiw	0
Ts	21
Na	0
Nr	80
Nt	0
Rr	4
Rt	0

Tcm - Time Calibration Message; this parameter is not currently in use, and should be set to 0. Parameter size=1 byte.

Tiw - Time Interlace Window; this parameter sets the time between the BMM (Broadcast Master Message) and the first reply slot. Minimum value=0, maximum value=16000. Parameter size=2 bytes.

Ts - Time slot; Size of reply slot. Unit size=1.024 ms. This parameter has 4 values which variate according to the amount of data received. These values are 21, 41, 63, 82. Other values will cause a deviation. Parameter size=1 byte.

Na - Number Assigned; Currently not in use. Value should be 0. Parameter size=1 byte.

Nr - Number Random; Number of random slots. Only a number from the statistical table may be entered. Parameter size=1 byte.

Nt - Number Tamper; Number of reply slots for the tamper message. Only a number from the statistical table may be entered.

Rr - Random Retry; The number of times the seal will send a transmission. To be set at the User's discretion. Only a number from the statistical table may be entered.

Rt - Retry Tamper; The number of times the seal will send a tamper message. To be set at the User's discretion. Only a number from the statistical table may be entered.

Nr, Nt, Rr & Rt Statistical Table

Max # Seals	Min # Sessions	#Window																											
		30	40	50	60	70	80	90	100	110	120	130	140	150	160	170	180	190	200	210	220	230	240	250					
2	1	4	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	2	2	2	2	2	2	2	2				
	2	2	2	2	2	2	2	2	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				
3	1	-	9	6	5	5	4	4	4	4	4	4	4	4	3	3	3	3	3	3	3	3	3	3	3				
	2	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2				
4	1	-	-	-	-	10	6	6	6	5	5	5	4	4	4	4	4	4	4	4	4	4	4	4	4				
	2	-	4	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2				
5	1	-	-	-	-	-	-	-	8	7	7	6	6	6	6	5	5	5	5	5	5	4	4	4	4				
	2	-	-	5	4	3	3	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2				
6	1	-	-	-	-	-	-	-	-	-	-	8	8	8	6	6	6	6	6	5	5	5	5	5	5				
	2	-	-	-	5	4	3	3	3	3	3	2	2	2	2	2	2	2	2	2	2	2	2	2	2				
7	1	-	-	-	-	-	-	-	-	-	-	-	-	9	8	8	7	6	6	6	6	6	6	6	5				
	2	-	-	-	-	5	5	4	4	3	3	3	3	3	3	2	2	2	2	2	2	2	2	2	2				
8	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	10	8	6	7	9	6	6	6	6				
	2	-	-	-	-	-	-	5	5	4	4	3	3	3	3	3	3	3	2	3	3	2	2	2	2				
9	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	8	9	9	9	8	8	8				
	2	-	-	-	-	-	-	-	6	5	4	4	4	3	3	3	3	3	3	3	-	3	3	3	3				
10	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	10	9	9	9				
	2	-	-	-	-	-	-	-	-	7	5	5	5	4	4	4	4	4	3	3	3	3	3	3	3				
12	1	-	-	-	-	-	-	-	-	-	-	7	6	5	5	4	4	4	4	4	4	3	3	3	3				
	2	-	-	-	-	-	-	-	4	4	3	3	3	2	2	2	2	2	2	2	2	2	2	2	2				
14	1	-	-	-	-	-	-	-	-	-	-	-	-	-	9	7	5	5	4	4	4	4	4	4	4				
	2	-	-	-	-	-	-	-	-	5	4	3	3	3	3	3	2	2	2	2	2	2	2	2	2				
16	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	6	5	5	5	4	4	4	4				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
18	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
20	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
25	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
30	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
35	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				

7.7.2.2 ADI Definition

ADI is the Seal Group Identification. Each seal can have an internal ID number. ADI defines the seals by group. All numbers on this screen are registered in decimal value. The ADI ranges from a minimum value of 0 to a maximum value of 64000. If the number entered in the ADI text box is "0", all seals respond. If a specific number is entered, the seals respond according to their grouping. See paragraph TBD.

Broadcast Verify																			
ADI:	0																		
Reader session:	5220 ms																		
Single Interrogation Cyclical Interrogation																			
Addressed Verify and Set																			
<table border="1"> <thead> <tr> <th colspan="2">Seal Status:</th> </tr> </thead> <tbody> <tr> <td>Tcm</td> <td>0</td> </tr> <tr> <td>Tiw</td> <td>0</td> </tr> <tr> <td>Ts</td> <td>21</td> </tr> <tr> <td>Na</td> <td>0</td> </tr> <tr> <td>Nr</td> <td>80</td> </tr> <tr> <td>Nt</td> <td>0</td> </tr> <tr> <td>Rr</td> <td>4</td> </tr> <tr> <td>Rt</td> <td>0</td> </tr> </tbody> </table>		Seal Status:		Tcm	0	Tiw	0	Ts	21	Na	0	Nr	80	Nt	0	Rr	4	Rt	0
Seal Status:																			
Tcm	0																		
Tiw	0																		
Ts	21																		
Na	0																		
Nr	80																		
Nt	0																		
Rr	4																		
Rt	0																		

7.7.2.3. Reader Session

The Reader Session button, located directly beneath the ADI window box, defines actual session time. The system automatically defines session time after the User clicks on either the Single or Cyclical Interrogation buttons.

Broadcast Verify																			
ADI:	0																		
Reader session:	5220 ms																		
Single Interrogation Cyclical Interrogation																			
Addressed Verify and Set																			
<table border="1"> <thead> <tr> <th colspan="2">Seal Status:</th> </tr> </thead> <tbody> <tr> <td>Tcm</td> <td>0</td> </tr> <tr> <td>Tiw</td> <td>0</td> </tr> <tr> <td>Ts</td> <td>21</td> </tr> <tr> <td>Na</td> <td>0</td> </tr> <tr> <td>Nr</td> <td>80</td> </tr> <tr> <td>Nt</td> <td>0</td> </tr> <tr> <td>Rr</td> <td>4</td> </tr> <tr> <td>Rt</td> <td>0</td> </tr> </tbody> </table>		Seal Status:		Tcm	0	Tiw	0	Ts	21	Na	0	Nr	80	Nt	0	Rr	4	Rt	0
Seal Status:																			
Tcm	0																		
Tiw	0																		
Ts	21																		
Na	0																		
Nr	80																		
Nt	0																		
Rr	4																		
Rt	0																		

7.7.2.4 Single Session.

Single Interrogation is one reader session of all seals answering to a specific definition. This means that several results may be obtained. Click on the Single Interrogation button for a single reader session. Results of the session appear in a table to the left of the button (See section 4.2.6.)

Broadcast Verify																			
ADI:	0																		
Reader session:	5220 ms																		
Single Interrogation Cyclical Interrogation																			
Addressed Verify and Set																			
<table border="1"> <thead> <tr> <th colspan="2">Seal Status:</th> </tr> </thead> <tbody> <tr> <td>Tcm</td> <td>0</td> </tr> <tr> <td>Tiw</td> <td>0</td> </tr> <tr> <td>Ts</td> <td>21</td> </tr> <tr> <td>Na</td> <td>0</td> </tr> <tr> <td>Nr</td> <td>80</td> </tr> <tr> <td>Nt</td> <td>0</td> </tr> <tr> <td>Rr</td> <td>4</td> </tr> <tr> <td>Rt</td> <td>0</td> </tr> </tbody> </table>		Seal Status:		Tcm	0	Tiw	0	Ts	21	Na	0	Nr	80	Nt	0	Rr	4	Rt	0
Seal Status:																			
Tcm	0																		
Tiw	0																		
Ts	21																		
Na	0																		
Nr	80																		
Nt	0																		
Rr	4																		
Rt	0																		

7.7.2.5 Multiple Sessions

Multiple Sessions mode differs from Single Sessions mode in that the User can define the number of cycles of interrogation (up to infinite). The User can also define the waiting period between each session.

Number of Cycles: Clicking on the Broadcast Verify Cyclical Interrogation button when there is a positive number in the Number of Cycles window box will cause the system to perform that number of sessions. When Number of Cycles is defined as -1, clicking on the Cyclical Interrogation button will cause the system to perform an unlimited number of sessions.

System Pause: This option allows the User to define a pause between reader sessions.

Loop Through All Readers: When this option is selected, the System Pause acts as a delay between the various readers.

NOTE: When the Loop Through All Readers option is selected, the value in the No. of Cycles window box must be greater than the number of readers defined.

Session # and Reset: The Session # window box shows the sequential number of the next session. Clicking on the Reset button resets this counter.

The cyclical interrogation can be stopped at any time by clicking on the Stop Cycle button. Results of the interrogation appear in a table to the left of the button (See section 4.2.6.)

SS	DBE		OID
WRC	DBC	BMU	
Sleep	UNL		
GE	NB		

S/T	LCO	OID	BF
LBW	RTC	CMF	SRL
D/C	LBE	UNC	HFD
SS	DBE		DRGB
WRC	DB	BMU	
SL	LCK		
GE	NB		
	HRE		

7.7.2.6 _Reading the Results

Hi-G-Tek Data Seal Evaluation Software - [Seal Status]

File Readers Seals Help

Readers Administration Reader Setup Verify & Set All Commands

Reader: 538443782 (Address=1) Seal ID:

Result: 15 seals were found.

Date & Time	# of Events	Seal Stamp	Rdr Addr	Status

Seal ID	Events	Seal Short Status	Session	Rdr
IAHA01052726	2 SVT	LBW DVC SS WRC Sleep GE	5	1
IAHA01052722	2 SVT	LBW DVC SS WRC Sleep GE	5	1
IAHA01052725	2 SVT	LBW DVC SS WRC Sleep GE	5	1
IAHA00001111	0 SVT	LBW DVC SS WRC Sleep GE	5	1
IAHA01052721	2 SVT	LBW DVC SS WRC Sleep GE	5	1
IAHA01052723	2 SVT	LBW DVC SS WRC Sleep GE	5	1

Broadcast Verify

AD: 0

Reader session: 5220 ms

Single Interrogation

Cyclical Interrogation

Addressed Verify and Set

Single Interrogation

Cyclical Interrogation

Set

Stop Cycle

No. of cycles: -1 (Use -1 for infinite)

System pause: 0 seconds ☐ Loop through All Readers

Session: 6

Next session #: 6

Reset

Seal Status:

S/T	LCO	DID	BF
LBW	RTC	CMF	SRL
D/C	LBE	UNC	HFD
SS	DBE	DRGB	
WRC	DB	BMU	
SL	LCK		
GE	NB		
HRE			

Results of the single and cyclical interrogations appear in tables to the left of the interrogation buttons. The information in the table includes the seal ID, the number of events detected, seal stamp, seal short status, the session number which is the number of the session in cyclical interrogation mode and the reader number, the number of the reader being interrogated.


Results are accumulated and can be stored to disk or printed by clicking on the FILE menu button located on the upper left portion of the screen.

Generally, items marked in red indicate errors. Items in red appearing in the Seal Short Status field indicate warnings or error status, while those appearing in gray are normal.

NOTE: To sort the interrogation results by Seal ID number, click on the Seal ID column header. To sort by session number, click on the Session column header.

7.7.3 Addressed Verify Sessions

The Addressed Verify Sessions differ from the Broadcast Verify sessions in that the reader sends interrogation messages to a specified seal. All parameter definitions described in section 4.2. are relevant here as well.




7.7.3.1 Single Session

To initiate an Address Verify Session, enter Reader and Seal ID data in the relevant windows in the upper portion of the screen and click on the required mode of interrogation (single or cyclical). To enter Seal ID automatically, click on the required seal ID that appears in the result table of a broadcast session.




For a single interrogation, click on the Single interrogation button. Results are displayed in the table to the left of the button (1) and in the Seal Status table (2) to the right of the button. Items appearing in red in the Seal Status table indicate error status. Items appearing in black indicate normal status.



7.7.3.2. Multiple Sessions

Multiple Sessions mode differs from Single Sessions mode in that the User can define the number of cycles of interrogation (up to infinite). Results are displayed in the table to the left of the button (1) and in the Seal Status table (2) to the right of the button. Items appearing in red in the Seal Status table indicate error status. Items appearing in black indicate normal status.



Number of Cycles: Clicking on the Addressed Verify and Set Interrogation button when there is a positive number in the Number of Cycles window box will cause the system to perform that number of sessions. When Number of Cycles is defined as -1, clicking on the Cyclical Interrogation button will cause the system to perform an unlimited number of sessions.

System Pause: This option allows the User to define a pause between reader sessions.

Loop Through All Readers: When this option is selected, the System Pause acts as a delay between the various readers.

NOTE: When the *Loop Through All Readers* option is selected, the value in the No. of Cycles window box must be greater than the number of readers interrogated.

Session # and Reset: The Session # and Reset options are not operational in multiple session mode. The system will stop, however, if a number has been entered in the Number of Cycles field.

The cyclical interrogation can be stopped at any time by clicking on the Stop Cycle button. Results of the interrogation are displayed in the Seal Status table at the right of the button, and in the table to the left of the button.

7.7.3.3. Reading the Results

After interrogation the following results are received:

a) In the main information table:

Date and Time, Number of Events, Seal Stamp, Reader Address and Seal Status.

Date & Time	# of Events	Seal Stamp	Rdr Addr	Status
13:32 04/07/2001	1	2044	3	OK
Seal ID	Events	Seal Short Status	Session	Rdr

b) In the Seal Status Table to the right of the buttons. Status events with detected errors are marked in red. Events marked in black are normal.

S/T - Set or tamper

LBW - Low battery warning

O/C - Open/close

SS - Suspended set

WRC - Wire change

SL - Deep sleep mode

GE - General Error

LCO - Life counter = 0

RTC - Real time clock error

LBE - Low bat error

DBE - Data base error

DBC - Data base corrupted

LCK - Locked

NB - New battery

IOD - Illegal org ID



CMF - Command failure

Addressed Verify and Set		Seal Status:			
Single Interrogation		S/T	LCO	OID	BF
Cyclical Interrogation		LBW	RTC	CMF	SRL
Set		O/C	LBE	UNC	HFD
		SS	DBE		ORGB
		WRC	DB	BMU	
		SL	LCK		
		GE	NB		
			HRE		

UNC - Unrecognized Command
 BMU - Burst Mode Unsynchronic
 BF - Buffer Full
 SRL - Scroll Event
 HFD - High frequency disabled
 ORGB - Org ID disabled

7.7.4 SET Sessions

A SET session is used to reset and arm a seal. A SET session can only be applied to a pre-defined seal. To initiate a SET Session, ensure that Seal Wire has been connected. Enter Reader and Seal ID data in the relevant windows in the upper portion of the screen and click on the SET button. Any change in the seal status will display a TAMP message.




7.8. Performing General Commands Cycles.

The main function of the General Commands Cycles is to get acquainted with the system. Access the General Commands screen by clicking on ALL COMMANDS located in the Seal drop down menu. Alternatively, click on the ALL COMMANDS icon or type CNTRL+A.




7.8.1. Selecting a Reader



Select a reader by clicking on the reader drop down list. Click on the appropriate reader to select it.


NOTE: Parameters appearing in the Command Data window may be changed by the User according to the data in the statistical table.

7.8.2. Selecting a Command



Select a command by clicking on the Command Code drop down list, and then by clicking on the appropriate command. Parameters of the selected command appear in the Command Data window below. The number appearing in the fields to the right of the Command Code field is the OPCODE>

7.8.3. Defining Seals



A seal is defined by typing seal ID in the Seals/Tags ID window. The Seal ID number can be found in numeric and barcode format on the seal.

7.8.4. Setting the System Session Duration

The screenshot shows the 'Evaluation Software' interface. At the top, 'Command Code' is set to 'Verify' and '10'. 'Reader' is set to '538443782 (Address=1)'. 'Command Data' is displayed as '00 00 15 29 00 32 00 02 00 00 02 00'. Below this, 'Reader session' is set to '6000 ms' and 'System pause' is set to '0.5 sec'. There are three buttons: 'Command Execution', 'Cyclic Execution', and 'Stop'. A 'Seals/Tags ID' field is empty. A 'Result' field is also empty. At the bottom, there is a 'Response' field.

System session duration is automatically set by the system upon initiation. This may be changed by the User in accordance with specific requirements.

System pause is the pause between sessions when the system is in cyclic mode. This may also be set by the user.

NOTE: Time settings differ according to parameters of the chosen command. If the parameters are changed, the User should try to initiate a session using the default settings. If a Command Fail message is received, the time should be increased. For details regarding calculation of time setting, see paragraph 5.10.

7.8.5. Setting the Command Parameters

This screenshot is identical to the one above, showing the 'Evaluation Software' interface with 'Command Code' set to 'Verify' and '10', 'Reader' set to '538443782 (Address=1)', and 'Command Data' as '00 00 15 29 00 32 00 02 00 00 02 00'. The 'Reader session' is '6000 ms' and 'System pause' is '0.5 sec'. The buttons 'Command Execution', 'Cyclic Execution', and 'Stop' are visible, along with empty fields for 'Seals/Tags ID', 'Result', and 'Response'.

Command parameters are initially determined by the system, and appear in HEX format in the Command Data window box after a Command Code has been selected. If necessary, parameters may be changed in accordance with the User's requirements.

7.8.6. Single or Continuous Settings

Reader session:		6000 ms		Seals/Tags ID:			
Command Execution		Cyclic Execution		Stop			
Response:							
11	48	50	10	10	10	3B	10 08 00 FD 02 02 A2 04 80 00
11	48	50	10	10	10	32	10 08 00 1D 02 02 8A 04 80 00
11	48	50	10	00	04	57	10 08 00 00 02 02 02 04 80 00
11	48	50	10	10	10	38	10 08 00 00 02 02 02 04 80 00
11	48	50	10	10	10	33	10 07 FF 84 02 02 A2 04 80 00
11	48	50	10	10	10	35	10 07 F9 E7 02 02 A2 04 80 00
11	48	50	10	10	10	3A	10 07 FA 2F 02 02 A2 04 80 00

Similar to Single and Cyclic Interrogation, Command Execution and Cyclic Execution perform single and cyclic execution of the chosen command. Results appear in the box below the buttons.

To stop a Cyclic Execution session, click on the Stop button.

7.8.7 Commands

Clicking on one of the commands in the Command Code drop down list initializes that command's Command Screen. Following is a description of the commands:

7.8.7.1. Verify Command

The VERIFY command is used to seek all the seals located in the area that answer the following conditions:

- ORG ID
- ADI
- Department

An explanation of the command parameters can be found in chapter 5.

The significant parameters which accompany the command in the following example are: *(A prior requisite is that the Tiw has been reset)*


- Number of windows: NR=32 hex
- Size of seal transmission window: Ts=29 hex
- Number of seal re-transmissions: Rr=02 hex

Parameters required for reading are:

- Short Status
- Date & Time
- Number of Events
- Version of Firmware
- Long Status
- Seal Stamp

Table 5.4 in chapter 5 defines the Bit mask required for these parameters. Bit Mask=d360 hex.

The initial response string always includes information regarding Number of Bytes, Seal ID and Message Type. A seal may receive a number of identical responses depending on the number of re-transmissions (Rr) defined and the results of conflicts with other seals..



Explanation of Results:

- Number of Bytes=19
- Seal ID=48481010102f
- MSGT=10
- Short Status=00 hex
- Date & Time=33099301 hex
- Number of Events=01 hex
- Version of Firmware=0203 hex
- Long Status=00000000 hex
- Org_ID=123400
- Seal Stamp=701d hex

NOTE: If the Global Parameter is activated, Reader access to some of the parameters will be blocked (see section 5.4).

7.8.7.2. Tamper Command

The TAMPER command is used to find all seals in the Reader's range which indicate a TAMPER status. Command definition and method of execution are identical to those of the VERIFY command described in section 7.8.7.1.

Command Code: Tamper 11 Reader: 553648136 (Address=1)

Command Data: 00 00 00 29 00 32 00 02 00 00 03 20

Reader session: 10000 ms Seals/Tags ID: System pause: 0.5 sec

Command Execution: Command OK.

Response:

10	48	48	10	10	10	2C	11	02	03	80	00	00	00	C1	20	Seal 1
10	48	48	10	10	10	2A	11	02	03	80	00	00	00	19	03	Seal 2
10	48	48	10	10	10	2C	11	02	03	80	00	00	00	C1	20	Seal 1
10	48	48	10	10	10	2A	11	02	03	80	00	00	00	19	03	Seal 2

Labels: Number of bytes, Seal ID, Message Type, Version of Firmware, Long Status, Seal Stamp

7.8.7.3. Addressed Verify

The ADDRESSED VERIFY command is a VERIFY command for a specific seal. In order to affect this command, the Seal ID must be entered into the required field. All other parameters are identical to those of the VERIFY command described in section 7.8.7.1.

Command Code: Addressed Verify 50 Reader: 553648136 (Address=1)

Command Data: 00 00 00 29 00 32 00 02 00 00 03 20

Reader session: 3800 ms Seals/Tags ID: IADA01052716 System pause: 0.5 sec

Command Execution: Command OK.

Response:

10	48	48	10	10	10	2C	50	02	03	80	00	00	00	C1	20	Seal 1
10	48	48	10	10	10	2C	50	02	03	80	00	00	00	C1	20	Seal 2

Labels: Number of Bytes, Seal ID, Msg Type, Version of Firmware, Long Status, Seal Stamp

The number of responses is in accordance with the number of retries requested.

7.8.7.4. SET

The SET command is used to arm or set one or several seals. Up to eight seals can be set in a single session. The SET command cannot be activated if the Seal Wire is not connected to the seal

Seal status will be indicated as closed (OK) or open (FAIL). An example of this can be seen in the RESPONSE window of the illustration below: The first row indicates an open seal and TAMPER status, and therefore a FAIL result, while the second row indicates a closed seal, status OK.

The screenshot displays the 'SET' command configuration and execution results. The 'Command Code' is set to 'Set' with a value of '98'. The 'Reader' is '553648136 (Address=1)'. The 'Command Data' field is empty. The 'Reader session' is '3500 ms'. The 'Seals/Tags ID' field contains 'IADA01052715' and 'IADA01052716'. The 'System pause' is '0.5 sec'. The 'Result' is 'Command OK.'.

The 'Response' window shows two rows of data:

Hex Data	Description
09 48 48 10 10 10 2B 98 A0	Seal 1 - Seal is open; result: fail
09 48 48 10 10 10 2C 18 00	Seal 2 - Seal closed; Seal is sealed with SealWire - result: OK

Annotations for the second row (Seal 2) include:

- Number of bytes: 09
- Seal ID: 48 48 10 10 10
- Msg type: 2C (18=OK)
- Short Status: 18 (A0=tamper+seal open, 00=OK)

Initiation of the SET command deletes all events stored in the EVENTS MEMORY. An additional explanation of this feature can be found in the Hi-G-TEK DataTerminal user manual.

7.8.7.5. Soft SET

Similar to the SET command, the SOFT SET command is used to arm or set one or several seals. Up to eight seals can be set in a single session. The SOFT SET command cannot be activated if the Seal Wire is not connected to the seal.

Seal status will be indicated as closed (OK) or open (FAIL). An example of this can be seen in the RESPONSE window of the illustration below: The first row indicates an open seal and TAMPER status, and therefore a FAIL result, while the second row indicates a closed seal, status OK.

The screenshot displays the 'Soft Set' command configuration and its response. The 'Command Code' is set to 'Soft Set' with a value of '9A'. The 'Reader' is '553648136 (Address=1)'. The 'Command Data' field is empty. The 'Reader session' is '4000 ms' and 'Seals/Tags ID' is 'IADA01052713 IADA01052719'. The 'System pause' is '0.5 sec'. The 'Result' is 'Command OK'.

The 'Response' section shows two rows of data:

Hex Data	Description
09 48 48 10 10 10 29 9A A0	Seal 1 - Seal is open; result: fail
09 48 48 10 10 10 2F 1A 00	Seal 2 - Seal closed; Seal is sealed with SealWire - result: OK

Annotations for the second row (09 48 48 10 10 10 2F 1A 00):

- Number of bytes:** Points to the first byte '09'.
- Seal ID:** Points to the next three bytes '48 48 10'.
- Msg type:** Points to the next three bytes '10 10 10'. Legend: 9A=fail, 1A=OK.
- Short Status:** Points to the last two bytes '1A 00'. Legend: A0=fail, 00=OK.

The main difference between the SOFT SET and SET commands is that the SOFT SET command does not delete previous events stored in the EVENTS MEMORY.

7.8.7.6. Suspended SET

Similar to the SET and SOFT SET commands, SUSPENDED SET is used to arm or set one or several seals. Up to eight seals can be set in a single session. The SUSPENDED SET command can only be initiated if the SealWire has not been connected to the seal.

Seal status will be indicated as closed (OK) or open + suspended set. An example of this can be seen in the RESPONSE window of the illustration below: The first row indicates an open seal that has not been sealed with Seal Wire. The status shows the seal is open + suspended set, waiting to be sealed.

The second row indicates a closed seal, status OK.

In the event of a FAIL status response, the message type response is "99".

The screenshot displays the 'Evaluation Software' interface. At the top, the 'Command Code' is set to 'Suspended Set' with a value of '99'. The 'Reader' is identified as '553648136 (Address=1)'. The 'Command Data' field is empty. The 'Reader session' is '4000 ms' and 'Seals/Tags ID' is 'IADA01052713 IADA01052719'. The 'System pause' is '0.5 sec'. Below these fields are buttons for 'Command Execution', 'Cyclic Execution', and 'Stop'. The 'Result' field shows 'Command OK'.

The 'Response' section shows two rows of data:

Number of bytes	Seal ID	Msg type	Short Status
09 48 48 10 10 10 29 19 B0	Seal 1 - Seal is open; result: waiting to be sealed	19=OK	00=OK B0=Open seal + suspended set
09 48 48 10 10 10 2F 19 00	Seal 2 - Seal closed; Seal is sealed with SealWire - result: OK	19=OK	00=OK B0=Open seal + suspended set

7.8.7.7. Read Data

The READ DATA command allows the Reader to retrieve data from a single seal located in the User Data area.

There are two separate storage areas in each seal, ranging from address 00 to address 53. The first area, from address 00 to 53, is used to store data used by the DataTerminal. The data-range can also be used by the HF system (both reading and writing). Data stored from address 54 to 2K is defined as a free high frequency area.

The illustration below demonstrates the reading of an 18 byte block, starting at address 5. This is shown in comparison to the same DataTerminal user data. The response is shown in both hex and ASCII formats. The largest block size that can be read in one session is 67 bytes.

In the event of a FAIL status response, the message type response is "E3".

The screenshot displays the software interface for sending a 'Read Data' command. The 'Command Code' is set to 'Read Data' (63) and the 'Reader' is '553648136 (Address=1)'. The 'Command Data' field contains '00 05 00 12', which is broken down into 'Base Address 2 Bytes' (00 05) and 'Block Length' (00 12). The 'Seals/Tags ID' is 'IADA01052715'. A warning box states 'Read Data command can only work with one seal ID'. The 'Response' window shows a hex string: '1C 48 48 10 10 10 2B 63 00 11 41 43 45 47 37 38 39 34 35 36 31 38 35 32 37 33 32 31'. Below this, the 'Ascii Data' is shown as 'ACEG78945618527321'. A callout box on the right shows the decoded data: CID: ACEG7894561, CONT: 8527, DEST: 321, and instructions to point the DataTerminal at the seal and press OK to confirm.

The hex and ASCII data in the Response window appears on the DataTerminal screen as follows:

7.8.7.8. Write Data

The WRITE DATA command allows the User to write text in the entire data area. This command can only work with one seal at a time.

There are two separate storage areas in each seal, ranging from address 00 to address 53. The first area, from address 00 to 53, is used to store data used by the DataTerminal. The data-range can also be used by the HF system (reading and writing). Data stored in address 54 to 2K is defined as a free high frequency area.

Maximum block size for a single session is 67 bytes.


The screenshot shows the 'Write Data' command interface. At the top, 'Command Code' is set to 'Write Data' with a value of 68. 'Select Reader' is set to '538443799 (Address=2)'. Below, 'Command Data' is displayed as a sequence of bytes: 11, 00, 00, 01, 23, 45, 67, 89, AB, CD, EF. Arrows point from labels below to specific bytes: 'P#PK' points to the first byte (11), 'Base Address' points to the third byte (00), and 'Data Block' points to the seventh byte (67). A text box on the right states: 'Read Data command can only work with one seal ID'.

The screenshot shows the 'Response' field with the following byte sequence: 09, 00, 00, 00, 00, 00, 01, 68, 00. Arrows point from labels below to specific bytes: 'Number of bytes' points to the first byte (09), 'Seal ID' points to the third byte (00), 'Msgt' points to the seventh byte (01), and 'Short Status' points to the eighth byte (68).

In the event of a FAIL status response, the message type response is "E8".

7.8.7.9. Read Parameter

The READ PARAMETER command enables the User to read parameters from a single seal (see table 5.4).



7.8.7.10. Write Parameter

The WRITE PARAMETER command enables the User to update some of the seal parameters (see table 5.4).

The screen below illustrates an update of the ADI parameter. In the event of a FAIL status response, the message type response is "E9".

Command Code: Write Parameters 69 Select Reader: 538443799 (Address=2)

Command Data: 11 13 00 00 00 11

Duration (mSec): P#PK

Seals/Tags: IAHA01052745

Command Execution: [Progress Bar]

Response: 1C 48 50 10 10 10 49 69 00

Number of bytes: 1C Seal ID: 48 50 10 10 10 10 Msg Type: 49 Short Status: 69 00

Write parameters can only work with one seal at a time

7.8.7.11. Reset Data

The RESET DATA command allows the User to reset all USER DATA from address 00 to address 2K.

Command Code: Reset Data AA Select Reader: 538443799 (Address=2)

Command Data:

Duration (mSec): 3500

Seals/Tags: IAHA01052745

Command Execution: [Progress Bar]

Response: 1C 48 50 10 10 10 49 2A 00

Number of bytes: 1C Seal ID: 48 50 10 10 10 10 Msg Type: 49 Short Status: 2A 00

The Reset Data command works with up to eight seal IDs.
The Reset Data command erases data user space.

In the event of a FAIL status response, the message type is "AA".

7.8.7.12. Deep Sleep

This command sends the seal into DEEP SLEEP mode. Prior to initialization of the command, seal IDs must be defined. This command can work with up to eight seals.

The screenshot shows the 'Deep Sleep' command configuration. The 'Command Code' is set to 'Deep Sleep' with a sub-code of 'B0'. The 'Select Reader' is '538443799 (Address=2)'. The 'Command Data' field is empty. The 'Duration (mSec)' is set to '3500'. The 'Seals/Tags' list contains four IDs: IAHA01052745, IAHA01052731, IAHA01052725, and IAHA01052722. A 'Command Execution' button is visible. The 'Response' field shows the hex string '1C,48 50 10 10 10 49,30,00'. Below this, a diagram maps the response bytes to fields: '1C' to 'Number of bytes', '48' to 'Seal ID', '50' to 'Msg Type', and '10 10 10 49,30,00' to 'Short Status'. A text box on the right states: 'The Deep Sleep command works with up to eight seal IDs. In this example, only one seal enters Deep Sleep mode.'

7.8.7.13. Hard Wakeup

The purpose of this command is to bring seals in DEEP SLEEP mode back to regular operating mode. Only seals that are on the seal ID list and are in DEEP SLEEP mode will be affected. This command can work with up to eight seals at a time.

The screenshot shows the 'Hard Wakeup' command configuration. The 'Command Code' is set to 'Hard Wakeup' with a sub-code of 'B1'. The 'Select Reader' is '538443799 (Address=2)'. The 'Command Data' field is empty. The 'Duration (mSec)' is set to '11000'. The 'Seals/Tags' list contains the same four IDs as the previous screenshot: IAHA01052745, IAHA01052731, IAHA01052725, and IAHA01052722. A 'Command Execution' button is visible. The 'Response' field shows the hex string '1C,48 50 10 10 10 49,31,00'. Below this, a diagram maps the response bytes to fields: '1C' to 'Number of bytes', '48' to 'Seal ID', '50' to 'Msg Type', and '10 10 10 49,31,00' to 'Short Status'. A text box on the right states: 'The Hard Wakeup command can work with up to eight seal IDs. In a continuation of the previous example, as only one seal entered Deep Sleep mode, only that seal can be awakened.'

7.8.7.14. Start Alert Burst

The START ALERT BURST command transforms the seal from its current operating mode to a burst mode of operation. In Alert Burst operating mode, whenever a seal is opened a transmission detailing the opened seal ID is automatically sent.

The START ALERT BURST command can work with up to eight seals. The number of transmissions and the pause between each transmission is predetermined (see table 5.4). The ACK command, detailed in section 7.8.7.18, can be used to stop a burst transmission.

The screenshot displays the 'Start Alert Burst' command configuration in the Hi-G-Tek Evaluation Software. The interface includes the following elements:

- Command Code:** A dropdown menu set to 'Start Alert Burst' with a hex code 'B8' displayed next to it.
- Reader:** A text field containing '553648136 (Address=1)'.
- Command Data:** An empty text field.
- Reader session:** A text field set to '3500' ms.
- Seals/Tags ID:** A text field containing 'IADA01052719' and 'IADA01052713'.
- System pause:** A text field set to '0.5' sec.
- Buttons:** 'Command Execution' (highlighted), 'Cyclic Execution', and 'Stop'.
- Result:** A text field displaying 'Command OK'.
- Response:** A section showing two lines of hex data:
 - Line 1: 09 48 48 10 10 10 2F 3B 00, labeled 'Seal 1'.
 - Line 2: 09 48 48 10 10 10 29 3B 00, labeled 'Seal 2'.
- Annotations:** Arrows point from labels to specific bytes in the response:
 - 'Number of bytes' points to the first byte (09).
 - 'Seal ID' points to the 5th byte (10).
 - 'Msg Type' points to the 7th byte (2F for Seal 1, 29 for Seal 2).
 - 'Short Status' points to the 9th byte (00).

7.8.7.15. Start Alert Burst (all)


Similar to the START ALERT BURST command, the START ALERT BURST (ALL) transforms the seal from its current operating mode to a burst mode of operation. The difference between the two is that in the case of START ALERT BURST (ALL), all seals in the area will be transferred to this mode of operation.

No response is received in the RESPONSE window when the the START ALERT BURST (ALL) command operates in Broadcast mode.

The screenshot shows a software interface for sending a command. At the top, 'Command Code' is set to 'Start Alert Burst (all)' with a value of '38'. 'Select Reader' is set to '538443799 (Address=2)'. Below this, 'Command Data' is an empty text field. 'Duration (mSec)' is set to '3500'. 'Seals/Tags' is an empty text field. A 'Command Execution' button is located below the duration field. At the bottom, the 'Response' area is a large empty box.

7.8.7.16. Stop Alert Burst

The STOP ALERT BURST command stops the seal from working in Alert Burst mode and returns it to the regular mode of operation.



Command Code: Stop Alert Burst B9 Reader: 538443779 (Address=3)

Command Data:

Reader session: 3500 ms Seals/Tags ID: IAHA01052745 System pause: 0.5 s

Command Execution Cyclic Execution Stop

Result: Command D

Response:


09 48 50 10 10 10 49 39 80

The Stop Alert Burst command translates the seal ID into hex file format. (B9=39)

Number of bytes Seal ID Msg Type Short Status

7.8.7.17. Stop Alert Burst (all)

The STOP ALERT BURST (ALL) command differs from the STOP ALERT BURST command only in that it applies to all the seals located in the Reader's vicinity. When the command is transmitted in Broadcast mode, no reply is received in the Response window.



Command Code: Stop Alert Burst (all) B9 Reader: 538443779 (Address=3)

Command Data:

Reader session: 3500 ms Seals/Tags ID: System pause: 0.5 s

Command Execution Cyclic Execution Stop

Result: Command D

Response:

7.8.7.18. Ack Alert

The ACK ALERT command confirms to the seal that its message has been received. After receiving an ACK ALERT command the seal stops transmitting until a new TAMP EVENT is detected.

The ACK ALERT command can work with up to eight seals at a time.

Command Code: Reader:

Command Data:

Reader session: ms Seals/Tags ID:
 System pause: sec

Result:

Response:

09	48	48	10	10	10	2F	3B	00	Seal 1
09	48	48	10	10	10	29	3B	00	Seal 2

Number of bytes Seal ID Msg Type Short Status

7.8.7.19. Read Events

The READ EVENTS command is used to read all events stored in the EVENTS MEMORY.

As is illustrated in the sample screen below, the Command Data field contains two numbers. The first defines the first event to be read, the second number defines the total number of events to be read.

The response is recorded in both hex and text formats. (See table 5.8. for a list of appropriate events.)

The READ EVENTS command is compatible with two event types: short events (8 bytes) and long events (16 bytes). In the sample screen illustration below, events 1 and 5 are long events. All the rest are short events.

Num	Event	Date & Time	Stamp	CRC	Event	Reader ID	Stamp	CRC
01	01	12/08/2001 15:33	4A0D	34	81	000003E8	051B	8D
02	04	14/08/2001 10:43	D12E	EC				
03	05	14/08/2001 10:43	4A0D	45				
04	04	14/08/2001 10:43	906F	EC				
05	0C	14/08/2001 10:43	F906	F4	8C	21000008	051B	D6