



RF - TEST REPORT

- FCC Part 15B -

Type / Model Name : smaXtec Classic Bolus SX.2, smaXtec pH Plus Bolus SX.2

Product Description : Animal sensor with RF interface

Applicant : smaXtec animal care GmbH

Address : Belgiergasse 3

8020 GRAZ, AUSTRIA

Manufacturer : RSG Elotech Elektronische Baugruppen GmbH

Address : Richard-Köcher-Straße 35

07356 BAD LOBENSTEIN, GERMANY

Test Result according to the standards
listed in clause 1 test standards:

POSITIVE

Test Report No. :

T47447-00-01HS

11. May 2021

Date of issue



Deutsche
Akkreditierungsstelle
D-PL-12030-01-03
D-PL-12030-01-04

Contents

1	<u>TEST STANDARDS</u>	3
2	<u>SUMMARY</u>	4
2.1	Summary for all EMC tests	4
2.2	Final assessment	4
3	<u>EQUIPMENT UNDER TEST</u>	5
3.1	Information provided by the Client	5
3.2	Sampling	5
3.3	Photo documentation of the EUT – Detailed photos see ATTACHMENT A	5
3.4	Power supply system utilised	5
3.5	Highest internal frequency	5
3.6	Short description of the Equipment Under Test (EUT)	5
3.7	Variants of the EUT	5
3.8	EUT operation mode	5
4	<u>TEST ENVIRONMENT</u>	6
4.1	Address of the test laboratory	6
4.2	Environmental conditions	6
4.3	Statement of the measurement uncertainty	6
4.4	Conformity Decision Rule	6
4.5	Measurement protocol for FCC and ISED	6
5	<u>TEST CONDITIONS AND RESULTS</u>	10
5.1	Radiated emission < 1 GHz (electric field)	10
5.2	Radiated emission > 1 GHz (electric field)	14
6	<u>USED TEST EQUIPMENT AND ACCESSORIES</u>	17
7	<u>DETAILED MEASUREMENT UNCERTAINTY</u>	18
7.1	Overview	18
7.2	Definitions and symbols	18
7.3	Measurement uncertainty	18

ATTACHMENT A as separate supplement

The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.

1 TEST STANDARDS

The tests were performed according to following standards:

FCC Rules and Regulations Part 15 Subpart B - Unintentional Radiators (September 2020)

Part 15, Subpart B, Section 15.107

AC Line conducted emission

☐ Class A device

☐ Class B device

Part 15, Subpart B, Section 15.109

Radiated emission, general requirements

☐ Class A device

☒ Class B device

ANSI C63.4: 2014

Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz.

CISPR 16-4-2: 2011 + A1: 2014
EN 55016-4-2: 2011

Uncertainty in EMC measurement

ISED Canada Rules and Regulations - Information Technology Equipment (Including Digital Apparatus)

ICES-003, Issue 7, October 15, 2020

AC Power Line Conducted Emissions

☐ Class A device

☐ Class B device

ICES-003, Issue 7, October 15, 2020

Radiated emission

☐ Class A device

☒ Class B device

ANSI C63.4: 2014

Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz.

The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.

2 SUMMARY

2.1 Summary for all EMC tests

FCC Rule Part	ISED Standard	Description
15.107	ICES-003/RSS-Gen	AC power line conducted emissions
15.109	ICES-003/RSS-Gen	Radiated Emissions

Type of test	Test result
Emission:	
A4 Conducted emission (AC mains power / DC power)	not applicable
A5 Radiated emission (< 1 GHz)	passed
SER 3 Radiated emission (> 1 GHz)	passed

A4 - Not applicable, the EUT is battery powered.

2.2 Final assessment

The equipment under test fulfills the requirements cited in clause 1 test standards.

Date of receipt of test sample : acc. to storage records

Testing commenced on : 23 April 2021

Testing concluded on : 26 April 2021

Checked by:

Tested by:

Klaus Gegenfurtner
Teamleader Radio

Hermann Smetana
Radio Team

3 EQUIPMENT UNDER TEST

3.1 Information provided by the Client

Please note, we do not take any responsibility for information provided by the client or his representative which may have an influence on the validity of the test results.

3.2 Sampling

The customer is responsible for the choice of sample. Sample configuration, start-up and operation is carried out by the customer or according to his/her instructions.

3.3 Photo documentation of the EUT – Detailed photos see ATTACHMENT A

3.4 Power supply system utilised

Power supply voltage : 3.0 VDC (Lithium battery)

3.5 Highest internal frequency

Highest internal frequency : 915 MHz

3.6 Short description of the Equipment Under Test (EUT)

The EUT uses a RF interface with LoRa modulation. The EUT is intended to be used inside of a cow in order to monitor the animal's well-being.

Number of tested samples: 1 radiated sample
Serial number: 1B00000006

3.7 Variants of the EUT

There are two variants:

1. smaXtec Classic Bolus SX.2
2. smaXtec pH Plus Bolus SX.2, additional pH sensor.

Note: For testing the smaXtec pH Plus Bolus SX.2 is used.

3.8 EUT operation mode

The equipment under test was operated during the measurement under the following conditions:

- Standby – waiting for activation by magnet, MCU and peripherals powered and in sleep state

4 TEST ENVIRONMENT

4.1 Address of the test laboratory

**CSA Group Bayern GmbH
Ohmstrasse 1-4
94342 STRASSKIRCHEN
GERMANY**

4.2 Environmental conditions

During the measurement the environmental conditions were within the listed ranges:

Temperature: 15 - 35 °C

Humidity: 30 - 60 %

Atmospheric pressure: 86 - 106 kPa

4.3 Statement of the measurement uncertainty

The data and results referenced in this document are true and accurate. It is noted that the expanded measurement uncertainty corresponds to the measurement results from the standard measurement uncertainty multiplied by the coverage factor $k = 2$. The true value is located in the corresponding interval with a probability of 95 %. The measurement uncertainty was calculated for all measurements listed in this test report acc. to CISPR 16-4-2 / 2011 + A1 / 2014 „Uncertainties, statistics and limit modelling – Uncertainty in EMC measurements“ and is documented in the quality system acc. to DIN EN ISO/IEC 17025. For all measurements shown in this report, the measurement uncertainty of the test laboratory, CSA Group Bayern GmbH, is below the measurement uncertainty as defined by CISPR. Therefore, no special measures must be taken into consideration with regard to the limits according to CISPR. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

4.4 Conformity Decision Rule

The conformity decision rule is based on the ILAC G8 published at the time of reporting.

4.5 Measurement protocol for FCC and ISED

4.5.1 General information


CSA Group Bayern GmbH is recognized as wireless testing laboratory under the CAB identifier:

**FCC: DE 0011
ISED: DE0009**

4.5.2 Details of test procedures

4.5.2.1 Conducted emission

Test setup according ANSI C63.4



Description of measurement

The final level, expressed in dB μ V, is arrived at by taking the reading directly from the Spectrum analyser. This level is compared to the limit.

To convert between dB μ V and μ V, the following conversions apply:

$$\text{dB}\mu\text{V} = 20(\log \mu\text{V})$$


$$\mu\text{V} = \text{Inverse log}(\text{dB}\mu\text{V}/20)$$

Conducted emissions on the 50 Hz and/or 60 Hz power interface of the EUT are measured in the frequency range of 150 kHz to 30 MHz. The measurements are performed using a receiver, which has CISPR characteristic bandwidth and quasi-peak detection and a Line Impedance Stabilization Network (LISN) with 50 Ω / 50 μ H (CISPR 16) characteristics. The receiver is protected by means of an impedance matched pulse limiter connected directly to the RF input. Table top equipment is placed on a non-conducting table 80 centimetres above the floor and is positioned 40 centimetres from the vertical ground plane (wall) of the screen room. If the minimum limit margin appears to be less than 20 dB with a peak mode measurement, the emission is re-measured using a tuned receiver with quasi-peak and average detection and recorded on the data sheets.

4.5.2.2 Radiated emission

4.5.2.2.1 OATS1 test site (30 MHz - 1 GHz)

Test setup according ANSI C63.4



Description of measurement

Spurious emission from the EUT is measured in the frequency range of 30 MHz to 1000 MHz using a tuned receiver and appropriate broadband linearly polarized antennas. Measurements between 30 MHz and 1000 MHz are made with 120 kHz/6 dB bandwidth and quasi-peak detection. Table top equipment is placed on a 1.0 X 1.5 metre non-conducting table 80 centimetres above the ground plane. Floor standing equipment is placed directly on the turntable/ground plane. The setup of the equipment under test is established in accordance with ANSI C63.4. The interface cables that are closer than 40 centimetres to the ground plane are bundled in the centre in a serpentine fashion so that they are at least 40 centimetres from the ground plane. Cables to simulators/testers (if used in this test) are routed through the centre of the table and to a screened room located outside the test area.

The antenna is positioned 3 or 10 metres horizontally from the EUT. To locate maximum emissions from the test sample the antenna is varied in height from 1 to 4 metres, measurement scans are made with both horizontal and vertical antenna polarization planes and the EUT is rotated 360 degrees.

The final level is calculated in a calculation sheet by taking the reading from the EMI receiver (Level dBμV) and adding the correction factors and cable loss factor (Factor dB) on to it. The limit is subtracted from this result in order to provide the limit margin listed in the measurement protocols.

Example:

Frequency (MHz)	Reading (dBμV)	+	Correction* (dB/m)	=	Level (dBμV/m)	-	Limit (dBμV/m)	=	Dlimit (dB)
719.0	75.0	+	32.6	=	107.6	-	110.0	=	-2.4


*Correction Factor = Antenna Factor + Cable Attenuation = 30 dB/m + 2.6 dB = 32.6 dB/m

The resolution bandwidth during the measurement is as follows:

30 MHz – 1000 MHz: RBW: 120 kHz

4.5.2.2.2 Anechoic chamber 1, 1000 MHz – 18000 MHz

Test setup according ANSI C63.4



Description of measurement

Radiated emission from the EUT are measured in the frequency range of 1 GHz to the maximum frequency as specified in 47 CFR Part 15 Subpart A section 15.33, using a tuned receiver (spectrum analyser) and appropriate linearly polarized antennas. Table top equipment is placed on a 0.65 X 1.0 metre non-conducting table 80 centimetres above the ground plane. The turntable is fully covered with the appropriate absorber (Type VHP-12).

The interface cables that are closer than 40 centimetres to the ground plane are bundled in the centre in a serpentine fashion, so they are at least 40 centimetres from the ground plane. Measurements are made in both the horizontal and vertical polarization planes in a fully anechoic room using a spectrum analyser set to a peak detector function and a RBW= 1 MHz and VBW = 3 MHz. All tests are performed at a test distance of 3 metres. Hand-held or body-worn devices are rotated around three orthogonal axes in order to determine the position, angle and configuration having the maximum emission. The antenna height is then adjusted from 1 m to 4 m maximizing the measured value. The antenna is mounted to a boresight axis, so the antenna centre always points to the EUT. The turntable is rotated 360° until the spectrum analyser displays the maximum level at the observed frequency. The antenna height is then adjusted from 1 m to 4 m maximizing the measured value. The turntable is re-adjusted to re-affirm the maximum emission value which is then recorded. This procedure is repeated for all frequencies of interest.

The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.

5 TEST CONDITIONS AND RESULTS

5.1 Radiated emission < 1 GHz (electric field)

For test instruments and accessories used see section 6 Part A 5.

5.1.1 Description of the test location

Test location: OATS 1
Test distance: 10 m

5.1.2 Photo documentation of the test setup



The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.



5.1.3 Test result

Frequency range: 30 MHz - 1000 MHz
Min. limit margin -5.9 dB at 42.5 MHz

The requirements are **FULFILLED**.

Remarks: For detailed results, please see the following page(s).

For description of the measurement see 4.5.2.

5.1.4 Test protocol

Operation mode: Standby – waiting for activation by magnet, MCU and peripherals powered and in sleep state Result: passed


Remarks:

Date: 22.4.2021

Tested by: Hermann Smetana

Frequency (MHz)	Reading Vert. (dBµV)	Reading Hor. (dBµV)	Correct. Vert. (dB)	Correct. Hor. (dB)	Level Vert. (dBµV/m)	Level Hor. (dBµV/m)	Limit (dBµV/m)	Dlimit (dB)
42.50	19.6	8.8	14.5	15.3	34.1	24.1	40.0	-5.9
70.90	2.6	10.3	12.6	13.1	15.2	23.4	40.0	-16.6
225.00	1.4	3.2	14.8	14.5	16.2	17.7	46.0	-28.3
766.00	-1.6	-1.9	27.9	28.3	26.3	26.4	46.0	-19.6
852.00	-1.3	-1.2	29.2	29.6	27.9	28.4	46.0	-17.6

The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.



The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.

5.2 Radiated emission > 1 GHz (electric field)

For test instruments and accessories used see section 6 Part SER 3.

5.2.1 Description of the test location

Test location: Anechoic chamber 1
Test distance: 3 m

5.2.2 Photo documentation of the test setup



The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.



5.2.3 Test result

Frequency range: 1000 MHz – 10000 MHz
Min. limit margin 6.0 dB at 9930 MHz

The requirements are **FULFILLED**.

Remarks: For detailed results, please see the following page(s).

For description of the measurement see 4.5.2

5.2.4 Test protocol


Operation mode: Standby – waiting for activation by magnet, MCU and peripherals powered and in sleep state

Result: passed

Remarks:

Date: 23.4.2021

Tested by: Hermann Smetana



The test report merely corresponds to the test sample. It is not permitted to copy extracts of these test results without the written permission of the test laboratory.

6 USED TEST EQUIPMENT AND ACCESSORIES

All test instruments used, in addition to the test accessories, are calibrated and verified regularly.

Test ID	Model Type	Kind of Equipment	Manufacturer	Equipment No.	Next Calib.	Last Calib.	Next Verif.	Last Verif.
SER 2	ESVS 30	EMI Test Receiver	Rohde & Schwarz München	02-02/03-05-006	15/07/2021	15/07/2020		
	VULB 9168	Trilog Broadband Antenn	Schwarzbeck Mess-Elektron	02-02/24-05-005	18/12/2021	18/12/2020		
	NW-2000-NB	RF Cable	Huber + Suhner	02-02/50-05-113				
	KK-EF393/U-16N-21N20 m	RF Cable 20m	Huber + Suhner	02-02/50-12-018				
	KK-SD_7/8-2X21N-33,0M	RF Cable 33 m	Huber + Suhner AG	02-02/50-15-028				
SER 3	ESW26	EMI Test Receiver	Rohde & Schwarz München	02-02/03-17-002	10/02/2022	10/02/2021		
	AMF-6D-01002000-22-10P	RF Amplifier	MITEQ, Inc.	02-02/17-15-004				
	3117	Horn Antenna 1 - 18 GH	EMCO Elektronik GmbH	02-02/24-05-009	18/06/2021	18/06/2020		
	BAM 4.5-P	Antenna Mast	maturo GmbH	02-02/50-17-024				
	NCD	Controller for Antenna M	maturo GmbH	02-02/50-17-025				
	KK-SF106-2X11N-6,5M	RF Cable	Huber + Suhner	02-02/50-18-016				
	BAT-EMC 3.19.1.24	Nexio Software	EMCO Elektronik GmbH	02-02/68-13-001				

7 Detailed measurement uncertainty

7.1 Overview

Measurement instrumentation uncertainty shall be taken into account when determining compliance or non-compliance with a disturbance limit.

The measurement instrumentation uncertainty for a test laboratory shall be evaluated. The standard uncertainty $u(x_i)$ in decibels and the sensitivity coefficient c_i shall be evaluated for the estimate x_i of each quantity. The combined standard uncertainty $u_c(y)$ of the estimate y of the measurand shall be calculated as

$$u_c(y) = \sqrt{\sum_i c_i^2 u^2(x_i)}$$

The expanded measurement instrumentation uncertainty U_{lab} for a test laboratory shall be calculated as $U_{lab} = 2 u_c(y)$

$$U_{lab} = 2 u_c(y)$$

Compliance or non-compliance with a disturbance limit shall be determined in the following manner:

If U_{lab} is less than or equal to U_{cispr} in the table below, then:

- compliance is deemed to occur if no measured disturbance exceeds the disturbance limit;
- non-compliance is deemed to occur if any measured disturbance exceeds the disturbance limit.

If U_{lab} is greater than U_{cispr} in the table below, then:

- compliance is deemed to occur if no measured disturbance, increased by $(U_{lab} - U_{cispr})$, exceeds the disturbance limit.
- non-compliance is deemed to occur if any measured disturbance, increased by $(U_{lab} - U_{cispr})$, exceeds the disturbance limit.

7.2 Definitions and symbols

X_i	Input quantity
x_i	estimate of X_i
$u(x_i)$	standard uncertainty of x_i
c_i	sensitivity coefficient
$u_c(y)$	(combined) standard uncertainty of y
Y	result of a measurement, (the estimate of the measured), corrected for all recognised significant systematic effects
U	expanded uncertainty of y

7.3 Measurement uncertainty

Measurement	U_{lab} [dB]
Conducted disturbance	+ 2.53 / - 2.77
Radiated disturbance (electric field)	
- 10 m test distance	+ 3.16 / - 3.22
- 3 m test distance	+ 3.16 / - 3.22
- Frequency range: 30 MHz – 200 MHz	
Radiated disturbance (electric field)	
- 10 m test distance	+ 4.51 / - 4.51
- 3 m test distance	+ 4.51 / - 4.51
- Frequency range: 200 MHz – 1000 MHz	
Radiated disturbance (electric field)	
- 3 m test distance	+ 5.07 / - 3.70
- Frequency range: 1 GHz – 30 GHz	