



C&I Electric Unit Test Procedure

Revision A

August 22, 2000

Table of Contents

1. Equipment Requirements
2. PCA Sub-Assembly Power Supply Function Test
3. PCA Sub-Assembly RF Communications Test
4. Final Assembly Test
5. Shipping Preparation

1. Equipment Requirements

DVM (Digital voltmeter) with ohm and amp functions.

(Bel MERIT, DX451)

Dual Channel Oscilloscope, 100 MHz, 1GBs

(Tektronix, TDS 220)

Variable/Isolation AC Transformer (VIT), 0-150 Vac, 4 Amp

(Global Specialties, 1504)

PC with Windows 95 Operating System

NCTT, Test software, Version 2.2.0 or later

Field Service Unit with Version 2 Communications Chip (Siliconians) NCI installed

Unit Under Test (UUT), in this case the C&I Electric Unit, Fab. Rev. 5.3 or higher, Firmware Ver. 23 or higher (CnI_V23.HEX, CS = 1c59)

(Innovatec, Relay, Rev. 5.3 or later)

Note: The information in parentheses is a suggested test equipment Manufacturer and Model. Equivalents may be substituted.

2. PCA Sub-Assembly Power Supply and Battery Charger Function Test

The following test in this section is to be performed before the PCA is installed into the Relay Housing.

2.1. Visual Inspection

2.1.1 Verify that the following components are installed with proper orientation / polarity, per assembly drawings: IC's, Transistors, Diodes, Capacitors and Transformer.

2.1.2 Check for solder bridges/solder splash across traces or other conductors.

Pass_____Fail____

2.2. Continuity Tests

2.2.1 Perform continuity test using DVM between metal tabs of U1, D2 and their heatsinks. It should be open circuit or > 10 Meg Ohms for U1 and > 2 Meg Ohms for D2.

Pass_____Fail____

2.2.2 Perform continuity test between input AC line connectors (J3 to J4) and line to ground (J3-H to J1-G and J4-N to J1-G). Should be open circuit or >2 Meg Ohms.

Pass_____Fail____

2.3. Power Supply Test

- 2.3.1. Connect 220 V variac (with isolation transformer and built-in fuse) to the input connector of power supply. Then, slowly bring up the voltage from 0 –85V while monitoring the line current. The line current at 85V should be < 15 mA

Pass_____Fail____

- 2.3.2. Wait few seconds and then verify all LEDs are turned on.

Pass_____Fail____

- 2.3.3. Measure the DC voltage between pins 3 and 21 of NCI connector (J7).

Specification: 5.5 – 5.7V DC.

Pass_____Fail____

- 2.3.4. Measure DC voltage between pins 15 and 21 of NCI connector (J7).

Specification: 5.0 to 5.1 Vdc

Pass_____Fail____

- 2.3.5. Measure DC voltage between pins 17 and 21 of NCI connector (J7).

Specification: 3.5 to 3.7 Vdc

Pass_____Fail____

- 2.3.6. Measure DC voltage between pins 2 and 5 of Molex connector (JP2).

Specification: 12 to 14 Vdc

Pass_____Fail____

- 2.3.7. Disconnect AC Power to UUT and install NCI unit onto the main board. Then, bring the voltage slowly up to 85 Vac and repeat the above steps 4.2- 4.6.

Pass_____Fail____

- 2.3.8. Bring up the AC line voltage slowly from 85 to 265 Vac and repeat the above steps with NCI installed (full-load).

Pass_____Fail____

2.4. Battery Charger Tests

- 2.4.1. Connect battery charger module to C&I main board connector (JP2) and verify that the voltage across BAT + and BAT- on the charger board is set to 6.9 Vdc with 680 Ohm resistor connected across battery leads. Otherwise, adjust R7 Pot to set battery voltage to 6.9Vdc.

Pass__Fail__

- 2.4.2. Connect battery leads to the battery terminals and verify that voltage across battery terminals has reached to 6.9Vdc (fully charged).

Pass__Fail__

- 2.4.3. Disconnect AC power to C&I main board and verify that the LEDs stays on (good indication that UUT is powered by battery only).

Pass__Fail__

- 2.4.4. Remove battery charger module from C&I board with battery leads disconnected from battery terminals. Then connect a dc power supply to battery leads and slowly increase the voltage from 0-6.5 Vdc while monitoring battery status pin (JP1-4). Verify that battery status pin goes high at 5.25 Vdc

Pass__Fail__

- 2.4.5. Then, lower the dc Power supplies voltage slowly and verify that battery status pin (JP1-4) goes low at 5.0Vdc.

Pass__Fail__

3. PCA Sub-Assembly RF Communications Test

3.1. System Hardware Set-up:

3.1.1. Firmware Installation:

Remove AC line voltage from PCA power leads.
Disconnect battery lead from Charger Assembly.
Verify installation of the EPROM with appropriate firmware reversion.

3.1.2. NCI Installation:

Install the NCI with version 2 communications IC (Siliconians) onto the PCA with appropriate antenna, 900 MHz, and 50 Ohms impedance.

3.1.3. Electric Meter RS-232 Communication connection:

Install the Electric Meter to connector J7 as follow:

J7, Pin 12	=	Transmit	(Pin 2 of the DB9 Meter communications cable)
J7, Pin 11	=	Receive	(Pin 3 of the DB9 Meter communications cable)
J7, Pin 10	=	Ground	(Pin 5 of the DB9 Meter communications cable)

Power up the electric meter.

3.1.4. Power on test:

Apply 120V AC line voltage to the PCA power leads, observe for the Status Indicator LEDs, make sure the Green and Yellow LEDs are illuminated.

Reconnect battery lead to Charger Assembly.

Pass__Fail__

3.2. NCTT Setting:

Using the PC, start the NCTT program.

Connect the FSU (Field Service Unit) with version 2 communications IC (Siliconians) to the PC.

Select “Setting” → “Option”:

Serial Port:	=	Select appropriate Serial Port
Wakeup Interval	=	1.25 Sec
Transmit Power	=	28 dBm
Repeat Interval	=	3 Sec (Min.); Unchecked “Random”
NCI Interaction	=	Checked “Automatic”
Conversion Factor	=	0.00001




FIGURE 1

Select “O.K.”, then setting NCTT for C&I Electric Communications:

3.3. C&I Electric Communications and Functional Test

3.3.1. General device setup in NCTT:

For "DEVICE", select "Electric IMU" and "Device ID" select "7"

For "TRANSMIT", select "CHANNEL"= 0 (Default for untested Relay PCA)

The following Transmit options are "unchecked":

"Auto Repeat"

"Scan"

"Wakeup/IMU"

(The untested Relay UUT Communication Channel defaults initially to Channel 0; if unable to establish a communications link between the FSU and the Relay UUT, try to scan all channels for the UUT. Select "Query Serial Numbers" message type, "Select Scan", and press "Transmit", then observe the reply message to identify the Relay communications channel setting.)




FIGURE 2

3.3.1. [Query Serial Number]

Select Query Serial Numbers and select "Transmit!"

Observer for the "Incoming Message", make sure the FSU (Field Service Unit) are communicating with the UUT, and reporting the correct serial number for attached Meter (Either Landis & Gyr, Vectron or applicable Device)




FIGURE 3

METER S/N REPORTED: _____

C&I DEVICE S/N REPORTED: _____

Pass__Fail__

3.3.2. [Set Serial Number]

Set "Electric USN" = Type in the C&I Serial Number then press "Transmit"
Make sure to obtain a "Acknowledgement Message " reply from Incoming Data

Pass__Fail__




FIGURE 4

3.3.3. [Set Communication Parameters]

RF CHANNEL = INITIAL CHANNEL
LCD UPDATE RATE = 1
BLINK RATE = 1

Press “TRANMIT”

Make sure to obtain a “Acknowledgement Message “ reply from Incoming Data

Pass__Fail__




FIGURE 5

3.3.4. [Query Status]

Select “Query Status for Message Type” then press “Transmit”
Make sure to obtain a reply from Incoming Data

Pass__Fail__




FIGURE 6

4. Final Assembly Test

The following test is to be performed after the PCA Assembly has been tested and install into appropriate Relay housing unit.

4.1. General Test

Repeat step 3.3.2. and step 3.3.3., if necessary.

4.1.1. [Set Clock]

Select "Set Clock" message, enter the applicable data then press "Transmit"
Observe "Acknowledged Message " reply in Incoming Data (See Figure 7)

Pass__Fail__

The screenshot displays the 'Network Communications Test Tool' window. The 'Device' section on the left has 'Electric IMU' selected. The 'Message Type' dropdown is set to 'Set Clock'. The 'Transmit' section shows 'Channel' 0, 'Device ID' 7, and the 'Transmit!' button. The 'Outgoing Data' section contains fields for 'Electric SN: Cnl53_0001', '24 Hour Time: 19:00:00', 'Month: August', 'Day: 22', and 'Year: 2000'. Below this is a progress bar and the 'Outgoing Message' hex string: '01 10 00 00 00 07 F9 43 6E 49 35 33 5F 30 30 30 31 19 00 00 08 22 00 04'. The 'Incoming Data' section shows the 'Message Type: Set Clock Acknowledge', 'Unknown Device: 7', and 'Status: Unknown Code'. Below this is the 'Incoming Message' hex string: '01 0B 00 00 00 07 79 43 6E 49 35 33 5F 30 30 30 31 00 04'. The status bar at the bottom indicates 'COM1', 'Wakeup 1.25 s', 'Repeat 3 s', '28 dBm', '8/22/00', and '7:14 PM'.

FIGURE 7

4.1.2. [Query Clock]

Select “Query Clock” message, enter the appropriate Relay Serial Number, and press “Transmit”

Observe “Acknowledged Message” reply in the Incoming Data fields (See Figure 8)
Verify Calendar and Clock settings.

Pass__Fail__




FIGURE 8

4.2. Alarms Test:

4.2.1. [Set Alarm Option]

Electric USN	=	UUT Serial Number
Set Alarm Active Mask	=	FFFFFFFF (8)
Set Alarm Priority Mask	=	FFFFFFFF (8)
Alarm Timer	=	1 (Optional)
Alarm Channel	=	INITIAL CHANNEL (Same as Communications Channel)

Pass__Fail__




FIGURE 9

4.2.2. Tamper Alarm Function Test:

Open the C&I UUT cover (Will release the Tamper Switch)
Verify the Tamper Alarm message is sent

Pass__Fail__




FIGURE 10

4.2.3. Power Failure Alarm Function Test:

Disconnect the ac power to the C&I UUT; verify the Power Failure Alarm Message is sent

Pass__Fail__




FIGURE 11

4.2.4. Power Restore Alarm Function Test

Re-connect the ac power to the C&I UUT; verify the Power Failure Restore Status Report

Pass__Fail__




FIGURE 12

4.2.5. Disabling Alarm Transmit Function Test

Repeat step 4.2.1 and set “Alarm Active Mask” and “Alarm priority Mask” to 0:

Electric USN	=	UUT Serial Number
Set Alarm Active Mask	=	00000000 (8)
Set Alarm Priority Mask	=	00000000 (8)
Alarm Timer	=	1 (Optional)
Alarm Channel	=	INITIAL CHANNEL (Same as Communications Channel)

4.2.5.1. Activate “Tamper” switch; observe for none alarm send message transmits.

4.2.5.2. Disconnect AC power; observe for none alarm send message transmits.

4.2.5.3. Reconnect AC powers; observe for none alarm send message transmits.

Pass__Fail__




FIGURE 13

4.3. Actuators Test:

4.3.5. [Set Actuator 1 Output]

Type in Electric USN = C&I UUT Serial Number
Set Actuator 1 = ON
Set Actuator 2 = OFF

Press “Transmit”

Make sure to obtain a “Acknowledgement Message “ reply from Incoming Data

Use DVM to verify between Pin 1, J10 (Actuator 1 Output) and Pin 3, J10 (Actuator 1) Common are “Closed”

Use DVM to verify between Pin 2, J10 (Actuator 2 Output) and Pin 4, J10 (Actuator 2) Common are “Open”

Pass__Fail__




FIGURE 13

4.3.6. [Set Actuator 2 Output]

Type in Electric USN = C&I UUT Serial Number
Set Actuator 1 = OFF
Set Actuator 2 = ON

Press “Transmit”

Make sure to obtain a “Acknowledgement Message “ reply from Incoming Data

Use DVM to verify between Pin 1, J10 (Actuator 1 Output) and Pin 3, J10 (Actuator 1) Common are “Open”

Use DVM to verify between Pin 2, J10 (Actuator 2 Output) and Pin 4, J10 (Actuator 2) Common are “Close”

Pass__Fail__




FIGURE 14

4.4. Battery Power Sustain Test:

4.4.5. Disconnect the ac power to the C&I UUT

4.4.6. [Query Serial Number]

Verify to obtain the correct Serial Number report for the C&I UUT.

Pass__Fail__




FIGURE 15

5. Shipping Preparation:

- **IMPORTANT!:**

Make sure to disconnect the hook-up wire from the Battery charger to the Positive (+) terminal of the battery!

Battery Disconnect Check: Initial_____

- Mechanical Inspection:
Inspect all hardware, screw and nut, wires and cables for proper fitting.
- Cosmetic Inspection:
Inspect for cosmetic defective.