

Device: Carbon Monoxide Detector

Model No.: COZW60R0-29

FCC ID: P27-COZW60R0

Input: 3V 

CO Sensitivity: 70, 150, 400 PPM

CONFORMS TO UL STD 2075

Owner's Manual at help.ADT.com

TEST ALARM MONTHLY

ADT



S/N: YYMMDR7XXXXXX

SD0 Made in Taiwan



Intertek
XXXXXXX



PIN CODE: XXXXX



Mfg Date: YYYY/MMM
Replace By: YYYY+10/MMM

WARNING

Carbon Monoxide cannot be seen or smelled.

If alarm sounds:

1. Operate TEST/SILENCE button.
2. Call your emergency services (Fire dept or 911).
3. Immediately move to fresh air- outdoor or by an open door or window.

WARNING

Use Only Lisun/Kinetik CR123A Lithium Batteries. Use of a different battery will have a detrimental effect on CO alarm operation. Lithium battery may present risk of fire or explosion. Remove all old batteries, wait 10 seconds, then insert two new batteries.

