

MODEL. NO. SD4-SS PHOTO-ELECTRONIC DETECTION PRINCIPLE
FCC ID: PPJSD4SS418 418MHz WIRELESS SINGLE STATION SMOKE ALARM
FACTORY SENS. 1.12%-3.33% PER FT. OBSCURATION 85DB SOUNDER

WARNING: USE ONLY BATTERIES SPECIFIED IN MARKING. USE OF
A DIFFERENT BATTERY WILL HAVE A DETRIMENTAL
EFFECT ON THE SMOKE ALARM OPERATION. **REPLACEMENT BATTERY USE PANA-
SONIC CR123A / DURACELL DL123A ONLY.** CONSTANT EXPOSURES TO HIGH OR
LOW TEMPERATURES OR HIGH HUMIDITY MAY REDUCE BATTERY LIFE. REFER
TO INSTALL GUIDE 108101 FOR INSTALLATION, MAINTENANCE, OPERATING, AND
SAFETY INFORMATION/INSTRUCTIONS. INSTALL GUIDE SHOULD BE READ AND RE-
TAINED. GREEN LED BLINKS EVERY 10 SECONDS - NORMAL (STANDBY), HORN OFF.
RED LED BLINKS EVERY 1 SECOND - SMOKE ALARM, HORN TEMPORAL PATTERN.
RED LED BLINKS EVERY 45 SECONDS - LOW BATTERY, HORN CHIRPS EVERY 45
SECONDS LED BLINKS FOR 7 DAYS. **MAINTENANCE NOTE:** POWER MUST BE RE-
MOVED FROM THE DETECTOR BEFORE PERFORMING MAINTENANCE OF ANY KIND
BY REMOVING THE DETECTOR'S BATTERY. TEST THE DETECTOR AFTER INSTALLA-
TION, WEEKLY AND AFTER CLEANING (VACUUMING) TO CHECK ALARM FUNCTIONS.
THIS ALARM CAN ONLY BE USED WITH SILENT CALL SK2-SS & WC08-SS RECEIV-
ERS. THE BATTERY WARRANTY PERIOD IS NOT A PERFORMANCE CLAIM OF THIS
DETECTOR.

FOR WARRANTY CLAIMS/REPAIRS SEND TO MANUFACTURER:
SILENT CALL COMMUNICATIONS 5095 WILLIAMS LAKE RD, WATERFORD, MI 48329
CALL 800-572-5227 OR VISIT SILENTCALL.COM

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:
(1) This device may not cause harmful interference, and
(2) This device must accept any interference received, including interference that may cause undesired operation.