

POWER

COMM. ACTIVE  
WHEN FLASHINGCURTAILMENT  
IN EFFECTCURTAILMENT  
OVERRIDE

## Invensys RF Load Control Meter Model vLR1

Style: vL02606100

**CAUTION** - Risk of Electric Shock -  
Disconnect power supply before servicing.

Ratings: 120 VAC, 30 Amps Resistive, Single Phase  
120 VAC, 1 HP, Single Phase

Raintight enclosure when mounted with any of the following three fitting installations:

| Fitting Assy. | Part #        | Locking Nut | Part #   | O-Ring  | Part #   |
|---------------|---------------|-------------|----------|---------|----------|
| Sealcon       | CD16AA-BK     | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |
| Sealcon       | ED16AA-BK     | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |
| Hummel        | 1.587.1602.01 | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |

Do not attach conduit above this line.



**LISTED**  
CLOSED ENERGY  
MANAGEMENT  
EQUIPMENT  
42EB

### FCC ID: QI2-EMSL-200

This device complies with Part 15 of the FCC rules. Operation is subject to the following two conditions:  
(1) this device may not cause harmful interference, and  
(2) this device must accept any interference received, including interference that may cause undesired operation.


**CAUTION:** Bonding between conduit connections is not automatic and must be provided as a part of the installation.

For supply connections, use No. 14 to 10 AWG wires rated at least 90°C (194°F)

Use copper conductors only. Torque to 16 in-lbs.

Install all wiring in accordance with National and Local codes.

### Typical Wiring



POWER

COMM. ACTIVE  
WHEN FLASHINGCURTAILMENT  
IN EFFECTCURTAILMENT  
OVERRIDE

## Invensys RF Load Control Meter Model vLR1

Style: vL02606200

### CAUTION - Risk of Electric Shock -

Disconnect power supply before servicing. More than one disconnect switch may be required to de-energize the equipment before servicing.

Ratings: 240 VAC, 30 Amps Resistive, Single Phase  
240 VAC, 2 HP, Single Phase

Raintight enclosure when mounted with any of the following three fitting installations:

| Fitting Assy. | Part #        | Locking Nut | Part #   | O-Ring  | Part #   |
|---------------|---------------|-------------|----------|---------|----------|
| Sealcon       | CD16AA-BK     | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |
| Sealcon       | ED16AA-BK     | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |
| Hummel        | 1.587.1602.01 | Sealcon     | NP-16-BK | Sealcon | OR-16-BN |

Do not attach conduit above this line.



**LISTED**  
CLOSED ENERGY  
MANAGEMENT  
EQUIPMENT  
42EB

### FCC ID: QI2-EMSL-200

This device complies with Part 15 of the FCC rules. Operation is subject to the following two conditions:  
(1) this device may not cause harmful interference, and  
(2) this device must accept any interference received, including interference that may cause undesired operation.

**CAUTION:** Bonding between conduit connections is not automatic and must be provided as a part of the installation.

For supply connections, use No. 14 to 10 AWG wires rated at least 90°C (194°F)

Use copper conductors only. Torque to 16 in-lbs.

Install all wiring in accordance with National and Local codes.

## Typical Wiring

