

Addendum to 30462675.001

EUT Name: UHF Data Transceiver

EUT Model: TX3

FCC Part 90

Prepared for:

Joe Winkler
Everyday Wireless LLC
2033 Penn Avenue
West Lawn, PA 19609
Tel: (610) 678-2100
Fax: (610) 678-2193

Prepared by:

TUV Rheinland of North America
762 Park Avenue
Youngsville, NC 27596
Tel: (919) 554-3668
Fax: (919) 554-3542
<http://www.tuv.com/>

Report/Issue Date: 10 December 2004

Report Number: 30462675.002

Statement of Compliance

Manufacturer: Everyday Wireless LLC
2033 Penn Avenue
West Lawn, PA 19609
(610) 678-2100
Requester / Applicant: Joe Winkler
Name of Equipment: UHF Data Transceiver
Model No. TX3
Type of Equipment: Intentional Radiator
Class of Equipment: N/A
Application of Regulations: FCC Part 90
Test Dates: 28 October 2004 to 8 December 2004

Guidance Documents:

Emissions: FCC 47 CFR Part 90

Test Methods:

Emissions: ANSI/TIA-603-B-2002

The electromagnetic compatibility test and documented data described in this report has been performed and recorded by TUV Rheinland of North America, in accordance with the standards and procedures listed herein. As the responsible authorized agent of the EMC laboratory, I hereby declare that a sample of one, of the equipment described above, has been shown to be compliant with the EMC requirements of the stated regulations and standards based on these results. If any special accessories and/or modifications were required for compliance, they are listed in the Executive Summary of this report.

This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report contains data that are not covered by NVLAP accreditation. This report shall not be reproduced except in full, without the written authorization of the laboratory.

NVLAP Signatory

10 December 2004

Date

Table of Contents

1	EXECUTIVE SUMMARY.....	4
1.1	SCOPE	4
1.2	PURPOSE.....	4
2	LABORATORY INFORMATION	4
2.1	ACCREDITATIONS & ENDORSEMENTS	4
2.2	TEST FACILITIES.....	5
2.3	MEASUREMENT UNCERTAINTY.....	5
2.4	CALIBRATION TRACEABILITY	6
3	TEST REPORT INFORMATION	7
3.6	2.1053 FIELD STRENGTH OF SPURIOUS RADIATION	7
3.7	2.1055 FREQUENCY STABILITY	10
4	TEST EQUIPMENT USE LIST	12
5	TEST SETUP PHOTOS.....	13

1 Executive Summary

1.1 Scope

This report is intended to document the status of conformance with the requirements of the FCC Part 90 based on the results of testing performed on *28 October 2004* through *8 December 2004* on the *UHF Data Transceiver* Model No. *TX3* manufactured by Everyday Wireless LLC. This report only applies to the specific samples tested under the stated test conditions. It is the responsibility of the manufacturer to assure that additional production units of this model are manufactured with identical or EMI equivalent electrical and mechanical components. This report is further intended to document changes and modifications to the EUT throughout its life cycle. All documentation will be included as a supplement.

1.2 Purpose

Testing was performed to evaluate the EMC performance of the EUT in accordance with the applicable requirements, procedures, and criteria defined in the application of regulations and application of standards listed in this report.

2 Laboratory Information

2.1 Accreditations & Endorsements

2.1.1 US Federal Communications Commission

TUV Rheinland of North America at the 762 Park Ave. Youngsville, N.C 27596 address is accredited by the commission for performing testing services for the general public on a fee basis. This laboratory test facilities have been fully described in reports submitted to and accepted by the FCC (Registration No 90552 and 100881). The laboratory scope of accreditation includes: Title 47 CFR Part 15, 18, and 90. The accreditation is updated every 3 years.

2.1.2 NIST / NVLAP

TUV Rheinland of North America is accredited by the National Voluntary Laboratory Accreditation Program, which is administered under the auspices of the National Institute of Standards and Technology. The laboratory has been assessed and accredited in accordance with ISO Guide 17025:1999 and ISO 9002 (Lab code 200094-0). The scope of laboratory accreditation includes emission and immunity testing. The accreditation is updated annually.

2.1.3 Japan - VCCI

The Voluntary Control Council for Interference by Information Technology Equipment (VCCI) is a group that consists of Information Technology Equipment (ITE) manufacturers and EMC test laboratories. The purpose of the Council is to take voluntary control measures against electromagnetic interference from Information Technology Equipment, and thereby contribute to the development of a socially beneficial and responsible state of affairs in the realm of Information Technology Equipment in Japan. TUV Rheinland of North America at the 762 Park Ave. Youngsville, N.C 27596 address has been assessed and

approved in accordance with the Regulations for Voluntary Control Measures. (Registration No. R-1174, R-1679, C-1790 and C-1791).

2.1.4 Acceptance By Mutual Recognition Arrangement

The United States has an established agreement with specific countries under the Asia Pacific Laboratory Accreditation Corporation (APLAC) Mutual Recognition Arrangement. Under this agreement, all TUV Rheinland of North America at the 762 Park Ave. Youngsville, N.C 27596 address test results and test reports within the scope of the laboratory NIST / NVLAP accreditation will be accepted by each member country.

2.2 Test Facilities

All of the test facilities are located at 762 Park Ave., Youngsville, North Carolina 27596, USA.

2.2.1 Emission Test Facility

The Open Area Test Site and AC Line Conducted measurement facility used to collect the radiated and conducted data has been constructed in accordance with ANSI C63.7:1992. The site has been measured in accordance with and verified to comply with the theoretical normalized site attenuation requirements of ANSI C63.4:1992, at a test distance of 3 and 10 meters. This site has been described in reports dated May 12, 1997, submitted to the FCC, and accepted by letter dated June 25, 1997 (31040/SIT 1300F2). The site is listed with the FCC and accredited by NVLAP (code 200094-0). The 5m semi-anechoic chamber used to collect the radiated data has been verified to comply with the theoretical normalized site attenuation requirements of ANSI C63.4:1992, at a test distance of 3 meters. A report detailing this site can be obtained from TUV Rheinland of North America.

2.2.2 Immunity Test Facility

ESD, EFT, Surge, PQF: These tests are performed in an environmentally controlled room with a 3.7m x 3.7m x 3.175mm thick aluminum floor connected to PE ground. For ESD testing, tabletop equipment is placed on an insulated mat with a surface resistivity of 10^9 Ohms/square on a 1.6m x 0.8m x 0.8m high non-conductive table with a 3.175mm aluminum top (Horizontal Coupling Plane). The HCP is connected to the main ground plane via a low impedance ground strap through two 470 k Ω resistors. The Vertical Coupling Plane consists of an aluminum plate 50cm x 50cm x 3.175mm thick. The VCP is connected to the main ground plane via a low impedance ground strap through two 470 k Ω resistors. For each of the other tests, the HCP is removed.

RF Field Immunity testing is performed in a 7.3m x 3.7m x 3.2m anechoic chamber.

RF Conducted and Magnetic Field Immunity testing is performed on a 4.9m x 3.7m x 3.175mm thick aluminum ground plane which is connected to one end of the anechoic chamber.

All test areas allow a minimum distance of 1 meter from the EUT to walls or conducting objects.

2.3 Measurement Uncertainty

Two types of measurement uncertainty are expressed in this report, per *ISO Guide To The Expression Of Uncertainty In Measurement*, 1st addition, 1995.

The Combined Standard Uncertainty is the standard uncertainty of the result of a measurement when that result is obtained from the values of a number of other quantities, equal to the positive square root of a

sum of terms, the terms being the variances or co-variances of these other quantities weighted according to how the measurement result varies with changes in these quantities. The term standard uncertainty is the result of a measurement expressed as a standard deviation.

The Expanded Uncertainty defines an interval about the result of a measurement that may be expected to encompass a large fraction of the distribution of values that could reasonably be attributed to the measurand. The fraction may be viewed as the coverage probability or level of confidence of the interval.

The test system for conducted emissions is defined as the LISN, spectrum analyzer, coaxial cables, and pads. The test system for radiated emissions is defined as the antenna, spectrum analyzer, pre-amplifier, coaxial cables, and pads. The test system for radiated immunity is defined as the antenna, amplifier, cables, signal generator field probe and spectrum analyzer. The test system for conducted immunity is defined as the coupling/decoupling device, amplifier, cables, signal generator and spectrum analyzer. The test system for voltage variations and interruptions immunity is defined as the AC power source and the interruptions generator. The test system for electrical fast transient immunity is defined as the AC power output source and the fast transient generator. The test system for lightning surge immunity is defined as the AC power output source and the lightning surge generator. The test system for electrostatic discharge immunity is defined as the air and contact discharge generators. The test system for power frequency magnetic field immunity is defined as the AC voltage source. The test system for the damped oscillatory wave immunity is defined as the AC power output source and the oscillatory wave generator. The test system for harmonic current and voltage flicker test is defined as the AC power source and the detection devices. The conducted emissions test system has a combined standard uncertainty of ± 1.2 dB. The radiated emissions test system has a combined standard uncertainty of ± 1.6 dB. The radiated immunity test system has a combined standard uncertainty of ± 2.7 dB. The conducted immunity test system has a combined standard uncertainty of ± 1.5 dB. The voltage variations and interruptions immunity test system has a combined standard uncertainty of ± 4.3 dB. The electrical fast transients immunity test system has a combined standard uncertainty of ± 5.8 dB. The lightning surge immunity test system has a combined standard uncertainty of ± 8.0 dB. The electrostatic discharge immunity test system has a combined standard uncertainty of ± 4.1 dB. The power frequency magnetic field immunity test system has a combined standard uncertainty of ± 0.58 dB. The damped oscillatory wave immunity test system has a combined standard uncertainty of ± 8.7 dB. The harmonic current and voltage flicker test system has a combined standard uncertainty of ± 11.6 dB. The expanded uncertainty at a level of 95% confidence is obtained by multiplying the combined standard uncertainty by a coverage factor of 2. Compliance criteria are not based on measurement uncertainty.

2.4 Calibration Traceability

All measurement instrumentation is traceable to the National Institute of Standards and Technology (NIST). Measurement method complies with ANSI/NCSL Z540-1-1994 and ISO Guide 17025:1999.

3 Test Report Information

3.6 2.1053 Field Strength of Spurious Radiation

NAME OF TEST: RADIATED SPURIOUS EMISSIONS 450 MHz

REQUIREMENTS: Emissions must be $50 + 10\log(P_o)$ dB below the mean power output of the transmitter.

$50 + 10\log(45) = 66.53 \text{ dBc}$

DATA:

Emission Frequency MHz	Ant. Polarity	Corrected EUT Signal Reading	Coax Loss (dB)	Substitution Antenna (dBd)	dB Below Carrier (dBc)
450.00		46.73			
900.00	H	-58.09	2.82	1.21	104.82
1350.00	V	-57.48	3.44	7.93	104.21
1800.00	V	-49.39	4.08	8.62	96.12
2250.00	V	-40.70	4.62	9.05	87.43
2700.00	H	-37.34	5.08	9.40	84.07
3150.00	H	-40.78	5.54	9.55	87.51
3600.00	H	-36.72	5.90	9.80	83.45
4050.00	H	-42.49	6.27	9.57	89.22
4500.00	H	-38.66	6.62	11.10	85.39

NAME OF TEST: RADIATED SPURIOUS EMISSIONS 463.7 MHz
REQUIREMENTS: Emissions must be $50 + 10\log(P_o)$ dB below the
mean power output of the transmitter.
 $50 + 10\log(45) = 66.53$ dBc

DATA:


Emission Frequency MHz	Ant. Polarity	Corrected EUT Signal Reading	Coax Loss (dB)	Substitution Antenna (dBd)	dB Below Carrier (dBc)
463.70		46.46			
927.40	H	-55.62	2.82	1.23	102.08
1391.10	V	-58.14	3.51	8.09	104.60
1854.80	V	-49.45	4.15	8.64	95.91
2318.50	H	-36.31	4.71	9.15	82.77
2782.20	V	-38.33	5.12	9.46	84.79
3245.90	H	-42.96	5.59	9.65	89.42
3709.60	H	-43.26	6.03	9.69	89.72
4173.30	H	-41.21	6.30	9.99	87.67
4637.00	H	-35.12	6.75	10.96	81.58

NAME OF TEST: RADIATED SPURIOUS EMISSIONS 470 MHz
 REQUIREMENTS: Emissions must be $50 + 10\log(P_o)$ dB below the
 mean power output of the transmitter.
 $50 + 10\log(45) = 66.53 \text{ dBc}$

DATA:

Emission Frequency MHz	Ant. Polarity	Corrected EUT Signal Reading	Coax Loss (dB)	Substitution Antenna (dBd)	dB Below Carrier (dBc)
470.00		46.54			
940.00	H	-48.93	2.86	1.06	95.47
1410.00	V	-59.79	3.54	8.16	106.33
1880.00	V	-48.61	4.20	8.65	95.15
2350.00	V	-38.67	4.77	9.19	85.21
2820.00	V	-40.61	5.21	9.46	87.15
3290.00	H	-43.19	5.58	9.69	89.73
3760.00	V	-42.52	5.99	9.64	89.06
4230.00	H	-40.60	6.46	10.18	87.14
4700.00	H	-36.36	6.88	10.90	82.90

Method of Measuring Radiated Spurious Emissions



Method of Measurements: The tabulated data shows the results of the radiated field strength emissions test. The spectrum was scanned from 30 MHz to at least the tenth harmonic of the fundamental. This test was conducted per TIA/EIA STANDARD 603 using the substitution method.

3.7 2.1055 Frequency Stability

90.213(a)(1)

Temperature and voltage tests were performed to verify that the frequency remains within the .00015%, 1.5 ppm specification limit, for 25 kHz spacing & 0.00025% for 12.5 KHz spacing. The test was conducted as follows: The transmitter was placed in the temperature chamber at 25° C and allowed to stabilize for one hour. The transmitter was keyed ON for one minute during which four frequency readings were recorded at 15 second intervals. The worse case number was taken for temperature plotting. The assigned channel frequency was considered to be the reference frequency. The temperature was then reduced to -30°C after which the transmitter was again allowed to stabilize for one

hour. The transmitter was keyed ON for one minute, and again frequency readings were noted at 15 second intervals. The worst-case number was recorded for temperature plotting. This procedure was repeated in 10° increments up to + 50 degrees C. Readings were also taken at minus 15% of the battery voltage of 13.6 VDC, which we estimate to be the battery endpoint.

MEASUREMENT DATA:


Temperature	Frequency	PPM
Reference	450.000 005	0.0
-30	450.000 085	0.18
-20	449.999 860	-0.32
-10	450.000 260	0.57
0	450.000 035	0.07
+10	450.000 180	0.39
+20	450.000 145	0.31
+30	450.000 050	0.10
+40	450.000 035	0.07
+50	450.000 050	0.10
-15% of Battery End-Point VDC	450.000 021	0.04

4 Test Equipment Use List

Equipment	Manufacturer	Model #	Serial/Inst #	Last Cal dd/mm/yy	Next Cal dd/mm/yy
Amplifier, preamp	Agilent Technologies	8449B	3008A01480	10-May-04	10-May-05
Ant. Log Periodic	AH Systems	SAS-516	133	19-Jan-04	19-Jan-05
Antenna Horn	EMCO	3115	2236	14-Oct-04	14-Oct-05
Cable, Coax	Andrew	FSJ1-50A	031	16-Jan-04	16-Jan-05
Cable, Coax	Andrew	FSJ1-50A	034	19-Jan-04	19-Jan-05
Cable, Coax	Thermax	RG 142 B/U	035	19-Jan-04	19-Jan-05
Cable, Coax	Andrew	FSJ1-50A	042	15-Jan-04	15-Jan-05
Cable, Coax	Andrew	FSJ1-50A	045	15-Jan-04	15-Jan-05
Chamber, Semi-Anechoic	Braden Shielding	5 meter	A67631	27-Jan-04	27-Jan-05
Spectrum Analyzer	Agilent Tec.	E7405A	US39440157	11-Aug-04	11-Aug-05
Ant. Dipole Set BL 1-4	EMCO	3121C	9302-914	20-Oct-04	20-Oct-05
Antenna Horn	EMCO	3115	5770	11-Mar-04	11-Mar-05
Meter, Multi	Fluke	179	82940101	27-Sept-04	27-Sept-05
Meter, RF Power	Boonton	4231A	66801	22-Aug-04	22-Aug-05
Meter, Temp/Humid/Barom	Fisher	02-400	01	13-Aug-04	13-Aug-05
Oscilloscope	Tektronix	TDS 680B	B030230	14-Feb-04	14-Feb-05
Power Sensor	Boonton	51075	32091	22-Aug-04	22-Aug-05
Power Sensor	Boonton	51011-EMC	32203	22-Aug-04	22-Aug-05
Power Supply, DC	Lambda	LK343A FM	D24270	CNR II	CNR II
Temperature Chamber	Espec	ECT-2	052525	CNR II	CNR II

* Calibration of equipment past due for re-calibration will be performed expeditiously. If any equipment is found to be out of tolerance at that time, affected customers will be notified accordingly.

5 Test Setup Photos



Radiated Spurious Emissions



Frequency Stability