Measurement Protocol

Measurement Object	FR1 n66_40 _DFT-s-OFDM_EVS NB 24.4kbps_CH349000
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:49
Responsible Person	audio

Overall Receive Delay NB, Index: 1 3
5.1a Receive Volume Control Performance 8N NB, Index: 1 3
5.1b Receive Volume Control Performance 2N NB, Index: 1 4
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 5
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 6
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 8
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 10
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 11
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 11
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 12
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 14
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 16
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 18
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 19
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 19
5.3 Frequency Response 8N FF HANB, Index: 1 20
5.3 Frequency Response 8N DF HANB, Index: 1 21
5.3 Frequency Response 2N FF HANB, Index: 1 21
5.3 Frequency Response 2N DF HANB, Index: 1 22

Overall Receive Delay NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	144.6 ms

2024/5/16 18:41 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	88.17 dB[SPL]	80.36%	18.17 dB[SPL]	Ok

Ok

2024/5/16 18:41 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	82.51 dB[SPL]	80.08%	12.51 dB[SPL]	Ok

Ok

2024/5/16 18:56 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.85 dB (3.22%) Ok

Ok

2024/5/16 18:42 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.26 dB (3.44%) Ok

Ok

2024/5/16 18:42 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.57 dB (3.73%) Ok

Ok

2024/5/16 18:42 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.28 dB (1.93%) Ok

Ok

2024/5/16 18:43 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.98 dB (4.48%) Ok

Ok

2024/5/16 18:43 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.76 dB (3.65%) Ok

Ok

2024/5/16 18:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.91 dB (3.59%) Ok

Ok

2024/5/16 18:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 27.17 dB (4.38%) Ok

Ok

2024/5/16 18:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 38.63 dB (1.17%) Ok

Ok

2024/5/16 18:45 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 41.95 dB (0.80%) Ok

Ok

2024/5/16 18:45 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	400Hz	29.85 dB
2	500Hz	29.26 dB
3	630Hz	28.57 dB
4	800Hz	34.28 dB
5	1000Hz	26.98 dB
6	1250Hz	28.76 dB
7	1600Hz	28.91 dB
8	2000Hz	27.17 dB
9	2500Hz	38.63 dB
10	3150Hz	41.95 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.98dB at 1000Hz.

2024/5/16 18:45 ACQUA

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.36 dB (3.41%) Ok

Ok

2024/5/16 18:57 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.67 dB (3.29%) Ok

Ok

2024/5/16 18:57 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.91 dB (3.59%) Ok

Ok

2024/5/16 18:58 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.73 dB (1.83%) Ok

Ok

2024/5/16 18:58 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.70 dB (4.62%) Ok

Ok

2024/5/16 18:58 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.37 dB (3.81%) Ok

Ok

2024/5/16 18:59 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.56 dB (3.73%) Ok

Ok

2024/5/16 18:59 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.29 dB (4.85%) Ok

Ok

2024/5/16 19:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 38.23 dB (1.23%) Ok

Ok

2024/5/16 19:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 41.87 dB (0.81%) Ok

Ok

2024/5/16 19:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	400Hz	29.36 dB

2	500Hz	29.67 dB
3	630Hz	28.91 dB
4	800Hz	34.73 dB
5	1000Hz	26.70 dB
6	1250Hz	28.37 dB
7	1600Hz	28.56 dB
8	2000Hz	26.29 dB
9	2500Hz	38.23 dB
10	3150Hz	41.87 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.29dB at 2000Hz.

2024/5/16 19:00 ACQUA

5.3 Frequency Response 8N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.51 dB at 1216.1 Hz Ok

Ok

2024/5/16 18:46 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.10 dB at 873.9 Hz Ok

Ok

2024/5/16 18:46 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.57 dB at 305.9 Hz Ok

Ok

2024/5/16 19:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.21 dB at 305.9 Hz Ok

Ok

2024/5/16 19:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n66_40 _DFT-s-OFDM_EVS WB 128kbps_CH349000
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:49
Responsible Person	audio

Overall Receive Delay WB, Index: 1 3
5.1a Receive Volume Control Performance 8N WB, Index: 1 3
5.1b Receive Volume Control Performance 2N WB, Index: 1 4
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 5
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 6
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 8
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 10
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 12
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 14
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 15
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 15
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 16
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 18
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 20
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 22
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 24
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 25
5.3 Frequency Response 8N FF, Index: 1 25
5.3 Frequency Response 8N DF, Index: 1 26
5.3 Frequency Response 2N FF, Index: 1 27
5.3 Frequency Response 2N DF, Index: 1 28

Overall Receive Delay WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	160.9 ms

2024/5/16 19:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	86.85 dB[SPL]	83.18%	16.85 dB[SPL]	Ok

Ok

2024/5/16 19:05 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	80.59 dB[SPL]	82.95%	10.59 dB[SPL]	Ok

Ok

2024/5/16 19:20 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.18 dB (3.47%) Ok

Ok

2024/5/16 19:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.84 dB (3.61%) Ok

Ok

2024/5/16 19:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.05 dB (2.80%) Ok

Ok

2024/5/16 19:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.04 dB (1.99%) Ok

Ok

2024/5/16 19:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.81 dB (1.62%) Ok

Ok

2024/5/16 19:07 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.94 dB (2.53%) Ok

Ok

2024/5/16 19:07 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.37 dB (2.70%) Ok

Ok

2024/5/16 19:07 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.29 dB (6.84%) Ok

Ok

2024/5/16 19:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.40 dB (6.03%) Ok

Ok

2024/5/16 19:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.37 dB (6.79%) Ok

Ok

2024/5/16 19:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.93 dB (3.19%) Ok

Ok

2024/5/16 19:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.06 dB (2.22%) Ok

Ok

2024/5/16 19:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 37.39 dB (1.35%) Ok

Ok

2024/5/16 19:10 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.15 dB (1.96%) Ok

Ok

2024/5/16 19:10 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	250Hz	29.18 dB
2	315Hz	28.84 dB
3	400Hz	31.05 dB
4	500Hz	34.04 dB
5	630Hz	35.81 dB
6	800Hz	31.94 dB
7	1000Hz	31.37 dB
8	1250Hz	23.29 dB
9	1600Hz	24.40 dB
10	2000Hz	23.37 dB
11	2500Hz	29.93 dB
12	3150Hz	33.06 dB
13	4000Hz	37.39 dB
14	5000Hz	34.15 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 23.29dB at 1250Hz.

2024/5/16 19:11 ACQUA

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.86 dB (3.61%) Ok

Ok

2024/5/16 19:20 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.58 dB (3.72%) Ok

Ok

2024/5/16 19:21 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.01 dB (2.82%) Ok

Ok

2024/5/16 19:21 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.08 dB (1.98%) Ok

Ok

2024/5/16 19:22 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 35.46 dB (1.69%) Ok

Ok

2024/5/16 19:22 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.60 dB (2.63%) Ok

Ok

2024/5/16 19:22 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.35 dB (2.71%) Ok

Ok

2024/5/16 19:23 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 23.91 dB (6.37%) Ok

Ok

2024/5/16 19:23 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.43 dB (6.01%) Ok

Ok

2024/5/16 19:24 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.41 dB (7.58%) Ok

Ok

2024/5/16 19:24 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.85 dB (2.87%) Ok

Ok

2024/5/16 19:24 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.93 dB (2.01%) Ok

Ok

2024/5/16 19:25 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 36.29 dB (1.53%) Ok

Ok

2024/5/16 19:25 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.71 dB (1.84%) Ok

Ok

2024/5/16 19:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	250Hz	28.86 dB
2	315Hz	28.58 dB
3	400Hz	31.01 dB
4	500Hz	34.08 dB
5	630Hz	35.46 dB
6	800Hz	31.60 dB
7	1000Hz	31.35 dB
8	1250Hz	23.91 dB
9	1600Hz	24.43 dB
10	2000Hz	22.41 dB
11	2500Hz	30.85 dB
12	3150Hz	33.93 dB
13	4000Hz	36.29 dB
14	5000Hz	34.71 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.41dB at 2000Hz.

2024/5/16 19:26 ACQUA

5.3 Frequency Response 8N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
0.76 dB at 5143.7 Hz Ok

Ok

2024/5/16 19:11 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.56 dB at 1088.7 Hz Ok

Ok

2024/5/16 19:12 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
2.31 dB at 205.7 Hz Ok

Ok

2024/5/16 19:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.95 dB at 3882.4 Hz Ok

Ok

2024/5/16 19:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n71_20 _DFT-s-OFDM_EVS NB 24.4kbps_CH136100
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:50
Responsible Person	audio

Overall Receive Delay NB, Index: 2 3
5.1a Receive Volume Control Performance 8N NB, Index: 1 3
5.1b Receive Volume Control Performance 2N NB, Index: 1 4
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 5
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 6
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 8
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 10
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 11
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 11
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 12
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 14
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 16
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 18
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 19
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 19
5.3 Frequency Response 8N FF HANB, Index: 1 20
5.3 Frequency Response 8N DF HANB, Index: 1 21
5.3 Frequency Response 2N FF HANB, Index: 1 21
5.3 Frequency Response 2N DF HANB, Index: 1 22

Overall Receive Delay NB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Narrowband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	124.1 ms

2024/5/16 19:53 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	88.02 dB[SPL]	80.23%	18.02 dB[SPL]	Ok

Ok

2024/5/16 19:53 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	82.08 dB[SPL]	79.83%	12.08 dB[SPL]	Ok

Ok

2024/5/16 19:48 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.01 dB (3.16%) Ok

Ok

2024/5/16 19:54 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.14 dB (3.49%) Ok

Ok

2024/5/16 19:54 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.86 dB (3.61%) Ok

Ok

2024/5/16 19:55 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.16 dB (1.96%) Ok

Ok

2024/5/16 19:55 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.82 dB (4.56%) Ok

Ok

2024/5/16 19:55 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 27.74 dB (4.10%) Ok

Ok

2024/5/16 19:56 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.64 dB (3.70%) Ok

Ok

2024/5/16 19:56 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.06 dB (4.98%) Ok

Ok

2024/5/16 19:57 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 39.11 dB (1.11%) Ok

Ok

2024/5/16 19:57 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 42.08 dB (0.79%) Ok

Ok

2024/5/16 19:57 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	400Hz	30.01 dB
2	500Hz	29.14 dB
3	630Hz	28.86 dB
4	800Hz	34.16 dB
5	1000Hz	26.82 dB
6	1250Hz	27.74 dB
7	1600Hz	28.64 dB
8	2000Hz	26.06 dB
9	2500Hz	39.11 dB
10	3150Hz	42.08 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.06dB at 2000Hz.

2024/5/16 19:57 ACQUA

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.68 dB (3.28%) Ok

Ok

2024/5/16 19:48 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.15 dB (3.49%) Ok

Ok

2024/5/16 19:49 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.66 dB (3.69%) Ok

Ok

2024/5/16 19:49 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.92 dB (1.80%) Ok

Ok

2024/5/16 19:49 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.81 dB (4.57%) Ok

Ok

2024/5/16 19:50 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.49 dB (3.76%) Ok

Ok

2024/5/16 19:50 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.63 dB (3.70%) Ok

Ok

2024/5/16 19:51 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 25.91 dB (5.07%) Ok

Ok

2024/5/16 19:51 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 38.36 dB (1.21%) Ok

Ok

2024/5/16 19:51 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 42.97 dB (0.71%) Ok

Ok

2024/5/16 19:52 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	400Hz	29.68 dB

2	500Hz	29.15 dB
3	630Hz	28.66 dB
4	800Hz	34.92 dB
5	1000Hz	26.81 dB
6	1250Hz	28.49 dB
7	1600Hz	28.63 dB
8	2000Hz	25.91 dB
9	2500Hz	38.36 dB
10	3150Hz	42.97 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 25.91dB at 2000Hz.

2024/5/16 19:52 ACQUA

5.3 Frequency Response 8N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.66 dB at 1285.9 Hz Ok

Ok

2024/5/16 19:58 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.16 dB at 873.9 Hz Ok

Ok

2024/5/16 19:58 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.58 dB at 305.9 Hz Ok

Ok

2024/5/16 19:52 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.14 dB at 305.9 Hz Ok

Ok

2024/5/16 19:52 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n71_20 _DFT-s-OFDM_EVS WB 128kbps_CH136100
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:51
Responsible Person	audio

Overall Receive Delay WB, Index: 2 3
5.1a Receive Volume Control Performance 8N WB, Index: 1 3
5.1b Receive Volume Control Performance 2N WB, Index: 1 4
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 5
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 6
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 8
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 10
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 12
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 14
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 15
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 15
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 16
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 18
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 20
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 22
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 24
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 25
5.3 Frequency Response 8N FF, Index: 2 25
5.3 Frequency Response 8N DF, Index: 1 26
5.3 Frequency Response 2N FF, Index: 1 27
5.3 Frequency Response 2N DF, Index: 1 28

Overall Receive Delay WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	120.4 ms

2024/5/16 19:38 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	86.68 dB[SPL]	83.03%	16.68 dB[SPL]	Ok

Ok

2024/5/16 19:39 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	80.57 dB[SPL]	83.70%	10.57 dB[SPL]	Ok

Ok

2024/5/16 19:31 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.39 dB (3.39%) Ok

Ok

2024/5/16 19:40 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.20 dB (3.47%) Ok

Ok

2024/5/16 19:40 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.51 dB (2.66%) Ok

Ok

2024/5/16 19:41 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.38 dB (2.14%) Ok

Ok

2024/5/16 19:41 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.80 dB (1.62%) Ok

Ok

2024/5/16 19:41 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.88 dB (2.02%) Ok

Ok

2024/5/16 19:42 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.89 dB (2.27%) Ok

Ok

2024/5/16 19:42 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.34 dB (6.06%) Ok

Ok

2024/5/16 19:43 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.68 dB (5.83%) Ok

Ok

2024/5/16 19:43 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 22.38 dB (7.61%) Ok

Ok

2024/5/16 19:43 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.98 dB (3.17%) Ok

Ok

2024/5/16 19:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.39 dB (2.40%) Ok

Ok

2024/5/16 19:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.30 dB (1.93%) Ok

Ok

2024/5/16 19:44 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.85 dB (2.87%) Ok

Ok

2024/5/16 19:45 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	250Hz	29.39 dB
2	315Hz	29.20 dB
3	400Hz	31.51 dB
4	500Hz	33.38 dB
5	630Hz	35.80 dB
6	800Hz	33.88 dB
7	1000Hz	32.89 dB
8	1250Hz	24.34 dB
9	1600Hz	24.68 dB
10	2000Hz	22.38 dB
11	2500Hz	29.98 dB
12	3150Hz	32.39 dB
13	4000Hz	34.30 dB
14	5000Hz	30.85 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.38dB at 2000Hz.

2024/5/16 19:45 ACQUA

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.78 dB (3.64%) Ok

Ok

2024/5/16 19:32 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.62 dB (3.71%) Ok

Ok

2024/5/16 19:32 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.97 dB (2.83%) Ok

Ok

2024/5/16 19:32 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.90 dB (2.02%) Ok

Ok

2024/5/16 19:33 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 35.88 dB (1.61%) Ok

Ok

2024/5/16 19:33 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.24 dB (2.44%) Ok

Ok

2024/5/16 19:34 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.18 dB (2.76%) Ok

Ok

2024/5/16 19:34 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.07 dB (6.26%) Ok

Ok

2024/5/16 19:34 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.43 dB (6.01%) Ok

Ok

2024/5/16 19:35 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.12 dB (7.83%) Ok

Ok

2024/5/16 19:35 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.27 dB (3.07%) Ok

Ok

2024/5/16 19:36 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.97 dB (2.00%) Ok

Ok

2024/5/16 19:36 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 36.00 dB (1.58%) Ok

Ok

2024/5/16 19:36 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.43 dB (1.90%) Ok

Ok

2024/5/16 19:37 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	250Hz	28.78 dB
2	315Hz	28.62 dB
3	400Hz	30.97 dB
4	500Hz	33.90 dB
5	630Hz	35.88 dB
6	800Hz	32.24 dB
7	1000Hz	31.18 dB
8	1250Hz	24.07 dB
9	1600Hz	24.43 dB
10	2000Hz	22.12 dB
11	2500Hz	30.27 dB
12	3150Hz	33.97 dB
13	4000Hz	36.00 dB
14	5000Hz	34.43 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.12dB at 2000Hz.

2024/5/16 19:37 ACQUA

5.3 Frequency Response 8N FF, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
0.84 dB at 1285.9 Hz Ok

Ok

2024/5/16 19:45 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.64 dB at 1088.7 Hz Ok

Ok

2024/5/16 19:39 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
2.21 dB at 1151.2 Hz Ok

Ok

2024/5/16 19:37 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.98 dB at 205.7 Hz Ok

Ok

2024/5/16 19:38 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n77_100 _DFT-s-OFDM_EVS NB 24.4kbps_CH633334
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:52
Responsible Person	audio

Overall Receive Delay NB, Index: 1 3
5.1a Receive Volume Control Performance 8N NB, Index: 1 3
5.1b Receive Volume Control Performance 2N NB, Index: 1 4
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 5
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 6
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 8
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 10
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 11
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 11
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 12
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 14
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 16
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 18
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 19
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 19
5.3 Frequency Response 8N FF HANB, Index: 1 20
5.3 Frequency Response 8N DF HANB, Index: 1 21
5.3 Frequency Response 2N FF HANB, Index: 1 21
5.3 Frequency Response 2N DF HANB, Index: 1 22

Overall Receive Delay NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ Preparation - Delay measurement



Delay (Cross): 158.4 ms

2024/3/19 15:42 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Speech Level RCV: 88.60 dB[SPL], Act.: 79.48%
Corrected Speech Level: 18.60 dB[SPL] Ok

Ok

2024/3/19 15:42 ACQUA 5.1.200

5.1b Receive Volume Control Performance 2N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Speech Level RCV: 80.91 dB[SPL], Act.: 84.08%
Corrected Speech Level: 10.91 dB[SPL] Ok

Ok

2024/3/19 16:10 ACQUA 5.1.200

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.97 dB (3.17%) Ok

Ok

2024/3/19 15:42 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.73 dB (3.26%) Ok

Ok

2024/3/19 15:43 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.54 dB (3.74%) Ok

Ok

2024/3/19 15:43 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.62 dB (2.34%) Ok

Ok

2024/3/19 15:44 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.57 dB (4.69%) Ok

Ok

2024/3/19 15:44 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.72 dB (4.61%) Ok

Ok

2024/3/19 15:44 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.35 dB (3.82%) Ok

Ok

2024/3/19 15:45 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.00 dB (3.98%) Ok

Ok

2024/3/19 15:45 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.91 dB (1.60%) Ok

Ok

2024/3/19 15:46 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 38.98 dB (1.12%) Ok

Ok

2024/3/19 15:46 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	400Hz	29.97 dB
2	500Hz	29.73 dB
3	630Hz	28.54 dB
4	800Hz	32.62 dB
5	1000Hz	26.57 dB
6	1250Hz	26.72 dB
7	1600Hz	28.35 dB
8	2000Hz	28.00 dB
9	2500Hz	35.91 dB
10	3150Hz	38.98 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.57dB at 1000Hz.

2024/3/19 15:46 ACQUA

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.61 dB (2.63%) Ok

Ok

2024/3/19 16:11 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.05 dB (2.23%) Ok

Ok

2024/3/19 16:12 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.15 dB (2.20%) Ok

Ok

2024/3/19 16:12 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.50 dB (2.98%) Ok

Ok

2024/3/19 16:12 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.64 dB (3.70%) Ok

Ok

2024/3/19 16:13 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 23.15 dB (6.96%) Ok

Ok

2024/3/19 16:13 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.44 dB (6.00%) Ok

Ok

2024/3/19 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.71 dB (7.32%) Ok

Ok

2024/3/19 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.36 dB (3.03%) Ok

Ok

2024/3/19 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.74 dB (2.06%) Ok

Ok

2024/3/19 16:15 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	400Hz	31.61 dB

2	500Hz	33.05 dB
3	630Hz	33.15 dB
4	800Hz	30.50 dB
5	1000Hz	28.64 dB
6	1250Hz	23.15 dB
7	1600Hz	24.44 dB
8	2000Hz	22.71 dB
9	2500Hz	30.36 dB
10	3150Hz	33.74 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.71dB at 2000Hz.

2024/3/19 16:15 ACQUA

5.3 Frequency Response 8N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.63 dB at 873.9 Hz Ok

Ok

2024/3/19 15:47 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.30 dB at 305.9 Hz Ok

Ok

2024/3/19 15:47 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.41 dB at 1285.9 Hz Ok

Ok

2024/3/19 16:15 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.73 dB at 3657.5 Hz Ok

Ok

2024/3/19 16:16 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n77_100 _DFT-s-OFDM_EVS NB 24.4kbps_CH656000
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:58
Responsible Person	audio

Overall Receive Delay NB, Index: 1 3
5.1a Receive Volume Control Performance 8N NB, Index: 1 3
5.1b Receive Volume Control Performance 2N NB, Index: 1 4
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 5
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 6
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 8
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 10
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 11
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 11
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 12
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 14
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 16
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 18
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 19
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 19
5.3 Frequency Response 8N FF HANB, Index: 1 20
5.3 Frequency Response 8N DF HANB, Index: 1 21
5.3 Frequency Response 2N FF HANB, Index: 1 21
5.3 Frequency Response 2N DF HANB, Index: 1 22

Overall Receive Delay NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	153.7 ms

2024/5/17 13:16 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	88.02 dB[SPL]	80.24%	18.02 dB[SPL]	Ok

Ok

2024/5/17 13:24 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	81.66 dB[SPL]	79.65%	11.66 dB[SPL]	Ok

Ok

2024/5/17 13:17 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.10 dB (3.51%) Ok

Ok

2024/5/17 13:24 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.06 dB (3.14%) Ok

Ok

2024/5/17 13:24 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.97 dB (3.56%) Ok

Ok

2024/5/17 13:25 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.90 dB (2.54%) Ok

Ok

2024/5/17 13:25 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 26.83 dB (4.55%) Ok

Ok

2024/5/17 13:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 27.00 dB (4.47%) Ok

Ok

2024/5/17 13:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.41 dB (3.80%) Ok

Ok

2024/5/17 13:26 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 27.55 dB (4.19%) Ok

Ok

2024/5/17 13:27 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 37.10 dB (1.40%) Ok

Ok

2024/5/17 13:27 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 39.26 dB (1.09%) Ok

Ok

2024/5/17 13:28 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	400Hz	29.10 dB
2	500Hz	30.06 dB
3	630Hz	28.97 dB
4	800Hz	31.90 dB
5	1000Hz	26.83 dB
6	1250Hz	27.00 dB
7	1600Hz	28.41 dB
8	2000Hz	27.55 dB
9	2500Hz	37.10 dB
10	3150Hz	39.26 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.83dB at 1000Hz.

2024/5/17 13:28 ACQUA

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.56 dB (3.33%) Ok

Ok

2024/5/17 13:18 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.09 dB (3.13%) Ok

Ok

2024/5/17 13:18 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.97 dB (3.56%) Ok

Ok

2024/5/17 13:19 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.82 dB (2.04%) Ok

Ok

2024/5/17 13:19 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.58 dB (4.69%) Ok

Ok

2024/5/17 13:19 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.56 dB (4.70%) Ok

Ok

2024/5/17 13:20 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 27.97 dB (4.00%) Ok

Ok

2024/5/17 13:20 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 26.62 dB (4.67%) Ok

Ok

2024/5/17 13:21 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 36.84 dB (1.44%) Ok

Ok

2024/5/17 13:21 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 40.20 dB (0.98%) Ok

Ok

2024/5/17 13:21 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	400Hz	29.56 dB

2	500Hz	30.09 dB
3	630Hz	28.97 dB
4	800Hz	33.82 dB
5	1000Hz	26.58 dB
6	1250Hz	26.56 dB
7	1600Hz	27.97 dB
8	2000Hz	26.62 dB
9	2500Hz	36.84 dB
10	3150Hz	40.20 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 26.56dB at 1250Hz.

2024/5/17 13:22 ACQUA

5.3 Frequency Response 8N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.69 dB at 1285.9 Hz Ok

Ok

2024/5/17 13:46 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.93 dB at 1285.9 Hz Ok

Ok

2024/5/17 13:46 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
1.39 dB at 305.9 Hz Ok

Ok

2024/5/17 13:22 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.94 dB at 305.9 Hz Ok

Ok

2024/5/17 13:22 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n77_100 _DFT-s-OFDM_EVS WB 128kbps_CH633334
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:54
Responsible Person	audio

Overall Receive Delay WB, Index: 2 3
5.1a Receive Volume Control Performance 8N WB, Index: 1 3
5.1b Receive Volume Control Performance 2N WB, Index: 1 4
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 2 5
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 2 6
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 2 7
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 2 7
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 2 8
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 2 9
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 2 9
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 2 10
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 2 11
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 2 11
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 2 12
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 2 13
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 2 13
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 2 14
Report - Receive Distortion and Noise (Conversational Gain), Index: 2 15
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 15
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 16
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 18
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 20
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 22
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 24
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 25
5.3 Frequency Response 8N FF, Index: 2 25
5.3 Frequency Response 8N DF, Index: 2 26
5.3 Frequency Response 2N FF, Index: 1 27
5.3 Frequency Response 2N DF, Index: 1 28

Overall Receive Delay WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	140.2 ms

2024/4/22 13:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Speech Level RCV: 88.41 dB[SPL], Act.: 79.82%
Corrected Speech Level: 18.41 dB[SPL] Ok

Ok

2024/3/19 15:48 ACQUA 5.1.200

5.1b Receive Volume Control Performance 2N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Speech Level RCV: 81.10 dB[SPL], Act.: 84.72%
Corrected Speech Level: 11.10 dB[SPL] Ok

Ok

2024/3/19 16:02 ACQUA 5.1.200

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.28 dB (3.06%) Ok

Ok

2024/4/22 13:03 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.68 dB (3.28%) Ok

Ok

2024/4/22 13:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.77 dB (2.58%) Ok

Ok

2024/4/22 13:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.87 dB (2.03%) Ok

Ok

2024/4/22 13:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.55 dB (2.10%) Ok

Ok

2024/4/22 13:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.33 dB (1.71%) Ok

Ok

2024/4/22 13:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.13 dB (1.75%) Ok

Ok

2024/4/22 13:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.49 dB (3.76%) Ok

Ok

2024/4/22 13:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.85 dB (5.72%) Ok

Ok

2024/4/22 13:07 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.65 dB (6.57%) Ok

Ok

2024/4/22 13:07 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.52 dB (1.67%) Ok

Ok

2024/4/22 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 37.01 dB (1.41%) Ok

Ok

2024/4/22 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 37.37 dB (1.35%) Ok

Ok

2024/4/22 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.70 dB (2.60%) Ok

Ok

2024/4/22 13:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	250Hz	30.28 dB
2	315Hz	29.68 dB
3	400Hz	31.77 dB
4	500Hz	33.87 dB
5	630Hz	33.55 dB
6	800Hz	35.33 dB
7	1000Hz	35.13 dB
8	1250Hz	28.49 dB
9	1600Hz	24.85 dB
10	2000Hz	23.65 dB
11	2500Hz	35.52 dB
12	3150Hz	37.01 dB
13	4000Hz	37.37 dB
14	5000Hz	31.70 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 23.65dB at 2000Hz.

2024/4/22 13:09 ACQUA

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.73 dB (2.91%) Ok

Ok

2024/3/19 16:03 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.25 dB (3.07%) Ok

Ok

2024/3/19 16:03 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.95 dB (2.53%) Ok

Ok

2024/3/19 16:03 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.85 dB (2.03%) Ok

Ok

2024/3/19 16:04 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.41 dB (1.90%) Ok

Ok

2024/3/19 16:04 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.10 dB (2.48%) Ok

Ok

2024/3/19 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.87 dB (3.60%) Ok

Ok

2024/3/19 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 23.98 dB (6.33%) Ok

Ok

2024/3/19 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.59 dB (5.89%) Ok

Ok

2024/3/19 16:06 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.41 dB (7.58%) Ok

Ok

2024/3/19 16:06 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.90 dB (3.20%) Ok

Ok

2024/3/19 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.35 dB (2.15%) Ok

Ok

2024/3/19 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.31 dB (2.16%) Ok

Ok

2024/3/19 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.29 dB (2.43%) Ok

Ok

2024/3/19 16:08 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	250Hz	30.73 dB
2	315Hz	30.25 dB
3	400Hz	31.95 dB
4	500Hz	33.85 dB
5	630Hz	34.41 dB
6	800Hz	32.10 dB
7	1000Hz	28.87 dB
8	1250Hz	23.98 dB
9	1600Hz	24.59 dB
10	2000Hz	22.41 dB
11	2500Hz	29.90 dB
12	3150Hz	33.35 dB
13	4000Hz	33.31 dB
14	5000Hz	32.29 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.41dB at 2000Hz.

2024/3/19 16:08 ACQUA

5.3 Frequency Response 8N FF, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
0.69 dB at 1285.9 Hz Ok

Ok

2024/4/22 13:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF, Index: 2

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.12 dB at 1088.7 Hz Ok

Ok

2024/4/22 13:02 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.20 dB at 1151.2 Hz Ok

Ok

2024/3/19 16:08 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.03 dB at 1088.7 Hz Ok

Ok

2024/3/19 16:09 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	FR1 n77_100 _DFT-s-OFDM_EVS WB 128kbps_CH656000
Description	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 15:59
Responsible Person	audio

Overall Receive Delay WB, Index: 1 3
5.1a Receive Volume Control Performance 8N WB, Index: 1 3
5.1b Receive Volume Control Performance 2N WB, Index: 1 4
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 5
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 6
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 8
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 10
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 12
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 14
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 15
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 15
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 16
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 18
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 20
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 22
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 24
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 25
5.3 Frequency Response 8N FF, Index: 1 25
5.3 Frequency Response 8N DF, Index: 1 26
5.3 Frequency Response 2N FF, Index: 1 27
5.3 Frequency Response 2N DF, Index: 1 28

Overall Receive Delay WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ Preparation - Delay measurement



Channel	Delay
RCV*Source	129.7 ms

2024/5/17 12:55 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	86.21 dB[SPL]	83.93%	16.21 dB[SPL]	Ok

Ok

2024/5/17 12:55 ACQUA 6.0.200

5.1b Receive Volume Control Performance 2N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Channel	Speech level	Activity	Corrected speech level	
RCV	80.45 dB[SPL]	83.05%	10.45 dB[SPL]	Ok

Ok

2024/5/17 12:59 ACQUA 6.0.200

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.80 dB (3.24%) Ok

Ok

2024/5/17 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.33 dB (3.41%) Ok

Ok

2024/5/17 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.55 dB (2.64%) Ok

Ok

2024/5/17 13:08 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.70 dB (2.06%) Ok

Ok

2024/5/17 13:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.87 dB (1.61%) Ok

Ok

2024/5/17 13:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.20 dB (1.95%) Ok

Ok

2024/5/17 13:09 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.47 dB (2.38%) Ok

Ok

2024/5/17 13:10 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.42 dB (6.01%) Ok

Ok

2024/5/17 13:10 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.71 dB (5.82%) Ok

Ok

2024/5/17 13:11 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.14 dB (6.97%) Ok

Ok

2024/5/17 13:11 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.14 dB (2.77%) Ok

Ok

2024/5/17 13:11 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.59 dB (2.35%) Ok

Ok

2024/5/17 13:12 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.02 dB (1.77%) Ok

Ok

2024/5/17 13:12 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.82 dB (2.88%) Ok

Ok

2024/5/17 13:13 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	250Hz	29.80 dB
2	315Hz	29.33 dB
3	400Hz	31.55 dB
4	500Hz	33.70 dB
5	630Hz	35.87 dB
6	800Hz	34.20 dB
7	1000Hz	32.47 dB
8	1250Hz	24.42 dB
9	1600Hz	24.71 dB
10	2000Hz	23.14 dB
11	2500Hz	31.14 dB
12	3150Hz	32.59 dB
13	4000Hz	35.02 dB
14	5000Hz	30.82 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 23.14dB at 2000Hz.

2024/5/17 13:13 ACQUA

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.92 dB (3.19%) Ok

Ok

2024/5/17 13:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.88 dB (3.21%) Ok

Ok

2024/5/17 13:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.84 dB (2.56%) Ok

Ok

2024/5/17 13:00 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.22 dB (2.18%) Ok

Ok

2024/5/17 13:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.86 dB (1.81%) Ok

Ok

2024/5/17 13:01 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.82 dB (1.82%) Ok

Ok

2024/5/17 13:02 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.83 dB (2.28%) Ok

Ok

2024/5/17 13:02 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 25.19 dB (5.50%) Ok

Ok

2024/5/17 13:02 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.50 dB (5.96%) Ok

Ok

2024/5/17 13:03 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.15 dB (7.81%) Ok

Ok

2024/5/17 13:03 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.70 dB (3.27%) Ok

Ok

2024/5/17 13:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.72 dB (2.06%) Ok

Ok

2024/5/17 13:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.17 dB (1.96%) Ok

Ok

2024/5/17 13:04 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.74 dB (2.59%) Ok

Ok

2024/5/17 13:05 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	250Hz	29.92 dB
2	315Hz	29.88 dB
3	400Hz	31.84 dB
4	500Hz	33.22 dB
5	630Hz	34.86 dB
6	800Hz	34.82 dB
7	1000Hz	32.83 dB
8	1250Hz	25.19 dB
9	1600Hz	24.50 dB
10	2000Hz	22.15 dB
11	2500Hz	29.70 dB
12	3150Hz	33.72 dB
13	4000Hz	34.17 dB
14	5000Hz	31.74 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.15dB at 2000Hz.

2024/5/17 13:05 ACQUA

5.3 Frequency Response 8N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
0.52 dB at 5143.7 Hz Ok

Ok

2024/5/17 13:14 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.31 dB at 1088.7 Hz Ok

Ok

2024/5/17 13:14 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.90 dB at 1216.1 Hz Ok

Ok

2024/5/17 13:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.71 dB at 205.7 Hz Ok

Ok

2024/5/17 13:06 ACQUA 6.0.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	LTE Band 7_20QPSK_100_0_EVS NB 24.4kbps_CH21100
Project	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 14:39
Responsible Person	audio

Overall Receive Delay NB, Index: 1 3
5.1a Receive Volume Control Performance 8N NB, Index: 1 3
5.1b Receive Volume Control Performance 2N NB, Index: 1 4
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 5
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 6
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 7
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 8
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 9
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 10
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 11
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 11
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 12
5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1 13
5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1 14
5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1 15
5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1 16
5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1 17
5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1 18
5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1 19
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 19
5.3 Frequency Response 8N FF HANB, Index: 1 20
5.3 Frequency Response 8N DF HANB, Index: 1 21
5.3 Frequency Response 2N FF HANB, Index: 1 21
5.3 Frequency Response 2N DF HANB, Index: 1 22

Overall Receive Delay NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ Preparation - Delay measurement



Delay (Cross): 116.2 ms

2024/2/27 15:33 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Speech Level RCV: 91.36 dB[SPL], Act.: 81.40%
Corrected Speech Level: 21.36 dB[SPL] Ok

Ok

2024/3/12 21:42 ACQUA 5.1.200

5.1b Receive Volume Control Performance 2N NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Correction

X - 70

Speech Level RCV: 85.89 dB[SPL], Act.: 83.54%
Corrected Speech Level: 15.89 dB[SPL] Ok

Ok

2024/2/27 15:27 ACQUA 5.1.200

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.43 dB (3.38%) Ok

Ok

2024/2/27 15:34 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.01 dB (3.16%) Ok

Ok

2024/2/27 15:34 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.71 dB (2.32%) Ok

Ok

2024/2/27 15:34 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.75 dB (2.05%) Ok

Ok

2024/2/27 15:35 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.72 dB (2.60%) Ok

Ok

2024/2/27 15:35 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.71 dB (6.52%) Ok

Ok

2024/2/27 15:36 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 24.37 dB (6.05%) Ok

Ok

2024/2/27 15:36 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 21.79 dB (8.14%) Ok

Ok

2024/2/27 15:36 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.12 dB (3.93%) Ok

Ok

2024/2/27 15:37 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 28.43 dB (3.79%) Ok

Ok

2024/2/27 15:37 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	400Hz	29.43 dB
2	500Hz	30.01 dB
3	630Hz	32.71 dB
4	800Hz	33.75 dB
5	1000Hz	31.72 dB
6	1250Hz	23.71 dB
7	1600Hz	24.37 dB
8	2000Hz	21.79 dB
9	2500Hz	28.12 dB
10	3150Hz	28.43 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 21.79dB at 2000Hz.

2024/2/27 15:38 ACQUA

5.2 RCV Distortion and Noise - 400 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.36 dB (3.40%) Ok

Ok

2024/2/27 15:27 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.27 dB (3.06%) Ok

Ok

2024/2/27 15:28 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.05 dB (2.23%) Ok

Ok

2024/2/27 15:28 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.77 dB (2.05%) Ok

Ok

2024/2/27 15:28 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.06 dB (2.49%) Ok

Ok

2024/2/27 15:29 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 23.55 dB (6.65%) Ok

Ok

2024/2/27 15:29 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.04 dB (6.28%) Ok

Ok

2024/2/27 15:30 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 21.96 dB (7.98%) Ok

Ok

2024/2/27 15:30 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 28.15 dB (3.91%) Ok

Ok

2024/2/27 15:31 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz NB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.09 dB (3.13%) Ok

Ok

2024/2/27 15:31 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	400Hz	29.36 dB

2	500Hz	30.27 dB
3	630Hz	33.05 dB
4	800Hz	33.77 dB
5	1000Hz	32.06 dB
6	1250Hz	23.55 dB
7	1600Hz	24.04 dB
8	2000Hz	21.96 dB
9	2500Hz	28.15 dB
10	3150Hz	30.09 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 21.96dB at 2000Hz.

2024/2/27 15:31 ACQUA

5.3 Frequency Response 8N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.29 dB at 1647.8 Hz Ok

Ok

2024/2/27 15:38 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.32 dB at 2057.5 Hz Ok

Ok

2024/2/27 15:39 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.75 dB at 689.1 Hz Ok

Ok

2024/2/27 15:31 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF HANB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Narrowband



Absolute minimal distance
0.25 dB at 305.9 Hz Ok

Ok

2024/2/27 15:32 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Measurement Protocol

Measurement Object	LTE Band 7_20QPSK_100_0_EVS WB 128kbps_CH21100
Project	CJWQ-W7L-P23120020 DTNC PM95

Project	TIA-5050 (2018-01)
Report Generation Date	2024/5/21 14:41
Responsible Person	audio

Overall Receive Delay WB, Index: 1 3
5.1a Receive Volume Control Performance 8N WB, Index: 1 3
5.1b Receive Volume Control Performance 2N WB, Index: 1 4
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 5
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 6
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 7
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 8
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 9
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 10
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 11
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 12
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 13
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 14
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 15
5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1 15
5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1 16
5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1 17
5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1 18
5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1 19
5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1 20
5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1 21
5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1 22
5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1 23
5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1 24
Report - Receive Distortion and Noise (Conversational Gain), Index: 1 25
5.3 Frequency Response 8N FF, Index: 1 25
5.3 Frequency Response 8N DF, Index: 1 26
5.3 Frequency Response 2N FF, Index: 1 27
5.3 Frequency Response 2N DF, Index: 1 28

Overall Receive Delay WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ Preparation - Delay measurement



Delay (Cross): 142.5 ms

2024/3/12 16:01 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.1a Receive Volume Control Performance 8N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Speech Level RCV: 87.37 dB[SPL], Act.: 83.44%
Corrected Speech Level: 17.37 dB[SPL] Ok

Ok

2024/3/12 16:02 ACQUA 5.1.200

5.1b Receive Volume Control Performance 2N WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Correction

X - 70

Speech Level RCV: 81.67 dB[SPL], Act.: 80.38%
Corrected Speech Level: 11.67 dB[SPL] Ok

Ok

2024/3/12 16:12 ACQUA 5.1.200

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 30.33 dB (3.05%) Ok

Ok

2024/3/12 16:03 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.65 dB (3.29%) Ok

Ok

2024/3/12 16:03 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.81 dB (2.57%) Ok

Ok

2024/3/12 16:04 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 34.17 dB (1.96%) Ok

Ok

2024/3/12 16:04 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 35.17 dB (1.74%) Ok

Ok

2024/3/12 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.83 dB (2.28%) Ok

Ok

2024/3/12 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 31.19 dB (2.76%) Ok

Ok

2024/3/12 16:05 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.85 dB (6.42%) Ok

Ok

2024/3/12 16:06 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 25.00 dB (5.62%) Ok

Ok

2024/3/12 16:06 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 23.16 dB (6.95%) Ok

Ok

2024/3/12 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 29.46 dB (3.37%) Ok

Ok

2024/3/12 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 32.73 dB (2.31%) Ok

Ok

2024/3/12 16:07 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 36.54 dB (1.49%) Ok

Ok

2024/3/12 16:08 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N



Distortion (Noise) RCV (packed): 33.45 dB (2.13%) Ok

Ok

2024/3/12 16:08 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 8N

Region	Frequency	SDNR
1	250Hz	30.33 dB
2	315Hz	29.65 dB
3	400Hz	31.81 dB
4	500Hz	34.17 dB
5	630Hz	35.17 dB
6	800Hz	32.83 dB
7	1000Hz	31.19 dB
8	1250Hz	23.85 dB
9	1600Hz	25.00 dB
10	2000Hz	23.16 dB
11	2500Hz	29.46 dB
12	3150Hz	32.73 dB
13	4000Hz	36.54 dB
14	5000Hz	33.45 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 23.16dB at 2000Hz.

2024/3/12 16:08 ACQUA

5.2 RCV Distortion and Noise - 250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.93 dB (3.19%) Ok

Ok

2024/3/12 16:12 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 315 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 29.43 dB (3.38%) Ok

Ok

2024/3/12 16:13 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 400 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 31.69 dB (2.60%) Ok

Ok

2024/3/12 16:13 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 34.40 dB (1.90%) Ok

Ok

2024/3/12 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 630 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.21 dB (2.19%) Ok

Ok

2024/3/12 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 800 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 32.15 dB (2.47%) Ok

Ok

2024/3/12 16:14 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.34 dB (3.04%) Ok

Ok

2024/3/12 16:15 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1250 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 24.21 dB (6.16%) Ok

Ok

2024/3/12 16:15 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 1600 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 23.74 dB (6.50%) Ok

Ok

2024/3/12 16:16 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 22.65 dB (7.37%) Ok

Ok

2024/3/12 16:16 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 2500 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 30.26 dB (3.07%) Ok

Ok

2024/3/12 16:16 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 3150 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 33.76 dB (2.05%) Ok

Ok

2024/3/12 16:17 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 4000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 35.14 dB (1.75%) Ok

Ok

2024/3/12 16:17 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.2 RCV Distortion and Noise - 5000 Hz WB, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N



Distortion (Noise) RCV (packed): 35.22 dB (1.73%) Ok

Ok

2024/3/12 16:18 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

Report - Receive Distortion and Noise (Conversational Gain), Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband \ 5.2 Receive Distortion and Noise 2N

Region	Frequency	SDNR
1	250Hz	29.93 dB
2	315Hz	29.43 dB
3	400Hz	31.69 dB
4	500Hz	34.40 dB
5	630Hz	33.21 dB
6	800Hz	32.15 dB
7	1000Hz	30.34 dB
8	1250Hz	24.21 dB
9	1600Hz	23.74 dB
10	2000Hz	22.65 dB
11	2500Hz	30.26 dB
12	3150Hz	33.76 dB
13	4000Hz	35.14 dB
14	5000Hz	35.22 dB

All SDNRs were greater than 20.0 dB, requirement was met.
Smallest SDNR was 22.65dB at 2000Hz.

2024/3/12 16:18 ACQUA

5.3 Frequency Response 8N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
0.33 dB at 1447.5 Hz Ok

Ok

2024/3/12 16:10 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 8N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.00 dB at 1088.7 Hz Ok

Ok

2024/3/12 16:11 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N FF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.57 dB at 1285.9 Hz Ok

Ok

2024/3/12 16:18 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor

5.3 Frequency Response 2N DF, Index: 1

TIA-5050 (2018-01) \ Measurements \ Wideband



Absolute minimal distance
1.37 dB at 1088.7 Hz Ok

Ok

2024/3/12 16:19 ACQUA 5.1.200
Unmodified HEAD acoustics Measurement Descriptor