

# Interface Manual

## DIN Gateway

*SignalFire Part Numbers: GW-DIN, GW-DIN-STATICIP*



The SignalFire DIN Gateway has the following features:

- RS485 connection to Modbus master device
- Optional Modbus-TCP Ethernet gateway module
- Wide range DC power input. 6 to 36VDC
- Two open collector digital outputs
- DIN rail mount
- Collects and caches Modbus data from all SignalFire remote nodes
- Provides configuration and status registers for remote configuration and status monitoring
- RP-SMA antenna port for connection to external 900MHz antenna
- Stores up to 4700 register values from any combination of remote nodes
- Supports transparent Modbus mode
- Internal Remote Shut Down (RSD) logic control option
- Slave register re-mapping
- Remote configuration of SignalFire devices through an Ethernet gateway connection
- Remote sensor configuration (PACTware and RadarMaster)
- Radio is FCC and IC approved

### DIN Gateway Connections

The DIN Gateway has a 6-position pluggable terminal block for power and serial communications. The connections are as follows:

| Terminal Name  | Connection                                                     |
|----------------|----------------------------------------------------------------|
| 6-36VDC (RED)  | Positive Power (6 to 36 VDC)                                   |
| GROUND (BLK)   | Ground                                                         |
| RS232 TX (ORG) | RS-232 Debug TX, 9600 Baud (Only used with Ethernet GW module) |
| RS232 RX (YEL) | RS-232 Debug RX, 9600 Baud (Only used with Ethernet GW module) |
| MODBUS A (GRN) | RS-485 "A", 9600 Baud                                          |
| MODBUS B (BRN) | RS-485 "B", 9600 Baud                                          |

In addition, a RS232 DB9 port is available for connection to the SignalFire Toolkit for configuration and diagnostics.

*Gateway Hardware revision 2 also has a 3-position pluggable terminal block with two open collector digital outputs for signaling or alarm functions. Each output is rated to 30VDC and 1 Amp.*

### Optional Ethernet Gateway Connections

When used with a SignalFire Ethernet Gateway module, the 6-position screw terminal block should be connected to the color coded "Gateway Stick Connection" connector on the Ethernet Gateway. Power can be supplied either to the Power Input terminals on the Ethernet Gateway or via power over Ethernet (PoE).

**NOTE: when used with an Ethernet Gateway module the DB9 on the Ethernet module must be used for ToolKit access.**

## Status LEDs

The DIN Gateway has three LED Available for field diagnostics. The RS485 TX/RX LEDs will blink in response to RS485 traffic, the status LED is described below.

| STATUS LED                    | Description                                               |
|-------------------------------|-----------------------------------------------------------|
| Slow Flash (3 second pause)   | System is running and in communication with radio network |
| Fast Flash (0.5 second pause) | System is running but no network found                    |
| Solid On                      | System Fault needs service or rescue bootloader           |

## Operation

The DIN Gateway supports all remote SignalFire nodes making all remote sensor data available in Modbus format.

The register data from remote sensor nodes is available by requesting the remote node's Modbus slave ID and register address from that node's register map. The gateway will respond with the most recent copy of the data from the remote node. The gateway will automatically time-out data from a remote node it stops receiving data for.

If the remote node is a Modbus-Stick additional features are supported.

### Remote Modbus Sticks and Sentinel-Modbus (non-sleeping radio only) Nodes

Remote nodes that have been pre-configured forward their set of registers to the Modbus gateway on a pre-defined schedule (1 minute to 5 minutes is typical). The register data is then buffered in the gateway and is available to be read by the RTU at any time.

If a Modbus request is received by the gateway for a Modbus ID and address for which buffered data does not exist, but the Modbus ID is known, the Modbus request will be forwarded to the remote Modbus node over the SignalFire network. The response is returned to the RTU.

If a request for multiple registers is issued by the RTU, and if the gateway does not have all registered data buffered, an exception will be returned. The system will not combine buffered and transparent data within a single Modbus response.

## Remote Modbus Stick Node Re-Scan

It is possible to cause a remote Modbus Stick to re-scan for attached Modbus devices by writing to one of the gateway's configuration registers. This is useful to discover a Modbus device that is added to an existing Modbus node. The scan may be initiated by one of the two methods. First, if the radio address of the Modbus Stick is known, writing this address to gateway register 3000 will result in a scan. Second, if the Modbus ID of one of the already registered devices attached to a Modbus Stick is known, a scan will be started by writing the ID to gateway register 3002.

## Setup

The DIN Gateway requires an initial configuration over the debug port. The supplied SignalFire Toolkit PC application will be used to configure the device over the serial port.


The following item must be configured:

- Radio Network and Group Selection

**NOTE: If used with an Ethernet Gateway module the DB9 on the Ethernet module must be used for ToolKit access.**

### Using the SignalFire Toolkit

The SignalFire Toolkit application can be downloaded at [www.signal-fire.com/customer](http://www.signal-fire.com/customer). After installation, launch the software and the main toolkit window will open:



Select the COM port associated with the DIN Gateway and click "Auto-Detect Device on COM Port." This will open the device configuration window, where all device settings can be configured.

## Network Setting

The network address can be used to create separate networks using multiple gateways (that are in close proximity with one another). The network is set using the SignalFire Toolkit. The Network Group setting is used when more than 8 networks are needed. Both the network and network group must match those of other nodes for nodes to communicate.

|                     |   |     |
|---------------------|---|-----|
| Radio Network       | 1 | Set |
| Radio Network Group | 0 | Set |

## Checking Remote Nodes

If one or more remote nodes are configured with the correct network settings they will send their data to the gateway. Clicking **Refresh List** will populate the list with all connected remote nodes. Double clicking on one of the nodes in the list will bring up additional detail including the register data from the remote node.

| Modbus Slaves Reporting              |           |           |            |                   |                  |                        |                    |                 |                          |
|--------------------------------------|-----------|-----------|------------|-------------------|------------------|------------------------|--------------------|-----------------|--------------------------|
| Double-click a Row to View Registers |           |           |            |                   |                  |                        |                    |                 |                          |
|                                      |           |           |            |                   |                  |                        |                    |                 |                          |
| Slave ID                             | Node Type | Node Name | RSSI (dBm) | Register Quantity | Checkin Interval | TTL (min): Current/Max | Mainboard Firmware | Radio Firmware  | Configure                |
| 1                                    | Sent TC   |           | -34        | 16                | 1 min            | 5/7                    | 0.25               | 2.49 (sleeping) | <input type="checkbox"/> |

The gateway displays the node type, node name (is one is programmed into the need), RSSI signal strength, programmed node check-in interval, the Time To Live (TTL), and the nodes radio and main firmware versions.

The RSSI and TTL values are color coded (Green, yellow, orange, red) to indicate relative link quality of a node. The 'TTL current' indicates the number of minutes remaining until the node will be timed out of the gateway if no updates are received. The 'TTL max' indicates the maximum TTL for that node, the 'TTL current' will be set to the 'TTL Max' each time an update is received from that node.

## Modbus Gateway Register Map

7

The SignalFire Modbus Gateway by default is assigned Modbus Slave ID number 247. **Only the Gateway status/configuration registers are read at this address.** All remote node registers are read from the slave ID and register address of the remote node, unless slave register remapping used.

### Gateway Configuration and Status Messages

**Boolean Registers** – These are 1-bit coil registers. They can only be written to by Modbus opcode 0x05 (Write Single Coil). To perform the following resets, write a 0xFF00 to the respective coil. Writing 0x0000 to a coil has no effect.

| Register Number | Register Address (Offset) | Description                                                     |
|-----------------|---------------------------|-----------------------------------------------------------------|
| 00001           | 0000                      | Resets the gateway and radio                                    |
| 00002           | 0001                      | Resets the radio leaving the gateway on                         |
| 00003           | 0002                      | Resets all counters to zero (See Read Only Registers 2026-2031) |

**Read/Write Registers** – These are 16-bit read/write registers. They can be written to by Modbus opcode 0x06 or 0x10 (Write Single and Multiple Registers, respectively) and can be read with Modbus opcode 0x03 or 0x04 (Read Discrete Input and Holding Registers, respectively). The first three registers are identical to the previous three write coils and behave similarly. They will be read as 0x0000 and can be triggered by writing 0xFF00 to them. The remaining must be written with 16-bit values in the range specified in the table below.

| Register Number | Register Address (Offset) | Description                                                               |
|-----------------|---------------------------|---------------------------------------------------------------------------|
| 41001           | 1000                      | Resets the gateway and radio                                              |
| 41002           | 1001                      | Resets the radio leaving the gateway on                                   |
| 41003           | 1002                      | Resets all GW status counters to zero (See Read Only Registers 2026-2031) |

**Read Only Registers** – These are 16-bit read only registers. They can be read with Modbus opcode 0x03 or 0x04 (Read Discrete Input and Holding Registers, respectively). The register map can be found on the next page.

If the gateway has a large total number of registers approaching 4700, register 2008 should be monitored to ensure that free registers are available before adding a new node.

| Register Number | Register Address (Offset) | Description                                                                   |
|-----------------|---------------------------|-------------------------------------------------------------------------------|
| 42001           | 2000                      | Upper 16 bits of SFTS GW node address (the radio ID)                          |
| 42002           | 2001                      | Lower 16 bits of SFTS GW node address (the radio ID)                          |
| 42003           | 2002                      | Upper 16 bits of Radio Firmware version number                                |
| 42004           | 2003                      | Lower 16 bits of Radio Firmware version number                                |
| 42005           | 2004                      | Upper 16 bits of gateway firmware version number                              |
| 42006           | 2005                      | Lower 16 bits of gateway firmware version number                              |
| 42007           | 2006                      | Number of slave nodes that data is cached for this gateway                    |
| 42008           | 2007                      | Total number of registers allocated to slave devices                          |
| 42009           | 2008                      | Total number of free registers available for slave devices                    |
| 42010           | 2009                      | Bitmask for active slave IDs 15-0 (LSB is 0)                                  |
| 42011           | 2010                      | Bitmask for active slave IDs 31-16 (LSB is 16)                                |
| 42012           | 2011                      | Bitmask for active slave IDs 47-32 (LSB is 32)                                |
| 42013           | 2012                      | Bitmask for active slave IDs 63-48 (LSB is 48)                                |
| 42014           | 2013                      | Bitmask for active slave IDs 79-64 (LSB is 64)                                |
| 42015           | 2014                      | Bitmask for active slave IDs 95-80 (LSB is 80)                                |
| 42016           | 2015                      | Bitmask for active slave IDs 111-96 (LSB is 96)                               |
| 42017           | 2016                      | Bitmask for active slave IDs 127-112 (LSB is 112)                             |
| 42018           | 2017                      | Bitmask for active slave IDs 143-128 (LSB is 128)                             |
| 42019           | 2018                      | Bitmask for active slave IDs 159-144 (LSB is 144)                             |
| 42020           | 2019                      | Bitmask for active slave IDs 175-160 (LSB is 160)                             |
| 42021           | 2020                      | Bitmask for active slave IDs 191-176 (LSB is 176)                             |
| 42022           | 2021                      | Bitmask for active slave IDs 207-192 (LSB is 192)                             |
| 42023           | 2022                      | Bitmask for active slave IDs 223-208 (LSB is 208)                             |
| 42024           | 2023                      | Bitmask for active slave IDs 239-224 (LSB is 224)                             |
| 42025           | 2024                      | Bitmask for active slave IDs 255-240 (LSB is 240)                             |
| 42026           | 2025                      | Gateway power supply voltage in mV                                            |
| 42027           | 2026                      | Radio packets received count                                                  |
| 42028           | 2027                      | Radio packets sent count                                                      |
| 42029           | 2028                      | RS-485 messages received count                                                |
| 42030           | 2029                      | RS-485 messages sent count                                                    |
| 42031           | 2030                      | Total Modbus errors from master and slaves                                    |
| 42032           | 2031                      | Modbus exceptions from slave nodes                                            |
| 42033           | 2032                      | Radio packets received/transmitted per minute. Recommended to be less than 60 |
| 42034           | 2033                      | Radio packets per minute alert. 0 if packets/min <= 60, 1 if packets/min > 60 |
| 42101           | 2100                      | Address test register. Always returns 2100                                    |
| 42102           | 2101                      | Address test register. Always returns 2101                                    |
| 42103           | 2102                      | Address test register. Always returns 2102                                    |

|       |      |                                                                                                                                          |
|-------|------|------------------------------------------------------------------------------------------------------------------------------------------|
| 43001 | 3000 | Write the radio address of a Modbus Stick node to this register to cause that Modbus Stick to perform a scan for attached Modbus sensors |
| 43004 | 3003 | Write Modbus ID for a Modbus Client node to this register to cause that remote node to perform a scan for attached Modbus sensors        |
|       |      |                                                                                                                                          |
| 44002 | 4001 | Status of Slave ID 1:Returns 1 if Slave is present and 0 if not present                                                                  |
| 44003 | 4002 | Status of Slave ID 2:Returns 1 if Slave is present and 0 if not present                                                                  |
| ...   | ...  | ...                                                                                                                                      |
| 44241 | 4240 | Status of Slave ID 240:Returns 1 if Slave is present and 0 if not present                                                                |

Firmware updates for both the gateway (ARM) and the built-in radio are possible over the RS-232 debug interface using the SignalFire Toolkit, or over a remote TCP connection if an Ethernet Gateway module is used.

### Gateway (ARM) Firmware update steps

- 1 Open the SignalFire Toolkit application.
- 2 Open the correct COM port connected to the RS-232 port of the gateway.
- 3 Go to the **Update** menu and select **Update Gateway Firmware**.
- 4 The latest gateway firmware file will be selected by default.
- 5 Click **Start Upgrade**.

### Gateway Radio Firmware update steps:

- 1 Open the SignalFire Toolkit application.
- 2 Open the correct COM port connected to the RS-232 port of the gateway.
- 3 Go to the **Update** menu and select **Update Radio Firmware**.
- 4 The latest radio firmware file will be selected by default.
- 5 Click **Start Upgrade**.

### Rescue Gateway (ARM) Bootload

If in the process of a firmware update there is a power failure or other communications failure it may be necessary to do a "rescue bootload." If the base LED is solid on and/or the Toolkit is unable to communicate with the Gateway the following process is necessary.


- 1 Remove DC power to the Gateway.
- 2 Open the SignalFire Toolkit application.
- 3 Open the correct COM port connected to the RS-232 port of the gateway.
- 4 Go to the **Update** menu and select **Update Gateway Firmware**.
- 5 The latest gateway firmware file will be selectable by default.
- 6 Click **Start Upgrade**.
- 7 Now re-connect the DC power to the gateway. The firmware update process should start. If the firmware update does not start remove power for at least 10 seconds and re-try.

## Remote Shutdown (RSD) and Local Digital Output Control

# 11

The SignalFire Gateway supports **Internal Logic Control** capability which enables the Gateway to control output relays on SignalFire RSD sticks as well as the two digital outputs local to the Gateway

The SignalFire Gateway Stick receives data from multiple remote nodes. It can use the data from those remote nodes to set the relay output on one or more remote RSD sticks. An example of the topology is shown in the following figure:



From the Gateway configuration window within the SignalFire Toolkit, go to the **Settings** menu and select **Remote Shutdown Settings**. This will open the RSD configuration window.

### Source Node Section

| Source Node |           |                  |               |                        |  |
|-------------|-----------|------------------|---------------|------------------------|--|
| Slave ID    | Node Type | Register Address | Register Type | Current Register Value |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |
| 0           | None      | 0                | 16bit UINT    | Unknown                |  |

The source node section is used to select the source register for the logic rule.

**Slave ID** – The Modbus Slave ID of the remote source node.

**Node Type** – Drop-down list of standard SignalFire remote nodes. Select the type of remote node here, or select **Custom** for manual data entry.

**Register Address** – Select the register address for the data to use for the logic, or manually enter the register address if **Custom** was select for the node type.

**Register Type** – The correct register data type will automatically be selected unless **Custom** is used. If using a custom register address, select the correct data type here.

**Current Register Value** – Displays the value of the selected source data register. Clicking the **Update** button will refresh this value.

| Relay Control Logic                       |       |                                                   |       |                       |   |
|-------------------------------------------|-------|---------------------------------------------------|-------|-----------------------|---|
| Run System<br>(Energize Relay)<br>when... | Value | Shutdown System<br>(De-energize Relay)<br>when... | Value | Number of<br>Readings |   |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |
| Greater than ▼                            | 0     | Less than ▼                                       | 0     | 1                     | ▼ |

The relay control logic section is used to set the trigger thresholds for the selected source data register.

**Run System (Energize Relay)** – Select the logic operand to use for the “energize” logic evaluation.

**Value** – The value that the relay will be energized. Note that the energized state is the normal “operating” state of the relay.

**Shutdown System (De-Energize Relay)** – The logic operand to use for the “de-energize” logic evaluation. This will automatically be the opposite of the selection for the energize case. Note that the de-energized state is the SAFE state of the relay.

**Value** – The value that the relay will be de-energized. Note that the de-energize state is the “safe” state of the relay.

**Number of Readings** – This field contains the number of check-in packets that must be received in a row that are above (or below) the logic threshold for the de-energize condition. This is useful so that a single (possibly a glitch) reading does not cause a shut-down. The default is 1 where each check-in will cause the rule to be evaluated and acted on. A single reading that satisfies the run system (energize) condition will cause the relay to energize.

| Destination Counter/RSD Stick |               |                                |
|-------------------------------|---------------|--------------------------------|
| Slave ID                      | Relay Channel | Current Relay State (readonly) |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |
| 0                             | 1             | Unknown                        |

**Slave ID** – The Slave ID of the destination RSD Stick, or the slave ID of the Gateway (default 247) for the local digital outputs.

**Relay Channel** – Select the relay or digital output channel to switch

**Current Relay State** – Shows the last value of the relay or digital output as reported to the gateway. Clicking the Update button will refresh this value.

After filling out the table click **Write Remote Shutdown Settings to Gateway** to store the setting in the gateway Stick.

## Example

| Source Node |                  |                   |               |                        | Relay Control Logic    |       |                           |       |                    | Destination Counter Stick |               |                                |
|-------------|------------------|-------------------|---------------|------------------------|------------------------|-------|---------------------------|-------|--------------------|---------------------------|---------------|--------------------------------|
| Slave ID    | Node Type        | Register Address  | Register Type | Current Register Value | Energize Relay when... | Value | De-energize Relay when... | Value | Number of Readings | Slave ID                  | Relay Channel | Current Relay State (readonly) |
| 1           | Sentinel Analog  | 3001-Current(μA)  | 16bit UINT    | 14495                  | Greater than           | 14000 | Less than                 | 13000 | 1                  | 5                         | 1             | Energized                      |
| 2           | A2 Analog        | 1003-Digital In   | BOOLEAN       | 1                      | Equal to               | 1     | Equal to                  | 0     | 1                  | 5                         | 1             | Energized                      |
| 3           | Sentinel HART    | 4005-HART PV      | 32bit FLOAT   | 8.22507                | Greater than           | 3.15  | Less than                 | 3.05  | 1                  | 5                         | 1             | Energized                      |
| 4           | Sentinel Digital | 3012-Digital In 1 | BOOLEAN       | 0                      | Equal to               | 0     | Equal to                  | 1     | 1                  | 5                         | 1             | Energized                      |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |
| 0           | None             | 0                 | 16bit UINT    | Unknown                | Greater than           | 0     | Less than                 | 0     | 1                  | 0                         | 1             | Unknown                        |

Line 1 has been configured with a source data node as a Sentinel-Analog with the loop current (in μA) as the selected register. The relay will energize when the loop current is above 1400μA (14mA) and de-energize when the loop current is below 1300μA (13mA). Note that this configuration has a 1000μA (1mA) hysteresis factor.

In this example all 4 source nodes are assigned to the same destination Slave ID and relay channel so the following statement applies:

**If more than one rule is assigned to the same destination RSD Stick (or gateway output) and relay channel, then all of the rules must meet the energize condition for the remote relay to be energized.**

**Alternatively, this means that if any one of the four source node's logic results in the "de-energize" condition being true the relay will be de-energized (safe).**

## Options

There are two check boxes for additional logic options.

- ☐ Failsafe Enabled - Missing Slave or Register results in Relay being De-energized
- ☐ Latch De-energize - Requires RTU to Re-energize Relay via Modbus Coil Write

***Failsafe Enabled*** – If this option is selected **all** rules must have valid data for the relay to be energized. If one or more of the nodes times-out or does not exist the relay will be de-energized.

If this option is not selected, then a node that is not installed or fails to check in will be ignored and the relay will be energized using logic only from the units that are active.

***Latch De-Energized*** – If this option is selected the rules may only de-energize the relay. For the relay to be energized again a Modbus write from a PLC to the gateway for the destination RSD stick relay must occur. This is useful if manual intervention is required before the relay is energized after an event. In the example above, a Modbus coil write to Slave ID 5 relay channel 1 (which is register 1) is required to energize the relay. See the RSD Stick manual for a detailed register map.

The “Normal” state of the relay or digital output is the un-energized state and this state should be used to set the controlled system (pump, motor,...) in the “safe” or “off” state.

## Slave Register Remapping

# 17

The gateway allows any of the remote register data to be remapped to a single block of registers available at the Gateway's slave ID (default is 247). This is useful for collecting a subset of register data from multiple nodes and making it readable in a single block of registers. Up to 750 registers can be remapped to the gateway's slave ID starting at register 5000.

To configure the remapping, first select **Slave Register Remapping** from the **Settings** dropdown menu.

|   | Remapped Address | Slave ID | Register Address | Node Name  | Data Type  | Register Value | Description           |
|---|------------------|----------|------------------|------------|------------|----------------|-----------------------|
| ▶ | 5000             | 1        | 3001             | Analog4-20 | 16bit UINT | 14479          | Sensor A Current (uA) |
|   | 5001             | 1        | 65531            | Analog4-20 | 16bit INT  | -47            | RSSI (dB)             |
|   | 5002             | 1        | 65532            | Analog4-20 | 16bit UINT | 3195           | Battery Voltage (mV)  |
|   | 5003             | 3        | 3012             | Digital    | 16bit UINT | 0              | Counter1 (state)      |
|   | 5004             | 3        | 3018             | Digital    | 16bit UINT | 0              | Counter2 (state)      |
|   | 5005             | 3        | 65531            | Digital    | 16bit INT  | -47            | RSSI (dB)             |
|   | 5006             | 3        | 65532            | Digital    | 16bit UINT | 3736           | Battery Voltage (mV)  |
|   | 5007             | 5        | 3001             |            | 16bit UINT | 65535          |                       |
|   | 5008             | 5        | 65531            |            | 16bit INT  | -1             | RSSI (dB)             |
|   | 5009             | 5        | 65532            |            | 16bit UINT | 65535          | Battery Voltage (mV)  |
|   | 5010             |          |                  |            | 16bit UINT |                |                       |
|   | 5011             |          |                  |            | 16bit UINT |                |                       |
|   | 5012             |          |                  |            | 16bit UINT |                |                       |

Read Mapping from Gateway

Write Mapping to Gateway

Clear Table

Save to File

Load from File

Clear Gateway

Display

☒ Apply Default Register Map

☐ Show Register Addresses in HEX

☐ Show Data Values in HEX

Fail Mode

☒ Fail with High Value

☐ Fail with Last Value (else High)

☐ Fail with Low Value

☐ Fail with Last Value (else Low)

Enter the remote slave ID and register address to map to each gateway register and click **Write Mapping to Gateway** to remap the register(s).

The **Node Name**, **Data Type**, **Register Value**, and **Description** fields will automatically be filled in by the gateway once the mapping is written to the gateway. If the gateway does not have data for a remapped value it will respond with 0xFFFF, or 0x0000 for the register request, this is configurable globally with the **Fail Mode** settings.

In the example above, slave ID 1 is a Sentinel-Analog with has been mapped to have sensor current, RSSI and battery voltage available at gateway registers 5000 through 5002. Note that slave ID 5 is not currently reporting data to the gateway so its registers are failing "high."

## Remote Node Configuration

# 18

The SignalFire Gateway allows configuration changes to be made to any of the connected SignalFire remote nodes wirelessly. To use this feature, access to the Gateway debug port is required. This may be accessed over a TCP/IP network using a SignalFire Ethernet Gateway module, or by a direct connection to the Gateway RS232 port.

To start a remote configuration session with a remote node, select the check-box next to the node to configure and click **Start Configuration**.

IP Addr:Port sfserver.signal-fire.com:100

Connected to sfserver.signal-fire.com:10002

Open Close Offline

☒ TCP Connection Clear Saved IPs

Connect/Update

|                      |             |
|----------------------|-------------|
| Product              | GATEWAY     |
| Supply Voltage       | 8.607       |
| Bootloader Version   | 2.00        |
| Gateway Version      | 7.75        |
| Gateway Version Date | 24-Nov-2014 |
| Radio Version        | 2.49        |
| Radio Address        | 4482        |
| Corporate ID         | 0           |
| Radio Network        | 3           |
| Radio Network Group  | 0           |
| Radio Power (dBm)    | 5           |
| Gateway Slave ID     | 247         |
| RS485 Baud Rate      | 57600       |
| RS485 UART Mode      | 8N1         |
| Registers in Use     | 54 of 4700  |
| Slave Entries in Use | 3 of 240    |
| NodeChecker Password | not set     |
| Remote Sensor Config | Unlocked    |

Settings

Radio Network 3 Set

Radio Network Group 0 Set

NodeChecker Password (case-sensitive) Set

Modbus Slaves Reporting

Double-click a Row to View Registers

Refresh

| Slave ID | Node Name  | Radio Address | Register Quantity | Register Timeout (min) | Mainboard Firmware | Radio Firmware  | Configure                           |
|----------|------------|---------------|-------------------|------------------------|--------------------|-----------------|-------------------------------------|
| 100      | YokoEJA    | 7999          | 18                | 7                      | 0.21               | 2.49 (sleeping) | <input type="checkbox"/>            |
| 143      | VEGAPULS62 | 50000         | 18                | 6                      | 0.19               | 2.49 (sleeping) | <input checked="" type="checkbox"/> |
| 144      | ROSEMOUNT  | 7008          | 18                | 7                      | 0.20               | 2.49 (sleeping) | <input type="checkbox"/>            |

Update List of Reporting Modbus Slaves

Gateway RS485 Settings

Gateway Slave ID 247 Set

Baud Rate 57600 Set

UART Mode 8N1 Set

Gateway Slave ID Word/Byte Order

☒ High Word/High Byte (ABCD)

☐ High Word/Low Byte (BADC)

☐ Low Word/High Byte (CDAB)

☐ Low Word/Low Byte (DCBA)

Set

Configuration

Ready

Start Configuration

If the node has an awake radio the remote configuration session will be ready immediately. If it is a sleeping node you must wait for the node to either check-in or send a "beacon" so that it can be commanded into configuration mode. The Sentinel nodes send a beacon every 2.5 minutes, while all other sleeping nodes send a beacon every 5.5 minutes. When the node has entered a remote configuration session you will see a message indicating the slave is ready. Click **Configure** to open the configuration window (image on next page).

Make any necessary changes and click the corresponding **Set** button to save the changes. When finished with the configuration, close the configuration window and then click the **End** button in the Gateway window to end the session. The session will also automatically time-out after 15 minutes of inactivity and the Node will resume normal operation.



## Gateway Event Log

21

Starting with Gateway Firmware version 7.81 the Gateway keeps an internal log of events. The event log can be viewed from the gateway window of the ToolKit by selecting 'View Gateway Log' from the Tools menu. The gateway log events such as reboots, remote nodes joining/timing out, local RSD control events, remote configuration sessions, firmware updates, and more.

### Revision History

| Revision | Date     | Changes/Updates                          |
|----------|----------|------------------------------------------|
| 1.0      | 10/02/15 | Initial Release for DIN Gateway          |
| 1.1      | 2/26/16  | Added FCC/IC certification details       |
| 1.2      | 4/6/16   | Added detail for Gateway digital outputs |
| 1.4      | 4/14/16  | Updated IC statements                    |

## **APPENDIX - FCC and IC Statements**

22

Changes or modifications not expressly approved by SignalFire Telemetry, Inc could void the user's authority to operate the equipment.

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

This device has been designed to operate with the antennas listed below, and having a maximum gain of 5.8 dBi. Antennas not included in this list or having a gain greater than 5.8 dBi are strictly prohibited for use with this device. The required antenna impedance is 50 ohms.

- San Jose Technology Inc.                      Model EEH-915
- Nearson                                              Model: S467XX-915S

To reduce potential radio interference to other users, the antenna type and its gain should be so chosen that the equivalent isotropically radiated power (e.i.r.p.) is not more than that permitted for successful communication.

To comply with FCC's and IC's RF radiation exposure requirements, the antenna(s) used for this transmitter must be installed such that a minimum separation distance of 20cm is maintained between the radiator (antenna) & user's/nearby person's body at all times and must not be co-located or operating in conjunction with any other antenna or transmitter.

This device complies with Industry Canada's licence-exempt RSSs. Operation is subject to the following two conditions:(1) This device may not cause interference; and (2) This device must accept any interference, including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes : (1) l'appareil ne doit pas produire de brouillage, et (2) l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.