

B8 B7 D7 00 01 17

REFER TO #77-000044-001 REV B FOR INSTALLATION INSTRUCTIONS.
WEEKLY TESTING IS REQUIRED TO ENSURE PROPER
OPERATION OF THE SYSTEM.
DO NOT CONNECT AC POWER TO A RECEPTACLE CONTROLLED
BY A SWITCH.
POWER SUPPLY: 5.0VDC, 0.2A.
TRANSCIVER FREQUENCY: 910 TO 920 MHz.



FCC ID: WDQ-BRDG
IC: 7994A BDRG
COMPLIES WITH: RSS-101C
EN CONFORMITE AVEC
IC CNR 210



WWYYY 44-000072-001 x3