

Date: 2025/3/25

**System Check\_1750MHz****D1750V2-SN:1137**


Communication System: CW; Frequency: 1750.0 MHz; Duty Cycle: 1:1  
Medium: HSL Medium parameters used:  $f = 1750.0$  MHz;  $\sigma = 1.34$  S/m;  $\epsilon_r = 41.9$   
Ambient Temperature: 23.4°C; Liquid Temperature: 22.4°C

**DASY6 Configuration:**

- Probe: EX3DV4 - SN3819; ConvF(7.94, 7.08, 7.50); Calibrated: 2024/8/22
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1386; Calibrated: 2024/8/30
- Phantom: ELI V5.0 (20deg probe tilt); Serial: 1233; Section: Flat
- Measurement Software: cDASY6 V16.0.0.116
- UID: CW, 0--

**Area Scan (40.0 mm x 120.0 mm):** Measurement Grid: 5.0 mm x 15.0 mm  
SAR (1g) = 8.80 W/kg; SAR (10g) = 4.78 W/kg;

**Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0mm x 1.5 mm  
Power Drift = 0.00 dB  
SAR (1g) = 8.75 W/kg; SAR (10g) = 4.74 W/kg  
Smallest distance from peaks to all points 3 dB below = 10.8 mm  
Ratio of SAR at M2 to SAR at M1 = 83.3 %



Date: 2025/3/25

**System Check\_1900MHz****D1900V2-SN:5d182**

Communication System: CW; Frequency: 1900.0 MHz; Duty Cycle: 1:1  
Medium: HSL Medium parameters used:  $f = 1900.0$  MHz;  $\sigma = 1.44$  S/m;  $\epsilon_r = 41.7$   
Ambient Temperature: 23.6°C; Liquid Temperature: 22.6°C

**DASY6 Configuration:**

- Probe: EX3DV4 - SN3819; ConvF(7.95, 7.09, 7.51); Calibrated: 2024/8/22
- Sensor-Surface: 1.4 mm
- Electronics: DAE4 Sn1386; Calibrated: 2024/8/30
- Phantom: ELI V5.0 (20deg probe tilt); Serial: 1233; Section: Flat
- Measurement Software: cDASY6 V16.0.0.116
- UID: CW, 0--

**Area Scan (40.0 mm x 120.0 mm):** Measurement Grid: 5.0 mm x 15.0 mm  
SAR (1g) = 10.9 W/kg; SAR (10g) = 5.70 W/kg;

**Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm):** Measurement Grid: 6.0 mm x 6.0mm x 1.5 mm  
Power Drift = 0.00 dB  
SAR (1g) = 10.7 W/kg; SAR (10g) = 5.52 W/kg  
Smallest distance from peaks to all points 3 dB below = 9.7 mm  
Ratio of SAR at M2 to SAR at M1 = 82.6 %

